

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[SEE SUB-RULE (1) OF RULE 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/2014/W2/462

Dated: 09/09/2014

Fire Safety Certificate

Certified that the **Banquet Hall** at 16, Shivaji Marg, Main Najafgarh Road Inustiral Area, New Delhi-110015 comprised of ground and one upper floor (and terrace floor room for kitchen) owned/occupied by M/s S & S Hospitality Services Inc. was issued NOC/FSC vide this office letter No. F6/MS/DFS/2011/156 dated 25/01/2011. The premises was re-inspected by the officers concerned of this department on 21/03/2014 and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have therefore, deemed complied with the requirement under Rule 33 of the Delhi Fire Service Rule 2010 and the building/premises is fit for **Class-D Assembly** occupancy with effect from.....09/09/14.....for a period of three year in accordance with rule 36 unless renewed under 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under 38 of the Delhi Fire Service Rule 2010.

Issued on.....09/09/14.....at New Delhi by

(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in

Copy to:

Sh. Sameer Arora

Banquet Hall at 16, Shivaji Marg, Main Najafgarh Road. Inustiral Area, New Delhi-110015

Note :- For general fire safety directives please over leaf.

Following fire safety directives must be adhered to:-

- 1) All the means of escape shall be kept free of all type of obstruction all the time.
- 2) All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
- 3) All the fire fighting equipment shall be maintained in perfect working condition all the time and lapse rendering non-functional of fire safety measures, management shall be responsible.
- 4) Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
- 5) Basement shall be used as per NBC.
- 6) This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

Renewal

1. Name & address of the building : **M/s S & S Hospitality Services Inc.** at 16, Shivaji Marg, Main Najafgarh Road Indl. Area, New Delhi-110015
2. Type of Occupancy : **Banquet Hall/Assembly (Basement and ground floor)**
3. Type of Case : **Renewal**
4. Details of previous NOC : **F6/MS/DFS/2011/156 dated 25/01/2011**
5. Fire Safety directives letter No. : **N.A.**
6. Date of inspection : **21.03.2014**
7. Name of the Inspecting Officers : **Divisional Officer Sunil Chawdhary**
8. Name and designation of officers
From the building side : **Mr. Sameer Arora**
9. Year of Construction :
10. Applicant's letter No. : **nil dated 06-03-2014**

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Old case	12 mtr	M.R.
	• Gate width	Old case	Old case	Old case
	• Width of internal road	N.R.	N.R.	N.R.
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	2	Provided	M.R.
	• Basement	N.A.	N.A.	N.A.
	b. Width of staircases			
	• Upper Floors	2 mtr	Provided	M.R.
	• Basement	N.A.	N.A.	N.A.

	c. Protection of exits			
	• Fire check door	Required	Provided	M.R.
	• Pressurization	N.R.	N.R.	N.R.
	d. No. of continuous staircases to terrace	2	2	M.R.
	e. Width of Corridor	Halls only	Halls only	M.R.
	f. Door size	Old case	Old case	Old case
3.	Compartmentation.			
	• Fire check door	required	Provided	M.R.
	• Sealing of electrical shafts	N.A.	N.A.	N.A.
	• Fire Rating of shaft door	N.R.	N.R.	N.R.
	• Water Curtain	N.R.	N.R.	N.R.
	• Fire Dampers	N.R.	N.R.	N.R.
4.	Smoke Management System.			
	• Basements	N.A.	N.A.	N.A.
	• Upper floors	Required	Provided	M.R.
5.	Fire Extinguishers			
	• Total numbers	18	22	M.R.
	• Types	Water CO ₂ & CO ₂ Required	Provided	M.R.
	• IS marking	ISI marks required	provided	M.R.
6.	First-Aid Hose Rees.			
	• Total numbers on each floor	2	Provided	M.R.
	• Length of hose reel hose	30 m required	Provided	M.R.

	• Nozzle diameter	5 mm required	Provided	M.R.
7.	Automatic fire detection and alarming system.			
	• Type of detectors	N.R.	Provided	M.R.
	• Location of Main Panel	G.F	Provided	M.R.
	• Location of Repeater Panel	G.F.	Provided	M.R.
	• Alternate source of power	Required	Provided	M.R.
	• Hooter's Location	Required all over	Provided	M.R.
8.	MOEFA	Required	Provided	M.R.
9.	Public Address System.	Not Required	Provided	M.R. ✓
10.	Automatic Sprinkler system			
	• Basement	N.A.	N.A.	N.A.
	• Upper Floor	N.R.	Provided	M.R. ✓
	• Sprinkler above false ceiling	Required	Provided	M.R.
11.	Internal Hydrants			
	• Size of riser/down-comer	150 mm	Provided	M.R.
	• Number of hydrants per floor	2	Provided	M.R.
	• Hose Box	2	Provided	M.R.
12.	Yard Hydrants.			
	• Total number of hydrants	N.R.	N.R.	N.R.
	• Hose Box	N.R.	N.R.	N.R.

13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	N.A.	N.A.	N.A.
	➤ Head of Main pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey Pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting/Manual stopping	N.A.	N.A.	N.A.
	➤ Pump Hose Access	N.A.	N.A.	N.A.
	Terrace level			
	➤ Discharge of pump	900 LPM & 180 LPM (jockey)	Provided	M.R
	➤ Head of the pump	25 mtr	Provided	M.R.
	➤ Power supply	Required	Provided	M.R.
	➤ Auto Starting of pump	required	Provided	M.R.
14.	Captive Water Storage for fire fighting.			
	Underground tank capacity			
	➤ Draw -off connection	N.A.	N.A.	N.A.
	➤ Fire service inlet	N.A.	N.A.	N.A.
	➤ Access to tank	N.A.	N.A.	N.A.

	➤ Overhead Tank Capacity	15,000 ltrs	Provided	M.R.
15	Exit Signage.	Required	Provided	M.R.
16.	Provision of Lifts			
	• Pressurization of Lift Shaft	N.R.	N.R.	N.R.
	• Pressurization of Lift lobby	N.R.	N.R.	N.R.
	• Communication In lift Car	N.R.	N.R.	N.R.
	• Fireman's Grounding Switch	N.R.	N.R.	N.R.
	• Lift Signage	N.R.	N.R.	N.R.
17.	Standby power supply	Required	Provided	M.R.
18.	Refuge Area			
	➤ Total Area	N.R.	N.R.	N.R.
	➤ Location	N.R.	N.R.	N.R.
19.	Fire Control Room			
	➤ Detector System Panel	N.R.	N.R.	N.R.
	➤ Flow Switch Panel	N.R.	N.R.	N.R.
	➤ PA system Panel	N.R.	N.R.	N.R.
	➤ Batter backup	N.R.	N.R.	N.R.
	➤ Building Floor plans	N.R.	N.R.	N.R.
20.	Special Fire Protection Systems for	N.R.	N.R.	N.R.

	Protection of special Risks, if any:			
--	--------------------------------------	--	--	--

The fire protection systems provided in the building were test checked and found functional at the time of inspection. In view of the deemed compliance of the minimum standard of fire prevention and fire safety measure as required under the rules the NOC issued vide letter no. F6/MS/DFS/2011/156 dated 25/01/2011 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended

Signature of the Inspection Officer

Signature of the Inspection Officer

Name Sunil Chawdhary

Name

Designation D.O. (M.N.)

Designation

