

NO. F6/DFS/MS/EH/2014/SZ/ 463

DATED: 08/04/14

FIRE SAFETY CERTIFICATE

Certified that the Shubham Valley Restaurant, Vikas Surya Arcade, Plot No. 8, Unit No.101, Sector-11 Dwarka, New Delhi running at 1st floor of the building comprising ground plus three upper floors, was granted NOC by this department vide letter No. F6/DFS/MS/EH/2010/1568 Dated 28.5.2010. The premises was re-inspected by officers concerned of this department on 26.3.2014 in the presence of Mr. Biju Gopal, Manager of the restaurant and found that the management of the restaurant have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 33 of the Delhi fire service and that the building is fit for occupancy class D "Assembly building (Restaurant)" with effect from...08/04/14... for a period of **three** years in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on ...08/04/14... at New Delhi by



(Dr. G.C. Misra)
Chief Fire Officer
Ph.011-23414333

o/c m/s

Copy To:-

1. DHO/West Zone, Deputy Health Officer, Municipal Corporation of Delhi, Najafgarh Zone New Delhi.
2. Manager, Shubham Valley Restaurant Plot No. 8, Vikas Surya Arcade Dwarka, New Delhi.

Conditions for the validity of fire safety certificate

1. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye laws.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules-2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1	Name & address of the building	M/S Subham Valley Restaurant , Vikas Surya Arcade, Plot No.8, Sector-11 Dwarka, New Delhi.		
2	Type of Occupancy	Assembly "D" Restaurant		
3	Type of case	Renewal		
4	Details of previous NOC	No. F-6/DFS/MS/EH/2010/1568 Dated 28.5.2010		
5	Fire safety directives letter No	Nil		
6	Date of inspection	26.3.2014.		
7	Name of the inspecting Officers :	ADO S.P Bhardwaj & S K Tomar D O		
8	Name and designation of officers from the building side	Mr Biju Gopal (Manager)		
9	Year of construction	2006	Restaurant Runinig at 1st Floor	
		Nil Dated 19.3.2014.	Ground + 3 upper Floors	
10	Applicant's letter No.			
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Old Case /NBC Requirement	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	6 mtrs	18 mtrs.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	One	One	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.5 Mtrs.	1.5 Mtr	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	One	One	
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1.70, 1.25 Mtrs.	1.70 , 1.25 Mtr.	MR(old case)
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	N/A	N/A	N/A
	upper floors		Exhust Fans provided	MR

Case - Renewal

Page - 1

Subham Valley Restaurant

5	Fire Extinguishers			
	total numbers		5 Nos	MR
	Types	5 Nos ABC, Co2	ABC, Co2,	MR
	ISI marking	ISI Marked	Yes	MR
6	First-Aid Hose Reels.			
	total numbers on each floor	1 No.	Provided	MR
	Length of Hose reel hose	30 m	Provided	MR
	Nozzle Diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system			
	Type of detectors	Heat/Smoke	Provided(Smoke)	M/R
	location of Main Panel	1st Floor	1st Floor	M/R
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	Required	Provided	MR
	hooter's location	1st Floor	Staircase 1st Floor	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	Required(1st Floor)	Provided	old case
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	100 mm	Provided	M/R
	Number of Hydrants per floor	1 No.	provided	M/R
	hose Box	1st Floor	Provided	M/R
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level/			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	450,180 Lpm.	450 ,180 LPM	MR(old case)
	b. head of the pump	40 Mtrs	40 Mtrs	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	5000 Lts.	5000 Ltrs.	MR(old case)
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A

N/S

17	Standby power supply	Required	Provided	MR
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: ABC Provided			

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards of fire prevention and fire safety required under the rule 33 of the Delhi Fire Service Rules, 2010, renewal of fire safety certificate is recommended.

Accordingly DFA is put up for approval and signature please.

Surya
28/3/14

Signature of the Inspecting Officer

Name S.P Bhardwaj

Designation ADO (DWARKA)

Do/SW

F.S.C. (renewal) for restaurant is put up for approval please.

K. Jamer
29/3/14