

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/2014/School/142/471

Dated: 11/4/14

FIRE SAFETY CERTIFICATE

Certified that the **Rising Star Academy Senior Secondary School** located at **110, Raj Nagar, Pitampura, Delhi - 110034** comprised of Ground + 03 Upper Floors was issued FSC vide Letter No. F6/DFS/MS/09/1408 dated 25-05-2009. The premises was re inspected by the officers concerned of this department on 20-02-2014 in the presence of Mr. Pradeep (Manager) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class " Educational Building" Group B with effect from 11/4/14 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on11/4/14..... at New Delhi by.

(Santokh Singh)
Chief Fire Officer,
Ph: 011 - 23414250.

Copy to:

1. The Principal,
Rising Star Academy Senior Secondary School,
110, Raj Nagar, Pitampura, Delhi - 110034.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: Rising Star Academy, 110, Raj Nagar,
Pitampura, Delhi-110034
2. Type of Occupancy : Educational
3. Type of Case : Renewal (G+3 upper floors)
4. Details of previous NOC : Letter No F.6/DFS/MS/09/1408 dated 20-05-09
5. Fire Safety directives Letter No. : DOE circular 262-362
6. Date of inspection : 20/02/14
7. Name of the Inspecting Officer : DO(West) & ADD(MN)
8. Name and designation of Officer Ms. Predeep (manager)
from the building side :
9. Year of Construction : 2005
10. Applicant's letter No. : Nil dated 28-01-2014

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL <u>DOE</u> Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	<u>Accessible</u>	<u>Provided</u>	<u>MR</u>
	• Gate width	<u>Accessible</u>	<u>Provided</u>	<u>MR</u>
	• Width of internal road	<u>NA</u>	<u>NA</u>	<u>NA</u>
2.	Number, width, Type & Arrangements of exits			
	g. Number of staircases			
	• Upper floors	<u>2</u>	<u>Provided</u>	<u>MR</u>
	• Basements	<u>NA</u>	<u>NA</u>	<u>NA</u>
	h. Width of staircases			
	• Upper floors	<u>Old case</u>	<u>Old case</u>	<u>MR</u>
	• Basements	<u>NA</u>	<u>NA</u>	<u>NA</u>
	i. Protection of exits			
	• Fire check door	<u>NA</u>	<u>NA</u>	<u>NA</u>
	• Pressurization	<u>NA</u>	<u>NA</u>	<u>NA</u>
	j. No of continuous staircase to terrace	<u>2</u>	<u>Provided</u>	<u>MR</u>

	k. Width Of Corridor	Old case	Old case	MR
	l. Door Size	Old case	Old case	MR
3.	Compartmentation			
	• Fire check door			
	• Sealing of electrical shafts			
	• Fire Rating of shaft door		N/A	
	• Water Curtain			
	• Fire Dampers			
4.	Smoke managements System			
	• Basements	30 a/c per hour		
	• Upper floors	12 a/c per hour		N/A
5.	Fire Extinguishers			
	• Total numbers	8 nos.	Provided	MR
	• Types	CO ₂ & ABC	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First - Aid Hose Reels			
	• Total numbers on each floor	1	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors			
	• Location of Main Panel			
	• Location of Repeater Panel		N/A	
	• Alternate source of power			
	• Hooters' Location			
8.	MOEFA		N/A	
9.	Public Address System		N/A	
10.	Automatic Sprinkler System			
	• Basements			
	• Upper Floor			
	• Sprinkler above false ceiling		N/A	

11.	Internal Hydrants			
	• Size of riser/down- comer	Required	Provided 100 mm	MR
	• Number of hydrants per floor	Required	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants			
	• Hose Box		N/A	
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump			
	➤ Head of main pump			
	➤ Number of main pumps			
	➤ Jockey pump out put			
	➤ Jockey pump head			
	➤ Standby Pump out put			
	➤ Standby Pump Head			
	➤ Auto Staring/Manual stopping			
	➤ Pump House Access			
	• Terrace level			
	➤ Discharge of pump	450 lpm & 100 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	50,000 lts.	Provided	MR
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10000 lts.	Provided	MR
15	Exit Signage	Required	Provided	MR

16.	Provision of Lifts			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 		N/A	
17.	Standby power supply		N/A	
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 		N/A	
19.	Fire control room			
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Battery backup ➤ Building Floor Plans 		N/A	
20.	Special Fire Protection Systems for Protection of special Risks, if any;		N/A	

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/09/1408 dated 25/06/09 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Name Mukesh Verma

Designation ADD(MN)

DO (West) 10/3

Signature of the Inspecting Officer

Name

Designation

CFO/417
31/3/14

