

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001


NO.F6/DFS/MS/School/2014/SZ/ 446

DATED: 04/04/14

FIRE SAFETY CERTIFICATE

Certified that the Neo Great Mission Public School Located at Sector-5 Dwarka New Delhi-110075 Comprised of ground plus two upper floors was granted NOC by this department vide letter No. F6/DFS/MS/2011/547 Dated 25.3.2011 in the name of Great Mission Public School .The school building was re-inspected by the officer concerned of this department on 27.3.2014 in presence of Smt.Vandana Jha principal and found that the school management have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Directorate of Education, Gove of NCT of Delhi, and that the building is fit for occupancy class B "Educational building" with effect from...04.04.14.... for a period of **three** years, subject to condition as mentioned below.

Issued on ...04.04.14..... at New Delhi by



(Dr. GC Misra)
Chief Fire Officer
Ph.011-23414333

Copy to:

1. The Principal, Neo Great Mission Public School Sector-5 Dwarka New Delhi.
2. The Director (Education) GNCT of Delhi , old secretariat New Delhi -54.

Conditions for the validity of fire safety certificate

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules-2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1	Name & address of the building	Neo Great Mission Public School, Sector-5 Dwarka, New Delhi-110075.		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	Renewal		
4	Details of previous NOC	F6/MS/DFS/2011/547 dated 25.3.2011		
5	Fire safety directives letter No	Edu. Circular. No. F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011.		
6	Date of inspection	29.03.2014		
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Smt. Vandana Jha (Principal) & Sh.Uma Shankar		
9	Year of construction	2000		
10	Applicant's letter No.	FNGMPS_F 2014-45 Dated 15.3.2014.	(Ground plus two upper floor)	

--	--	--	--	--

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
--------	---	-----------------	------------------	------------------

1	Access to building			
----------	---------------------------	--	--	--

	1) Road width	Approachable for F E	Approachable	MR
	2) Gate width	5 Mtrs.	5 Mtrs.	MR
	3) Width of internal road	N/A	N/A	N/A

2	Number, width Type & arrangement of exits			
----------	--	--	--	--

	a. Number of staircases			
	1. Upper floors	2 Nos.	2 Nos.	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.5 Mtrs.	1.5 & .75 Mtrs.	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	Required	One	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1 Mtr.	1 Mtr.	MR

3	Compartmentation.			
----------	--------------------------	--	--	--

	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A

4	Smoke Management system.			
----------	---------------------------------	--	--	--

	basement	N/A	N/A	N/A
	upper floors		Natural Vent.	MR

5	Fire Extinguishers			
----------	---------------------------	--	--	--

	total numbers		6 Nos	MR
	Types		Co2 & ABC	MR

6	First-Aid Hose Reels.			
	total numbers on each floor	N/A	Provided	MR
	Length of Hose reel hose	N/A	30 Mtr Provided	MR
	Nozzle Diameter	N/A	5mm	MR
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	MR
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	Provided	N/A
	Number of Hydrants per floor	N/A	Provided	N/A
	hose Box	N/A	Provided	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	450 LPM.	450 LPM , 180 LPM	MR
	b. head of the pump	N/A	40 Mtr.	MR
	c. Power supply	N/A	N/A	MR
	d. Auto starting of pump	N/A	N/A	N/A
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	5000 Lts.	5000 Ltrs.	MR
15	Exit Signage.	N/A	N/A	N/A
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

N/S

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any:	ABC		

The fire protection systems provided in the building were checked and found functional at the time of inspection. In view of the deemed compliance of the minimum standards of fire prevention & fire safety measures as required under rules , the NOC issued vide letter No. F6/DFS/MS/2011/547 Dated.25.03.2011, is recommended for renewal.

Accordingly DFA is put up for approval and signature please.

S.P. Bhardwaj
31/3/14

Signature of the Inspecting Officer

Name S.P. Bhardwaj

Designation ADO (DWK)

D.O. / SW

F.S.C. (renewal) for G+2 storied school bldg is put up for kind approval please.

1
S.P. Bhardwaj
31/3/14