

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. FC/DFS/MS/School/2014/W2/457

Dated: 08/09/2014

FIRE SAFETY CERTIFICATE

Certified that the Mother's Choice An Exclusive School, Lampur Road, Narela, Delhi-110040 comprised of Ground + one upper floor of a three storied building owned / occupied by Mother's Choice An Exclusive School have complied with the fire prevention and fire safety requirements in accordance with the Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education / NBC- Part IV and verified by the officer concerned of Fire Service on 19/02/2014 in the presence of Sh. Dinesh Gupta (Manager) and that the building / premises is fit for occupancy of Educational building with effect from 08/09/2014 for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

- 1 All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
- 2 Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 This certificate cannot be treated in any case for regularizations of unauthorized construction
- 6 The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
Issued on 08/09/14 at New Delhi


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in

Copy to:

1. The Principal, Mother's Choice An Exclusive School, Lampur Road, Narela, Delhi-110040
2. The Director of Education, Old Sectt. Delhi for information



N-1

Gr 2 Two floor

INSPECTION REPORT

1. Name & address of the building: Mother's choice school Campus Road, Narenda
2. Type of Occupancy : educational Delhi-40
3. Type of Case : New Case / Renewal → (FSC Regd. for Gr + one floor only)
2nd floor for residential purpose
4. Details of previous NOC : NIL
5. Fire Safety directives letter No : Dir. of Edu.
6. Date of inspection : 19.2.14
7. Name of the Inspecting Officers : ADP (BIO)
8. Name and designation of officers
from the building side : sh Dinesh Gupta - Manager
9. Year of Construction : 2003
10. Applicant's letter No. : lt. No. MC/14/2014/51 dt. 21.1.14

Plot area: 200 Sq. yards Covered area: 400 Sq. yards No.'s of students: 155 No's of classrooms: 7
(3 room for other purpose)

	Minimum Standards on fire prevention and fire safety U/R 33	Circular Dir. of Edu Requirement/ <u>NBC</u>	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	<u>Accessible</u>	<u>Accessible</u>	<u>MR</u>
	• Gate width	<u>—</u>	<u>—</u>	<u>—</u>
	• Width of internal road	<u>—</u>	<u>—</u>	<u>—</u>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	<u>—</u>	<u>—</u>	<u>—</u>
	• Upper Floors	<u>1</u>	<u>2</u>	<u>MR</u>
	• Basements	<u>—</u>	<u>—</u>	<u>—</u>
	b. Width of staircases	<u>—</u>	<u>—</u>	<u>—</u>
	• Upper Floors	<u>1.50 mtr</u>	<u>1.23 + .80 mtr</u>	<u>MR</u>
	• Basements	<u>—</u>	<u>—</u>	<u>—</u>
	c. Protection of exits	<u>—</u>	<u>—</u>	<u>—</u>
	• Fire check door	<u>—</u>	<u>—</u>	<u>—</u>
	• Pressurization	<u>—</u>	<u>—</u>	<u>—</u>
	e. No. of continuous staircases to terrace	<u>—</u>	<u>—</u>	<u>—</u>
	g. Width of Corridor	<u>—</u>	<u>—</u>	<u>—</u>
	h. Door Size	<u>1 mtr</u>	<u>1 mtr</u>	<u>MR</u>

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 			N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour		N/A
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	5 ABC ISI marked	5 ABC	MR -do- -do-
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	30 m 5 mm		N/A
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 			N/A
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 			N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 			N/A

12	Yard Hydrants.		
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	N/A	
13	Pumping Arrangements.		
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N/A	
14	Captive Water Storage for fire fighting.		
	<ul style="list-style-type: none"> • Underground tank capacity <ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	N/A	
15	Exit Signage.		
16	Provision of Lifts.		
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	
17	Standby power supply		

N-4

18	Refuge Area.			
	➤ Total Area			
	➤ Location			
19	Fire Control Room			
	• Detector System Panel			
	• Flow Switch Panel			
	• PA System Panel			
	• Batter backup			
	• Building Floor Plans			
20	Special Fire Protection Systems for Protection of special Risks, if any:			

N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....NIL.....

Signature of the Inspecting Officer

Name

Designation

[Signature]
[Signature]
24/3/14

Signature of the Inspecting Officer

Name

Designation

[Signature]
24/3/14
HO (B.W.)

215/DC/2014
31/2/14