

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593

No.F.6/DFS/MS/School/2014/ 52/437

Dated: 03/04/14

FIRE SAFETY CERTIFICATE

Certified that the building of **Green Valley International Public School** located at 205, Deepak Vihar (Near Udaseen Ashram), Najafgarh, New Delhi-110043 is comprised of ground floor plus one upper floor was issued NOC by this department vide letter No.F.6/DFS/MS/2010/2654 dated 10.09.2010. The School building was re-inspected by the officer concerned of this department on 21.03.2014 in the presence of Sh. Om Parkash Gautam (Manager) and found that the school management have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/ premises is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed overleaf.


Issued on.....03/04/14.....at New Delhi.



(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph:- 011-23414333

Copy to:-

1. The Manager,
Green Valley International Public School,
205, Deepak Vihar (Near Udaseen Ashram),
Najafgarh, New Delhi-110043.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi - 110054.



Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/ occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

N/4 Ground floor and one upper floor

INSPECTION REPORT

1. Name & address of the building: Green Valley International Public School, 205, Deepak
2. Type of Occupancy: Educational (School) Vihar, Nafat Garh, N.O. 43.
3. Type of Case: New Case/Renewal
4. Details of Previous NOC: Letter No. F.G/DFS/MS/2010/2654 Dated 16.09.2010
5. Fire Safety directives letter No: -
6. Date of inspection: 21.03.2014
7. Name of Inspecting Officer: A.D.O Sandeep Duggal
8. Name and designation of officers:
From the building side: Sh. Om Parkash Gautam (Manager)
9. Year of Construction: 2002-2003
10. Applicant's letter No.: Nil dated 09.02.2014

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | Dir. Of Edu. Circular dt. 01.03.2011 | Provided at site | Remarks MR/NMR |
|--------|---|---|---|---|
| 1. | Access to building | | | |
| | <ul style="list-style-type: none"> • Road width • Gate width • Width of internal road | <ul style="list-style-type: none"> Accessible - - | <ul style="list-style-type: none"> 07mtr 480cms, 115cms - | <ul style="list-style-type: none"> MR MR - |
| 2. | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | <ul style="list-style-type: none"> • Upper Floors • Basements | <ul style="list-style-type: none"> Two - | <ul style="list-style-type: none"> Two - | <ul style="list-style-type: none"> MR No Basement |
| | b. Width of staircases | | | |
| | <ul style="list-style-type: none"> • Upper Floor • Basements | <ul style="list-style-type: none"> 150cms Each - | <ul style="list-style-type: none"> 160cms Each - | <ul style="list-style-type: none"> MR No Basement |
| | c. Protection of exits | | | |
| | <ul style="list-style-type: none"> • Fire check door • pressurization | <ul style="list-style-type: none"> - - | <ul style="list-style-type: none"> - - | <ul style="list-style-type: none"> - - |
| | d. No. of continuous staircases to terrace | | | |
| | | - | One | - |
| | e. Width of Corridor | - | 190cms | - |
| | f. Door Size | 100cms | 100cms | MR (Being Old case) |
| 3. | Compartmentation | | | |
| | <ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers | <ul style="list-style-type: none"> - - - - - | <ul style="list-style-type: none"> - - - - - | <ul style="list-style-type: none"> - - - - - |
| 4. | Smoke Management System | | | |
| | <ul style="list-style-type: none"> • Basements • Upper floors | <ul style="list-style-type: none"> 30 a/c per hour - | <ul style="list-style-type: none"> - Natural Ventilation | <ul style="list-style-type: none"> No Basement MR |

N/S

| | | | | |
|-----|--|----------------------|------------|-------------|
| | | 12 a/c per hour | | |
| 5. | Fire Extinguishers | | | |
| | • Total numbers | 08 Nos | Provided | MR |
| | • Types | ABC, CO ₂ | - do - | MR |
| | • IS marking | ISI marked | ISI marked | MR |
| 6. | First-Aid Hose Reels | | | |
| | • Total numbers on each floor | — | — | — |
| | • Length of hose reel hose | 30 m | — | — |
| | • Nozzle diameter | 5 mm | — | — |
| 7. | Automatic fire detection and alarming system | | | |
| | • Type of detectors | — | — | — |
| | • Location of Main Panel | — | — | — |
| | • Location of Repeater Panel | — | — | — |
| | • Alternate source of power | — | — | — |
| | • Hooters' Location | — | — | — |
| 8. | MOEFA | | — | — |
| 9. | Public Address System | | — | — |
| 10. | Automatic Sprinkler System | | Provided | — |
| | • Basement | — | — | NO Basement |
| | • Upper Floor | — | — | — |
| | • Sprinkler above false ceiling | — | — | — |
| 11. | Internal Hydrants | | | |
| | • Size of riser/down-comer | — | — | — |
| | • Number of hydrants per floor | — | — | — |
| | • Hose Box | — | — | — |
| 12. | Yard Hydrants | | | |
| | • Total number of hydrants | — | — | — |
| | • Hose Box | — | — | — |
| 13. | Pumping Arrangements | | | |
| | • Ground Level | | | |
| | ➤ Discharge of main Pump | — | — | — |
| | ➤ Head of Main pump | — | — | — |
| | ➤ Number of main pumps | — | — | — |
| | ➤ Jockey Pump out put | — | — | — |
| | ➤ Jockey pump head | — | — | — |
| | ➤ Standby Pump out put | — | — | — |
| | ➤ Standby Pump Head | — | — | — |
| | ➤ Auto Starting/Manual stopping | — | — | — |

San

N/6 Green Valley International Public School,
 205, Deepak Vihar (Near Udaseen Ashram),
 Najafgarh, New Delhi - 110043.

| | | | | |
|------------|---|----------|----------|---------|
| | <ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump | — | — | — |
| 14. | Captive Water Storage for fire fighting | | | |
| | <ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity | — | — | — |
| 15. | Exit Signage. | Required | Provided | MR |
| 16. | Provision of Lifts: | | | |
| | <ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage | — | — | No Lift |
| | | — | — | - do - |
| | | — | — | - do - |
| | | — | — | - do - |
| | | — | — | - do - |
| 17. | Standby power supply | — | Provided | — |
| 18. | Refuge Area. | | | |
| | <ul style="list-style-type: none"> ➤ Total Area ➤ Location | — | — | — |
| | | — | — | — |
| 19. | Fire Control Room | | | |
| | <ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans | — | — | — |
| | | — | — | — |
| | | — | — | — |
| | | — | — | — |
| | | — | — | — |
| 20. | Special Fire Protection System for Protection of special Risks, if any: | — | — | — |

Cons

N/7

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F:G/DFS/MS/2010/2654 dated 10.09.2010 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Note :- School building is comprised of ground floor plus one upper floor approachable by ~~two~~ staircases having width 160cms each. There are classrooms with single double doors, but classrooms with single door (imts) have students less than 45 each. The undertaking given by the manager placed on C-10. FSC is recommended for renewal please

~~Sandeep~~
25/3/14

Signature of Inspecting Officer

Name Sandeep Duggal

Designation Asstt. Divisional Officer

~~Signature of Inspecting Officer~~


~~Name~~

~~Designation~~

Do (SW)

F.S.C. for G+1 floor school bldg. is put up for approval please.

Do (FO(S2)) 


25/3/14