

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI-110001.

NO.F6/DFS/MS/School/2014/SZ/ 472

DATED: 11/04/14

FIRE SAFETY CERTIFICATE

Certified that the Gaur Public School A/20 Rajapuri, Uttamnagar, New Delhi-110059, comprised of ground plus one upper floor owned/occupied by the Gaur Public School have complied with the fire prevention and fire safety requirements in accordance with letter No.F16/Estate/CC/FireSafety/2011/3298 Dated 1.3.2011 issued by Direction Education GNCT of Delhi and verified by the officers concerned of fire service on 3.4.2014. in presence of Smt. Renu Sharma (Principal) and that the building is fit for occupancy class B "Educational building" with effect from.....11/4/14... for a period of **three** years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi fire service Rules, 2010 as mentioned below.

Issued on11/4/14..... at New Delhi by


(Dr. GC Misra)
Chief Fire Officer
Ph.011-23414333

Copy to,

1. The principal, Gaur Public School A/20 Rajapuri, Uttamnagar, New Delhi-59.
2. The Director (Edu.), SDMC, 23rd floor, Civic Centre, Minto Road, New Delhi.

Conditions for the validity of fire safety certificate

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules-2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1	Name & address of the building	Gaur Public School A-20, Rajapuri, Uttam Nagar New Delhi-110059		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	New		
4	Details of previous NOC	Nil		
5	Fire safety directives letter No	Edu. Circular. No. F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011.		
6	Date of inspection	3.4.2014		
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Renu Sharma (Principal)		
9	Year of construction	2005		
10	Applicant's letter No.	03 GPS/2014 Dated 24.3.2014	(Ground plus one upper floor)	

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	Accesible For F E	6 Mtrs.	MR
	2) Gate width	N/A	2 Mtr	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	One	One Provided	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.5 Mtr	1.5	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	One	One	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1 Mtr.	1 Mtr.	MR
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	30 a/c per hour 12 a/c per hour	N/A	N/A
	upper floors		Natural Vent.	MR

6	First-Aid Hose Reels.		
	total numbers on each floor	N/A	N/A
	Length of Hose reel hose	N/A	N/A
	Nozzle Diameter	N/A	N/A
7	Automatic fire detection and alarming system		
	Type of detectors	N/A	N/A
	location of Main Panel	N/A	N/A
	location of Repeater panel	N/A	N/A
	Alternate source of power	N/A	N/A
	hooter's location	N/A	N/A
8	MOEFA	N/A	N/A
9	Public Address System.	N/A	N/A
10	Automatic Sprinkler System.		
	basement	N/A	N/A
	upper floors	N/A	N/A
	sprinkler above false ceiling	N/A	N/A
11	Internal Hydrants		
	Size of riser/down-corner	N/A	N/A
	Number of Hydrants per floor	N/A	N/A
	hose Box	N/A	N/A
12	Yard Hydrants.		
	total number of hydrants	N/A	N/A
	hose box	N/A	N/A
13	Pumping arrangements		
	1. Ground level		
	a. Discharge of main Pump	N/A	N/A
	b. Head of main pump	N/A	N/A
	c. Number of main pumps	N/A	N/A
	d. jockey pump out put	N/A	N/A
	e. jockey pump head	N/A	N/A
	f. Standby Pump output	N/A	N/A
	g. Stanby Pump head	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A
	pump house access	N/A	N/A
	2. Terrace level		
	a. Discharge of pump	N/A	N/A
	b. head of the pump	N/A	N/A
	c. Power supply	N/A	N/A
	d. Auto starting of pump	N/A	N/A
14	Captive water storage for fire fighting		
	1. Underground tank capacity	N/A	N/A
	a. Draw-off connection	N/A	N/A
	b. fire service inlet	N/A	N/A
	c. Access to tank	N/A	N/A
	Over head tank Capacity	N/A	N/A
15	Exit Signage.	N/A	N/A
16	Provision of lifts.		
	a. Pressurization of lift shaft	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A
	c. communication in lift car	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A
	e. Lift signage	N/A	N/A

New

Jan-2


Page

2/4

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any:	N/A		

The fire protection system provided in the building was checked and found functional at the time of inspection.
 Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010/
 The shortcomings vide letter No.F6/ DFS/MS/2014/SZ/172 Dated.28.1.2014 found rectified.

According DFA is put up for approval & signature Please.

Signature of the Inspecting Officer 
 Name S.P. Bhardwaj
 Designation ADO (Dwarka)

DO/SW.

F.S.C. for G+1 floor school building is put up for approval please.


 2/4/14