

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F6/DFS/MS/school/2014/w2/427

Dated: 03/04/2014

FIRE SAFETY CERTIFICATE

Certified that M C Primary School, K-II, Mangolpuri, New Delhi-110083 comprised of Two block- old Block, Ground floor, New Block Ground Floor + First Floor Only owned/occupied by M C Primary School have complied with the fire prevention and fire safety requirements in accordance with the Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 15/03/2014 in the presence of Mrs. Gulshan Kumari (Principal) and that the building / premises is fit for occupancy of Educational building with effect from 03 / 04 /2014 for a period of three years, subject to compliance of the conditions mentioned below:.

Conditions for the validity of Fire Safety Certificate:


- 1 All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
- 2 Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 This certificate cannot be treated in any case for regularizations of unauthorized construction.
- 6 The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 03/04/14 at New Delhi


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in

Copy to:

1. The Principal, M C Primary School, K-II, Mangolpuri, New Delhi-110083
2. The Addl. Director of Education, North MCD, Civic Centre New Delhi.



Total Two Blocks. old Block - G.F. New Block - G.F + one upper Floor

INSPECTION REPORT

1. Name & address of the building: M.C. Primary School, K Block Mangal Puri, Delhi-83. Educational
2. Type of Occupancy: Educational
3. Type of Case: New Case / Renewal
4. Details of previous NOC: -
5. Fire Safety directives letter No: Circular of The Director of Edn.
6. Date of inspection: 15-3-14
7. Name of the Inspecting Officers: N.P. Sharma
8. Name and designation of officers from the building side: Miss Gulshan Kumari Principal.
9. Year of Construction: old Block - 1984. New Block 2006.
10. Applicant's letter No: - 06-2-14

PA - 6117 m². CA - 1215 m². NIS - 354. NOLCR - 18

	Minimum Standards on fire prevention and fire safety U/R 33	in NBC of Requirement The Clin. of Edn	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	-	-	-
	• Width of internal road	-	-	-
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	R	P	MR
	• Upper Floors	one	one	MR
	• Basements	-	-	-
	b. Width of staircases	R	P	MR
	• Upper Floors	1.5 mtr	1.85 mtr	MR
	• Basements	-	-	-
	c. Protection of exits	-	-	-
	• Fire check door	+	-	-
	• Pressurization	-	-	-
	e. No. of continuous staircases to terrace	-	-	-
	g. Width of Corridor	-	-	-
	h. Door Size	1. mtr	1.5 mtr	M/R
3	Compartmentation.	-	-	-
	• Fire check door	-	-	-

N/6

	<ul style="list-style-type: none"> Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	—	—	—
4	Smoke Management System.	NIA		
	<ul style="list-style-type: none"> Basements Upper floors 	30 a/c per hour	—	—
		12 a/c per hour	—	—
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types ISI marking 	05 ISI marked	05 ABC yes	MR MR MR
6	First-Aid Hose Reels.	NIA		
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	30 m 5 mm	—	—
7	Automatic fire detection and alarming system.	NIA		
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	—	—	—
8	MOEFA	—	—	—
9	Public Address System.	—	—	—
10	Automatic Sprinkler System.	NIA		
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	—	—	—
11	Internal Hydrants	NIA		
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	—	—	—
12	Yard Hydrants.	NIA		
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	—	—	—

N17

13	Pumping Arrangements.	NIA		
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pum 			
14	Captive Water Storage for fire fighting.	NIA		
	<ul style="list-style-type: none"> • Underground tank capacity <ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 			
15	Exit Signage.			
16	Provision of Lifts.	NIA		
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 			
17	Standby power supply			
18	Refuge Area.	NIA		
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 			
19	Fire Control Room	NIA		
	<ul style="list-style-type: none"> • Detector System Panel 			

N/S

	• Flow Switch Panel	—	—	—
	• PA System Panel	—	—	—
	• Batter backup	—	—	—
	• Building Floor Plans	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer N.P. Sharma 15-3-14

Name N.P. Sharma

Designation ADO (R)

Signature of the Inspecting Officer

Name

Designation