

No.F6/DFS/MS/2014/ EH/52/449

Dated : 04/04/14

**FIRE SAFETY CERTIFICATE**

Certified that "Fresco & Baker Street" Restaurant located at Unit No. 1 & 2 ,Security Hold Area 1D-IGI Airport Terminal,New Delhi. comprised of Ground + 1 Upper Floor but the restaurant is running on 1<sup>st</sup> floor security hold area only was granted NOC by this department vide letter No.F6/DFS/MS/EH/2009/2446 dated 07/08/09.The premises was re-inspected by the officer concerned of this department on 28/03/14 in the presence of Mr. G.S. Rana and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Group - D Eating House Assembly Building** with effect from 04/04/14 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010 subject to conditions printed below.

Issued 04/04/14 at New Delhi by.

  
(Dr. G.C. Misra)  
Chief Fire Officer  
Delhi Fire Service

Copy to:- (1) The D.E.O. ( Restt.),G.N.C.T. of Delhi,  
Office of the Commissioner of Excise, Entt.& L. Tax  
Department, L & N Block, I.P. Estate, Vikas Bhawan, New Delhi.

(2) "Fresco & Baker Street" Restaurant,  
Unit No. 1 & 2 ,Security Hold Area 1D-IGI Airport Terminal, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

-11/18-

**INSPECTION REPORT**

1. Name & address of the building:- "Fresco & Baker Street" Restaurant, Unit No. 1 & 2, Security Hold Area 1D-IGI Airport Terminal, New Delhi.
2. Type of occupancy:- Group -D Eating House Assembly Building.
3. Type of case:- Renewal
4. Details of previous NOC:- No.F6/DFS/MS/EH/2009/2446 dated 07/08/09
5. Fire safety directives No.- NOC to 1D Terminal issued vide letter No.F6/DFS/MS/2012/3941 dated 23/10/12.
6. Date of inspection:- 28/03/14
7. Name of the inspecting officer:- A.D.O. S.S. Kaushik
8. Name & designation of officer  
From the building side:- Mr. G.S. Rana
9. Year of construction:- 2008
10. Applicant's letter No:- Nil. dated 03/03/14. Building comprised of ground + 1 upper floor but the restaurant is running on 1<sup>st</sup> floor in security hold area only.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Access to Building</b>			
	1) Road width	4.5 Mtrs.	Provided.	MR
	2) Gate width	2 mtr.	Provided.	MR
	3) Width of internal road	N/A.	N/A.	N/A
<b>2.</b>	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	<b>A. Number of staircases</b>			
	1. Upper floors	2 Nos. near restaurant	2 Nos. near restaurant	MR
	2. Basements	N/A.	N/A.	N/A
	<b>B. Width of staircase</b>			
	1. Upper floors	1.50 mtr.	1.50 mtr. each	N/A
	2. Basements	N/A.	N/A	N/A
	<b>C. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	N/A	N/A.	N/A
	F. Door size	Two exits	Provided.	MR
<b>3.</b>	<b>Compartmentation</b>			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
<b>4.</b>	<b>Smoke Management System</b>			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	Exhaust Fan	Provided	MR
<b>5.</b>	<b>Fire Extinguishers</b>			

*(Handwritten signature)*



	1) Total numbers	ISI Marked	06 Nos.	MR
	2) Types		Co2, W.Co2 ABC,	MR
	3) ISI marking		Yes	MR
6.	<b>First-Aid Hose Reel :-</b>	<b>Provided &amp; Maintained by Terminal 1D IGI Airport</b>		
	1) Total number of each floor	Required	2 Nos. provided near restaurant	MR
	2) Length of hose reel hose	30 m	Yes	MR
	3) Nozzle diameter	5 mm	Yes	MR
7.	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors	-----do-----	-----do-----	-----do-----
	2) Location of main panel	-----do-----	-----do-----	-----do-----
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	-----do-----	-----do-----	-----do-----
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	<b>Automatic Sprinkler System</b>	<b>Provided &amp; Maintained by Terminal 1D IGI Airport</b>		
	1) Basement	-----do-----	-----do-----	-----do-----
	2) Upper floors	-----do-----	-----do-----	-----do-----
	3) Sprinkler above false ceiling	-----do-----	-----do-----	-----do-----
11.	<b>Internal Hydrants</b>	<b>Provided &amp; Maintained by Terminal 1D IGI Airport</b>		
	1) Size of riser/down-comer	-----do-----	-----do-----	-----do-----
	2) Number of hydrants per floor	-----do-----	-----do-----	-----do-----
	3) Hose box	-----do-----	-----do-----	-----do-----
12.	<b>Yard Hydrants</b>	<b>Provided &amp; Maintained by Terminal 1D IGI Airport</b>		
	1) Total number of hydrants	-----do-----	-----do-----	-----do-----
	2) Hose box	-----do-----	-----do-----	-----do-----
13.	<b>Pumping Arrangement</b>	<b>Provided &amp; Maintained by Terminal 1D IGI Airport</b>		
	1) Ground level			
	a) Discharge of main pump	-----do-----	-----do-----	-----do-----
	b) Head of main pump	-----do-----	-----do-----	-----do-----
	c) Number of main pump	-----do-----	-----do-----	-----do-----
	d) Jockey pump out put	-----do-----	-----do-----	-----do-----
	e) Jockey pump head	-----do-----	-----do-----	-----do-----
	f) Stand by pump output	-----do-----	-----do-----	-----do-----
	g) Stand by pump head	-----do-----	-----do-----	-----do-----
	h) Auto starting/Manual stopping	-----do-----	-----do-----	-----do-----
	2) Terrace level			
	a) Discharge of pump	-----do-----	-----do-----	-----do-----
	b) Head of pump	-----do-----	-----do-----	-----do-----
	c) Power supply	-----do-----	-----do-----	-----do-----
	d) Auto starting of pump	-----do-----	-----do-----	-----do-----

*Mansy*



Captive Water Storage for Fire Fighting Provided & Maintained by Terminal 1D IGI Airport				
14.	1) Under ground tank capacity	-----do-----	-----do-----	-----do-----
	a) Draw-off connection	-----do-----	-----do-----	-----do-----
	b) Fire service inlet	-----do-----	-----do-----	-----do-----
	c) Access to tank	-----do-----	-----do-----	-----do-----
	d) Over head tank capacity	-----do-----	-----do-----	-----do-----
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area			
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	Provided & Maintained by Terminal 1D IGI Airport		
	a) Detector system panel	-----do-----	-----do-----	-----do-----
	b) Flow switch panel	-----do-----	-----do-----	-----do-----
	c) PA system panel	-----do-----	-----do-----	-----do-----
	d) Battery backup	-----do-----	-----do-----	-----do-----
	e) Building floor plan	-----do-----	-----do-----	-----do-----
20.	Special Fire Protection System for Protection of special Risk, if any:			MR

The fire protection system provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No.F6/DFS/MS/EH/2009/2446 dated 07/08/09 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Accordingly DFA is put up please

Signature of the inspecting officer

Signature of the inspecting officer

Name :-

Designation:-

Name:- S.S.Kaushik.

Designation:- Assistant Divisional Officer.