

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

Fax:- 011-23412593

E-mail ID:cfohq:dlfire@nic.in

No. F6/DFS/MS/2014/MD2/490

Dated 17/04/14

FIRE SAFETY CERTIFICATE

Certified that the Kamani Auditorium located at, Copernicus Marg, **New Delhi** comprises of basement floor, (LGF) Ground floor, Mezzanine floor +2 upper floors was granted NOC by this department vide letter No. F6/MS/DFS/2011/Auditorium/300 dated 15-02-2011. The premises was re-inspected by the officers concerned of this department on 05-03-2014 in the presence of Mr. S.P. Misra (Manager) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and the building is fit for occupancy Class B "**Assembly Building**" with effect from 17/04/2014 for period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 17/04/14..... at New Delhi by.


(DR. G.C. MISRA)
Chief Fire Officer
Delhi Fire Service
Ph – 011-23414333

Copy to:-

1. Kamani Auditorium located at, Copernicus Marg, **New Delhi**
2. The Joint. Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi – 110049 w.r.t. letter No. 6949-54/joint. C.P./Lic(H) dated New Delhi the 07-02-2014.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

INSPECTION REPORT

1. Name & address of the building : Kamani Auditorium at, Copernicus Marg, New Delhi.
2. Type of Occupancy : Assembly Building (B + (LGF) + Gr. + Mezz. floor & 2 floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/MS/DFS/2011/Auditorium/300 dated 15/02/2011
5. Fire Safety directives Letter No. : NA
6. Date of inspection : 05/03/2014
- 7 Name of the Inspecting Officer : Sh. Gurmukh Singh (DO/CD) & Sh. M. K. Sharma (ADO/CC)
- 8 Name and designation of Officer
from the building side : Mr. S. P. Misra (Manager)
- 9 Year of Construction : old building
10. Applicant's letter No. : No. 6949-54/Joint C.P./Lic.(Amst.) dated Delhi the 07/02/14.

S No	Minimum standards on fire prevention and fire safety U/R 33	Existing Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9 Mtr.	12 Mtr.	MR
	• Gate width	4.5 Mtr.	4.5 Mtr.	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits & Spiral Staircase			
	a. Number of staircases			
	• Upper floors	2 Nos.	2 Nos.	MR
	• Basements	2 Nos.	2 Nos.	MR
	b. Width of staircases			
	• Upper floors (one ramp)	1.0 & 1.9 Mtr.	1.0 & 1.9 Mtr.	MR
	• Basements	1 Mtr. each	1 Mtr. each	MR
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA

h

P
mar

	d. No of continuous staircase to terrace	2 Nos.	2 Nos.	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	NA	NA	NA
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke managements System			
	• Basements	30 ACPH	Machincal	MR
	• Upper floors	12 ACPH	NATURAL	MR
5	Fire Extinguishers			
	• Total numbers	30 Nos.	32 Nos.	MR
	• Types	ABC, CO ₂ , Wco ₂	ABC, CO ₂ , Wco ₂	MR
	• IS marking	Required	Provided	MR
6	First – Aid Hose Reels			
	• Total numbers on each floor	04	04	MR
	• Length of hose reel hose	30 Mtr.	30 Mtr.	MR
	• Nozzle diameter	05 MM	05 MM	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	Required	Provided	MR
	• Location of Main Panel	At G. floor	At G. floor	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler			
	• Basements	Required	Provided	MR

h

man

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 	Required NA	Provided NA	MR NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down- comer • Number of hydrants per floor • Hose Box 	100 MM 2 No 2 No	100 MM 2 No 2 No	MR MR MR
12	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	03 03	03 03	MR MR
13	Pumping Arrangements			
	<ul style="list-style-type: none"> ○ Ground Level • Discharge of main pump • Head of main pump • Number of main pumps • Jockey pump out put • Jockey pump head • Standby Pump out put • Standby Pump Head • auto Staring/Manual stopping • Pump House Access ○ Terrace level • Discharge of pump • Head of the pump • Power supply • Auto starting of pump 	2280 LPM 70 Mtr. 1 180 LPM 70 Mtr. 2280 LPM 70 Mtr. NA NA NA NA NA NA NA NA	2280 LPM 70 Mtr. 1 180 LPM 70 Mtr. 2280 LPM 70 Mtr. NA NA NA NA NA NA NA NA	MR MR MR MR MR MR MR NA NA NA NA NA NA NA NA
14	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> • Under ground tank capacity • Draw of connection • Fire service inlet • Access to tank • Overhead Tank capacity 	1,00,000 Ltr. Required Required Required 20,000 Ltr.	1,65,000 Ltr. Provided Provided Provided 20,000 Ltr.	MR MR MR MR MR

h

new

15	Exit Signage	Required	Provided	MR
16	Provision of Lifts			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of lift lobby	NA	NA	NA
	• Communication in lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area			
	• Total area	NA	NA	NA
	• Location	NA	NA	NA
19	Fire control room			
	• Detector system panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	Required	Co2 & DCP	MR

The fire protection systems provided in the building were tested, checked randomly and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/MS/DFS/2011/Auditorium/300 dated 15/02/2011 renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer

Gurmukh Singh
3/13/14
Name :- Sh. Gurmukh Singh
Designation :-DO(CD)

Signature of the Inspecting Officer

M. K. Sharma
3/13/14
Name :- Sh. M. K. Sharma
Designation :- A. D.O. (CC)