

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/2014/W2/478

Dated: 16/04/2014

FIRE SAFETY CERTIFICATE

Certified that the S.S. Cosmetics, F-125, Sector-II-E, DSIDC, Bawana Indl Area, Delhi-110039, comprised of Basement + Ground + two upper floor owned / occupied by M/s S.S. Cosmetics have complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by the officers concerned of this department on 01/04/2014 in the presence of Sh. Himansu Khatter (Manager) and that the building / premises is fit for occupancy Class-G (G-1) Industrial with effect from 16/04/2014 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.


Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 16/04/14 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in

Copy to:

1. M/S S.S. Cosmetics, F-125, Sector-II-E, DSIDC, Bawana Indl Area, Delhi-110039 
2. The Assistant Drugs Controller & Licensing Authority, GNCT, F-17, Karkardooma, New Delhi-110032

N-1

Bldg. - B + G + one + two floors
 Factory running Gr. floors only.

INSPECTION REPORT

1. Name & address of the building: SS Cosmetics F-125 Sec 2 E
2. Type of Occupancy: Industrial - G DSIDC Bawana Delhi 39
3. Type of Case: New Case / Renewal (DSE for Gr floors only)
Affidavit Submitted
4. Details of previous NOC: NIL
5. Fire Safety directives letter No: NBC - Part IV
6. Date of inspection: 1-4-14
7. Name of the Inspecting Officers: ADD (RW)
8. Name and designation of officers from the building side: Sh. Himanshu Khattar Manager
9. Year of Construction: 2009
10. Applicant's letter No.: dt. No. Nil dt. 6-3-14

PA - 100 m² CA - 280 m²

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	—	—	—
	• Width of internal road	—	—	—
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	—	—	—
	• Upper Floors	—	—	—
	• Basements	—	—	—
	b. Width of staircases	—	—	—
	• Upper Floors	N.R	1.25 m ^{tr}	MR/R
	• Basements	N.R	1.30 m ^{tr}	MR
	c. Protection of exits	—	—	—
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	—	—	—
	g. Width of Corridor	—	—	—
	h. Door Size	1 m ^{tr}	1.10 & 1.80 m ^{tr}	MR
3	Compartmentation.	—	—	—
	• Fire check door	—	—	—

N-2

	<ul style="list-style-type: none"> Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 			
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements Upper floors 	30 a/c per hour 12 a/c per hour		
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types ISI marking 	3 ABC 3 water ISI marked CO ₂	3 ABC 3 water ABC CO ₂	MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	one 30 m 5 mm	one P P	MR MR MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Smoke NR	P	MR
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	R R	P P	MR MR
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 			
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 			

13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N/A	N/A	N/A
		900 CPM	900 CPM	MR
		40M	40M	MR
		—	—	—
		—	—	—
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity <ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	N/A	N/A	N/A
		10,000 lbs	10,000 lbs	MR
15	Exit Signage.			
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
17	Standby power supply			
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 			
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel 	N/A	N/A	N/A

NIL

	<ul style="list-style-type: none">• Flow Switch Panel• PA System Panel• Batter backup• Building Floor Plans			
20	Special Fire Protection Systems for Protection of special Risks, if any:			

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....NIL.....



Signature of the Inspecting Officer

Name

Designation

[Handwritten Signature]

Signature of the Inspecting Officer

Name

Designation

[Handwritten Signature]
2/4/14
ADDG (B/W)