

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F6/DFS/MS/School/2014/W2/456

Dated: 08/04/2014

FIRE SAFETY CERTIFICATE

Certified that **R L M Public School, Tatesar - Jounti, Delhi-110081** comprised of **Ground Floor Only** owned / occupied by **R L M Public School** has already been issued fire safety certificate vide this office letter No **F-6/DFS/MS/2008/1742 dated 25/06/2008** have complied with the fire prevention and fire safety requirements in accordance Circular No **F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011** issued by Director of Education and verified by the officer concerned of Fire Service on **20/03/2014** in the presence of **Smt. Manju (Teacher-in-Charge)** and that the building / premises is fit for occupancy of **Group Class B (Educational building)** with effect from **08/04/2014** for a period of **three years**, subject to compliance of the following conditions.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on 08/04/14 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in

Copy to:

1. The Principal, R L M Public School, Tatesar - Jounti, Delhi-110081
2. The Director of Education, Old Secretariat, Delhi



INSPECTION REPORT

1. Name & address of the building: RLM Public School Tatalar Jaunpur-281081
2. Type of Occupancy : Edu.
3. Type of Case : New Case / Renewal
4. Details of previous NOC : Pl No. F-6/P.F.S./M.S/2008/1742 dt 25-6-08
5. Fire Safety directives letter No : Dir. of Edu.
6. Date of inspection : 20-3-19
7. Name of the Inspecting Officers : ASO (BWS)
8. Name and designation of officers from the building side : Smt Manjiv Teacher-in-charge
9. Year of Construction : 2006
10. Applicant's letter No. : Pl No. N12 dt. 21-2-19

Plot area: 418 m² Covered area: 242 m² No.'s of students: 120 No's of classrooms: 6
one office

	Minimum Standards on fire prevention and fire safety U/R 33	Circular Dir. of Edu Requirement <u>NBC</u>	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	<u>Accessible</u>	<u>Accessible</u>	<u>MIR</u>
	• Gate width	<u>—</u>	<u>—</u>	<u>—</u>
	• Width of internal road	<u>—</u>	<u>—</u>	<u>—</u>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors			
	• Basements			
	b. Width of staircases			
	• Upper Floors			
	• Basements			
	c. Protection of exits			
	• Fire check door			
	• Pressurization			
	e. No. of continuous staircases to terrace			
	g. Width of Corridor			
	h. Door Size	<u>old case</u>	<u>old case</u>	<u>old case</u>

N-4

M

	<ul style="list-style-type: none"> Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 				
4	Smoke Management System.				
	<ul style="list-style-type: none"> Basements Upper floors 	30 a/c per hour 12 a/c per hour			
5	Fire Extinguishers				
	<ul style="list-style-type: none"> Total numbers Types IS marking 	3 ABC ISI marked	4 ABC Yes	MIR MIR MIR	
6	First-Aid Hose Reels.				
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	30 m 5 mm			
7	Automatic fire detection and alarming system.				
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 				
8	MOEFA				
9	Public Address System.				
10	Automatic Sprinkler System.				
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 				
11	Internal Hydrants				
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 				
12	Yard Hydrants.				
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 				

12 **Yard Hydrants.**

- Total number of hydrants
- Hose Box

N/A

13 **Pumping Arrangements.**

- Ground Level
 - Discharge of main Pump
 - Head of Main pump
 - Number of main pumps
 - Jockey Pump out put
 - Jockey pump head
 - Standby Pump out put
 - Standby Pump Head
 - Auto Starting/ Manual stopping
 - Pump House Access
- Terrace level
 - Discharge of pump
 - Head of the pump
 - Power Supply
 - Auto Starting of pum

N/A

14 **Captive Water Storage for fire fighting.**

- Underground tank capacity
 - Draw-off connection
 - Fire service inlet
 - Access to tank
- Overhead Tank capacity

N/A

15 **Exit Signage.**

16 **Provision of Lifts.**

- Pressurization of Lift Shaft
- Pressurization of Lift lobby
- Communication In lift Car
- Fireman's Grounding Switch
- Lift Signage

N/A

17 **Standby power supply**

M-6

18	Refuge Area.			
	➤ Total Area			
	➤ Location			
19	Fire Control Room			
	• Detector System Panel			
	• Flow Switch Panel			
	• PA System Panel			
	• Batter backup			
	• Building Floor Plans			
20	Special Fire Protection Systems for Protection of special Risks, if any:			

N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no F-6/D.F.S./MS/2008/1742 Dated 25/06/08 Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name

Designation

De. (S/O)

24/3/14

Signature of the Inspecting Officer

Name

Designation

A. Sharma
21/3/14

A.D.O (B.W)



1411