

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/School/2014/W2/515

Dated: 24/04/2014

FIRE SAFETY CERTIFICATE

Certified that Naveen Public School, Village Nithari, Delhi-110086 comprised of Ground + Two upper floor owned/occupied by Naveen Public School, has already been issued fire safety certificate vide letter no. F6/DFS/MS/2011/569 Dated: 01/04/2011. The premises was re-inspected by the officer from this department on dated 09/04/2014 in the presence of Nafe Singh (Chairman) and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with the requirements of Circular issued by Director of Education letter dated 17/01/2005 issued by Director of Education / NBC- Part IV and verified by the officer concerned of Fire Service and the building / premise is fit for occupancy of Group Class B (Educational) with effect from 24 / 04 /2014 for a period of three years, subject to compliance of the conditions mentioned below:


Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 24/04/14 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250

Copy to:

1. The Principal, Naveen Public School, Village Nithari, Delhi-110086
 2. The Director of Education, Old Secretariat, Delhi
- 

INSPECTION REPORT

(G + 2 upper floor)

1. Name & address of the building : Naveen Public School, Village Nithari, Delhi-110086.
2. Type of Occupancy : Educational
3. Type of Case : Renewal,
4. Details of previous NOC : Letter No. F6/DFS/MS/2011/569 Dated: 01/04/2011
5. Fire Safety directives letter No : Circular, Dir. of Edmn.
6. Date of inspection : 09/04/2014
7. Name of the Inspecting Officers : DO NW
8. Name and designation of officers
from the building side : Nafe Singh (Chairman)
9. Year of Construction : 1996
10. Applicant's letter No. : L. no- Nil, Dated 21/03/2014

Plot area- 3000 Sq.yds. Covered area-2400 yds No's of student- 660 No's of class room- 45

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Circular, Dir. of Edmn.	Provided at site	Remarks MR/NMR
1	Access to building	Old case		
	• Road width	Accessible	Accessible	M.R
	• Gate width	Accessible	Accessible	M.R
	• Width of internal road	--	--	--
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	04	04	M/R
	• Basements	--	--	--
	b. Width of staircases			
	• Upper Floors	1.5mtr	(i)150cm (ii)150cm (iii)3.9 feet (iv)80cm	M/R
	• Basements	--	--	--
	c. Protection of exits			
	• Fire check door	--	--	--
	• Pressurization	--	--	--
	d. No. of continuous staircases to terrace	02	02	M.R
	e. Width of Corridor	--	--	--
	f. Door Size	1 mtr	1mtr	M.R


3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	NA	NA
		12 a/c per hour	NA	NA
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	15	09 ABC, 06 Water Co ₂	M.R
		ISI marked	--	M.R
			yes	M.R
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	01	P	M.R
		30 m 5 mm	P	M.R
			yes	M.R
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA

12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 LPM	P	M.R
	➤ Head of the pump	40 m	P	M.R
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10000 ltr	10000 ltr	M.R
15	Exit Signage.	R	P	M.R
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA

17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/2011/569 dated 01/04/2011 Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.



Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Name

Designation

Designation

[Handwritten signature]
17/4/14