

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI -110001


No. F6/DFS/MS/EH/2014/MDZ/504

Dated 23/04/14

FIRE SAFETY CERTIFICATE

Certified that the M/s United Coffee House, 15-E, Connaught Place, New Delhi at ground & mezzanine floor, of building which comprises of Ground +2 Upper floors, was granted NOC by this department vide letter No.F6/MS/DFS/2011/EH/1313 dated 24-06-2011. The premises was re-inspected by the officer concerned of this department on 16-04-2014 in the presence of Mr. Rakesh Sr. Manager and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of restaurant with effect from 23/04/2014 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued ... 23/04/14 .....at New Delhi by.

  
(DR. G.C. MISRA)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE  
Ph:- 011-23414333

Copy to :-

1. Mr. Akash Kalra (Partner)  
M/s United Coffee House,  
15-E, Connaught Place, New Delhi
2. The DEO (Restt.)  
Deptt. of Excise, Entertainment and Luxury,  
Govt. of NCT of Delhi.  
L & N Block, Vikas Bhawan, I.P.Estate, New Delhi.

United Coffee House  
-15, Inner Circle  
Connaught Place  
New Delhi-110001

Musataque  
23-04-14



11-10

## INSPECTION REPORT

1. Name & address of the building : M/s United Coffee House, 15-E,  
Connaught Place New Delhi.
2. Building is comprised of : Ground +2 Upper floors Restaurant is  
at Ground & Mezzanine floor
3. Type of Occupancy : Restaurant
4. Type of Case : Renewal
5. Details of Previous NOC Letter: F6/MS/DFS/2011/ EH/1313 dated  
24-06-2011
6. Fire Safety directive letter No : -Nil-
7. Date of Inspection : 16.04.2014
8. Name of the Inspecting officers : Gurmukh Singh (DO)
9. Name and designation of Officer:  
from the building side : Mr. Rakesh Chander
10. Year of Construction :
11. Applicant's letter No : -Nil - dated 05.04.2014

S.NO.	Minimum Standards on fire prevention and fire safety U/R33	Existing Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	• Road width	9 Mtrs	9 Mtrs.	MR
	• Gate width	NA	Directly from road	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	2 Nos	2 Nos.	MR
	• Basement	NA	NA	NA
	B. Width of Staircases			
	• Upper Floor	1.2 Mtr & .70 Mtr	1.2 Mtr.& .70 Mtr	MR (old case)
	• Basement	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	NA	NA	NA

h



2-11

	g. Width of Corridor	NA	NA	NA
	h. Door Size	1.0 Mtr.	1.0 Mtr.	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire rating of shaft door	NA	NA	NA
	• Water curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basement	NA	NA	NA
	• Upper floor	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	4Nos.	8 Nos.	MR
	• types	Co2 &Wco2	Co2 &Wco2	MR
	• ISI marking	Required	Provided	MR
6	First-aid-Hose Reels.			
	• Total numbers at each floor	Required	Provided	MR
	• Length of hose reel hose	30 Mtr.	30 Mtr.	MR
	• Nozzle diameter	5 MM	5 MM	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of main panel	NA	NA	NA
	• Location of repeater panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooter's location	NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public address System.	NA	NA	NA
10	Automatic Sprinkler System.	Required	Provided	MR
	• Basement	NA	NA	NA
	• upper floor	Required	Provided	MR
	• sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants.		NA	NA
	• Total number of hydrants	NA	NA.	NA

h



	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level	NA	NA	NA
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main Pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby pump out put	NA	NA	NA
	➤ Standby pump Head	NA	NA	NA
	➤ Auto Starting /Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace Level	Required	Provided	MR
	➤ Discharge of pump	180 LPM & 450 LPM	180 LPM & 450 LPM	MR
	➤ Head of the Pump	30Mtrs	30Mtrs	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	5,000 Ltrs.	5,000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.	NA		
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication in lift car	NA	NA	NA
	• Firemen's grounding switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area.	NA	NA	NA
	• Total area	NA	NA	NA
	• Location	NA	NA	NA
19	Fire Control Room	NA	NA	NA
	• Detector system panel	NA	NA	NA
	• Flow switch panel	NA	NA	NA
	• PA system panel	NA	NA	NA

h



N-13

	• Battery backup	NA	NA	
	• Building Floor Plans	NA	NA	
20	Special Fire Protection systems fire protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspection.  
In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no.F6/MS/DFS/2011/EH/1313 dated 24.06.2011, renewal, under rule 35 of the Delhi Fire Service Rule 2010, is recommended.

*Gurmukh Singh*  
18/11/14  
Name - Gurmukh Singh  
Designation (DO)

