

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/2014/W2/523

Dated: 28/04/14

FIRE SAFETY CERTIFICATE

Certified that the City Square Mall located at Plot No. 7 & 8, District Centre, Shivaji Palace, Raja Garden, New Delhi - 110027 comprised of 2 Basement + Ground + 4 Upper Floors was issued FSC vide Letter No. F6/DFS/MS/2010/2188 dated 23-07-2010. The premises was re inspected by the officers concerned of this department on 11-04-2014 in the presence of Mr. Arvind Kapur (General Manager) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Mercantile" Group F with effect from 28/04/14 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 28/04/14.... at New Delhi by.


28/4
(Santokh Singh)
Chief Fire Officer,
Ph: 011 - 23414250

Copy to:

1. Sh. Arvind Kapoor (General Manager),
City Square Mall, Plot No. 7, 8,
Shivaji Palace, District Centre, Raja Garden, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. form is available on www.dfs.delhigovt.nic.in.

Re inspection to see the compliance of shortcomings communicated vide letter no. F6/DFS act 2007/MN dated 17-09-2013.

INSPECTION REPORT

1. Name & address of the building: City Square Mall, Plot No. 7, 8, Shivaji Palace, District Centre, Raja Garden, New Delhi.
2. Type of Occupaney : Mall
3. Type of Case : Renewal
4. Details of previous NOC : Letter No. F6/DFS/MS/2010/2188 dated 23-07-2010
5. Fire Safety directives Letter No. : Letter No. F6/DFS/MS/BP/2004/341 dated 12-02-2004
6. Date of inspection : 11-04-2014
7. Name of the Inspecting Officer : DO (West) & ADO (MN)
8. Name and designation of Officer
from the building side : Sh. Arvind Kapur (General Manager)
9. Year of Construction : 2006
10. Applicant's letter No. : Nil Dated 08-03-2014

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	30 m	Provided	MR
	• Gate width	6 m	Provided	MR
	• Width of internal road	6 m	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	3	Provided	MR
	• Basements	5	Provided	MR
	b. Width of staircases			
	• Upper floors	Old Case	Old Case	MR
	• Basements	Old Case	Old Case	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NR	NR	NR
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width Of Corridor	Old Case	Old Case	MR
	f. Door Size	Old Case	Old Case	MR
3.	Compartmentation			
	• Fire check door	Required	Provided (NR near lift lobby as it opens in atrium)	MR

	<ul style="list-style-type: none"> Sealing of electrical shafts 	Required	Found Provided	MR
	<ul style="list-style-type: none"> Fire Rating of shaft door 	Required	Provided	MR
	<ul style="list-style-type: none"> Water Curtain 	Required	Provided	MR
	<ul style="list-style-type: none"> Fire Dampers 	Required	Provided at the AHU	MR
4.	Smoke managements System			
	<ul style="list-style-type: none"> Basements 	30 a/c per hour	Connected with Detection & alarm system	MR
	<ul style="list-style-type: none"> Upper floors 	12 a/c per hour	Provided	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	51 nos.	Provided	MR
	<ul style="list-style-type: none"> Types 	ABC, CO2 & WCO2	Provided	MR
	<ul style="list-style-type: none"> IS marking 	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor 	Required	Provided	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m	Provided	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors 	Smoke & Heat	Provided	MR
	<ul style="list-style-type: none"> Location of Main Panel 	Required	Provided	MR
	<ul style="list-style-type: none"> Location of Repeater Panel 	Required	Provided	MR
	<ul style="list-style-type: none"> Alternate source of power 	Required	Provided	MR
	<ul style="list-style-type: none"> Hooters' Location 	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements 	Required	Provided	MR
	<ul style="list-style-type: none"> Upper Floor 	Required	Provided	MR
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	Required	Provided	MR
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down- comer 	150 mm	Provided	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	Required	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	Required	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	Required	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	Required	Provided	MR
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> Discharge of main pump 	2850 lpm	Provided	MR
	<ul style="list-style-type: none"> ➤ Head of main pump 	60 m	Provided	MR
	<ul style="list-style-type: none"> ➤ Number of main pumps 	1	Provided	MR
	<ul style="list-style-type: none"> ➤ Jockey pump out put 	180 lpm	Provided	MR

	➤ Jockey pump head	60 m	Provided	MR
	➤ Standby Pump out put	2850 lpm	Provided	MR
	➤ Standby Pump Head	60 m	Provided	MR
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	NR	NR	NR
	➤ Head of the pump	NR	NR	NR
	➤ Power supply	NR	NR	NR
	➤ Auto starting of pump	NR	NR	NR
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	1,00,000 litres	Provided	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	30, 000 litres	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NR	NR	NR
	➤ Pressurization of lift lobby	NR	NR	NR
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	Required	Provided	MR
	➤ Location	Open Terrace	Provided	MR
19.	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	Required	Provided	MR
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any:	CO2 Flooding System for HT & LT Panel	Provided	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/2010/2188 dated 23-07-2010 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

MUKESH VERMA


Name

Designation

ADD (MN)

Designation

Dy CFO (on call)



CFO/486
17/4/14
28/4/14

JRA Meena
17/4