

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/School/2014/02/514

Dated: 24/04/2014

FIRE SAFETY CERTIFICATE

Certified that the Dhruv Public School Z-134, Prem Nagar, Kirari, Nangloi, Delhi 110086 is comprised of Ground + two upper floor owned and occupied by Dhruv Public School have complied with the fire prevention and fire safety requirements in accordance with the Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 04/03/2014 in the presence of Mrs. Rekha (Principal) and that the building / premises is fit for occupancy of Educational building with effect from 24/04/2014 for a period of three years, subject to compliance of the conditions mentioned below.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 24/04/14 at New Delhi by

  
(SANTOKH SINGH)  
Chief Fire Officer  
Delhi Fire Service  
Ph: 011-23414250  
cfowz.dlfire@nic.in

**Copy to:**

1. The Principal, Dhruv Public School Z-134, Prem Nagar, Kirari, Nangloi, Delhi 110086
2. The Director of Education, Old Secretariat, Delhi

GF + FF - Second Floor

INSPECTION REPORT

1. Name & address of the building: DHRUV PUBLIC SCHOOL, 2-134, Prem
2. Type of Occupancy: Nagar, Kirti, Manglo, Delhi-86. Educational
3. Type of Case: New Case / Renewal
4. Details of previous NOC: —
5. Fire Safety directives letter No: BBL 1983/NBC-IV
6. Date of inspection: 04-3-14
7. Name of the Inspecting Officers: N.P. Sharma
8. Name and designation of officers  
from the building side: Mrs Rekha
9. Year of Construction: 2006
10. Applicant's letter No: — 20-2-14

PA - 9725 Syds. CA - 461 Syds. Nbs S - 256 Nbs CR - 12

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR ✓
	• Gate width	—	—	—
	• Width of internal road	—	—	—
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	R	P	MR ✓
	• Upper Floors	01	02 ✓	MR ✓
	• Basements	—	—	—
	b. Width of staircases	1.5 mtr	1 - 0.90 mtr 2 - 0.75 mtr ✓	MR ✓
	• Upper Floors	—	—	—
	• Basements	—	—	—
	c. Protection of exits	—	—	—
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	—	—	—
	g. Width of Corridor	—	—	—
	h. Door Size	1. mtr	P —	MR —
3	Compartmentation.			
	• Fire check door	N/A	—	—

	<ul style="list-style-type: none"> <li>Sealing of electrical shafts</li> <li>Fire Rating of shaft door</li> <li>Water Curtain</li> <li>Fire Dampers</li> </ul>	—	—	—
4	<b>Smoke Management System.</b>			
	Basements	30 a/c per hour	—	—
	Upper floors	12 a/c per hour	—	—
5	<b>Fire Extinguishers</b>			
	Total numbers	03	06	MR
	Types	ISI marked	ABC & CO <sub>2</sub>	MR
	IS marking		yes	MR
6	<b>First-Aid Hose Reels.</b>			
	Total numbers on each floor	one @ each floor	P	MR
	Length of hose reel hose	30 m	P	MR
	Nozzle diameter	5 mm	P	MR
7	<b>Automatic fire detection and alarming system.</b>			
	Type of detectors	—	—	—
	Location of Main Panel	—	—	—
	Location of Repeater Panel	—	—	—
	Alternate source of power	—	—	—
	Hooters' Location	—	—	—
8	<b>MOEFA</b>			
9	<b>Public Address System.</b>			
10	<b>Automatic Sprinkler System.</b>			
	Basement	—	—	—
	Upper Floor	—	—	—
	Sprinkler above false ceiling	—	—	—
11	<b>Internal Hydrants</b>			
	Size of riser/down-comer	—	—	—
	Number of hydrants per floor	—	—	—
	Hose Box	—	—	—
12	<b>Yard Hydrants.</b>			
	Total number of hydrants	—	—	—
	Hose Box	—	—	—

13	Pumping Arrangements.			
	<ul style="list-style-type: none"> <li>• Ground Level</li> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> </ul>	—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
	<ul style="list-style-type: none"> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pum</li> </ul>	450 lpm	P	MR
		40 m	P	MR
		—	—	—
		—	—	—
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> </ul>			
	<ul style="list-style-type: none"> <li>• Overhead Tank capacity</li> </ul>	10000 ltr	10000 ltr	MR
15	Exit Signage.			
		—	—	—
16	Provision of Lifts.			
		NIA		
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
17	Standby power supply			
		—	—	—
18	Refuge Area.			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	—	—	—
		—	—	—
19	Fire Control Room			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> </ul>	—	—	—

	<ul style="list-style-type: none"> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer  04-3-14.

Name N. P. Sharma

Designation ADD R.

Signature of the Inspecting Officer

Name

Designation

lecdan