

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI- 110001


No. F6/DFS/MS/school/2014/NDZ/5/8

Dated: 25/04/14

FIRE SAFETY CERTIFICATE

Certified that the Dashmesh Public School at Vasundhara Enclave, Delhi-96, owned/occupied by Dashmesh Public School, comprising of basement ,ground plus two upper floors was granted NOC vide letter no. No.F.6/DFS/MS/2008/1359 dated 16.05.2008.The school building was inspected by the officer concerned of this department on 18.04.2014 in the presence of Smt.Vinay Panday (OS) of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular no.262-362 Dated 17.01.2005 issued by the Director of Education and found that the building is fit for occupancy class B "Educational Building" with effect from 25/04/14... for a period of three years, subject to conditions printed overleaf.

Issued on 25/04/14..... at New Delhi by



(Dr. G.C. Misra)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE  
Tel:- 011-23414333  
E-Mail:- [cfohq.dlfire@nic.in](mailto:cfohq.dlfire@nic.in)

To,  
The Principal  
Dashmesh Public School  
Vasundhara Enclave, Delhi-96,

Copy to:-  
The Director of Education  
GNCT of Delhi, Old secretariat  
Delhi -54.

OK  
04

- Conditions -

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
6. Basement shall be used as per BBL.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)



1. Name & address of the building: Dashmesh Public School at Vasundhara Enclave, Delhi .
2. Building is comprised of : Basement, Ground +2, upper floor.
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/2008/1359 dated 16.05.2008
6. Fire Safety direction letter No : Circular No.262-362 Dated 17.01.2005 Director of Education
7. Date of Inspection : 12.02.2014 & 18.04.2014
8. Name of the Inspecting officers: DO Virendra Singh
9. Name and designation of Officer:  
from the building side : Smt. Vinay Panday (OS).
10. Year of Construction - :2005
11. Applicant's letter No : DPS/No.64/6358 dated 29.01.2014

| NO. | Minimum Standards on fire prevention and fire safety U/R33 | Old Circular Requirement | Provided at Site | Remarks |
|-----|--|--------------------------|------------------|---------|
| 1   | Access to building   |                          |                  |         |
|     | • Road width   | 06 Mtrs.                 | 15 Mtrs.         | MR      |
|     | • Gate width   | 4.5 Mtrs.                | 4.5 Mtrs.        | MR      |
|     | • Width of internal road                                   | N/A                      | 06 Mtrs.         | MR      |
| 2   | Number, Width, Type and Arrangement of Exits               |                          |                  |         |
|     | a. Number of Staircases                                    |                          |                  |         |
|     | • Upper Floor  | 03 Nos                   | 03 Nos.          | MR      |
|     | • Basement   | 03 Nos                   | 03 Nos.          | MR      |
|     | B. Width of Staircases                                     |                          |                  |         |
|     | • Upper Floor  | 1.5 M                    | 1.8 M & 1.7 M    | MR      |
|     | • Basement   | 1.5 M                    | 1.8 M & 1.7 M    | MR      |
|     | c. Protection of exits                                     | Required                 | Provided         | MR      |
|     | • Fire check door  | Required                 | Provided         | MR      |
|     | • Pressurization   | N/A                      | N/A              | N/A     |
|     | e. No. of continuous staircases to terrace                 | 2 nos.                   | 2 Nos.           | MR      |
|     | g. Width of Corridor                                       | 1.5 M                    | 2.0 M            | MR      |
|     | h. Door Size   | 1.0 Mtrs                 | 1.0 Mtrs         | MR      |
| 3   | Compartmentation.  |                          |                  |         |
|     | • Fire check door  | Required                 | Provided         | MR      |
|     | • Sealing of electrical shafts                             | Required                 | Sealed           | MR      |
|     | • Fire rating of shaft door                                | N/A                      | N/A              | N/A     |
|     | • Water curtain  | N/A                      | N/A              | N/A     |
|     | • Fire Dampers   | N/A                      | N/A              | N/A     |
| 4   | Smoke Management System.                                   |                          |                  |         |
|     | • Basement   | Required                 | Provided         | MR      |
|     | • Upper floor  | N/A                      | N/A              | N/A     |
| 5.  | Fire Extinguishers   |                          |                  |         |
|     | • Total numbers  | 24 Nos.                  | 30 Nos.          | MR      |
|     | • Types  | ABC & Co2                | ABC & Co2        | MR      |
|     | • IS marking   | ISI marked               | ISI marked       | MR      |
| 6   | First-aid-Hose Reels.                                      |                          |                  |         |
|     | Total numbers of each floor                                | 4 nos.                   | 4 nos.           | MR      |
|     | • Length of hose reel hose                                 | 30 M                     | 30 M             | MR      |
|     | • Nozzle diameter  | 5 mm                     | 5 mm             | MR      |
| 7   | Automatic fire detection and alarming system.              |                          |                  |         |
|     | • Type of detectors  | N/A                      | N/A              | N/A     |
|     | • Location of main panel                                   | N/A                      | N/A              | N/A     |
|     | • Location of repeater panel                               | N/A                      | N/A              | N/A     |



|    |  |              |                 |     |
|----|--|--------------|-----------------|-----|
| 8  | MOEFA                                    | N/A          | Provided        | MR  |
| 9  | Public address System.                   | N/A          | Provided        | MR  |
| 10 | Automatic Sprinkler System.              |              |                 |     |
|    | • Basement                               | Required     | Provided        | MR  |
|    | • upper floor                            | N/A          | N/A             | N/A |
|    | • sprinkler above false ceiling          | N/A          | N/A             | N/A |
| 11 | Internal Hydrants                        |              |                 |     |
|    | • size of riser/down-comer               | 100 MM       | 100 MM          | MR  |
|    | • Number of hydrants per floor           | 4 Nos.       | 4 Nos.          | MR  |
|    | • Hose Box                               | 4 Nos.       | 4 Nos.          | MR  |
| 12 | Yard Hydrants.                           |              |                 |     |
|    | • Total number of hydrants               | N/A          | 4 Nos. Provided | MR  |
|    | • Hose Box                               | N/A          | 4 Nos. Provided | MR  |
| 13 | Pumping Arrangements.                    |              |                 |     |
|    | • Ground Level                           | N/A          | Provided        | MR  |
|    | ➤ Discharge of main Pump                 | N/A          | 1620 LPM        | MR  |
|    | ➤ Head of Main Pump                      | N/A          | 60 M            | MR  |
|    | ➤ Number of main pumps                   | N/A          | 01 No.          | MR  |
|    | ➤ Jockey pump out put                    | N/A          | 180 LPM         | MR  |
|    | ➤ Jockey pump head                       | N/A          | 60 M            | MR  |
|    | ➤ Standby pump out put                   | N/A          | 1620 LPM        | MR  |
|    | ➤ Standby pump Head                      | N/A          | 60 M            | MR  |
|    | ➤ Auto Starting /Manual stopping         | N/A          | Provided        | MR  |
|    | ➤ Pump House Access                      | N/A          | Provided        | MR  |
|    | • Terrace Level                          | Required     | Provided        | MR  |
|    | ➤ Discharge of pump                      | 450 LPM      | 2 no. 450 LPM   | MR  |
|    | ➤ Head of the Pump                       | 40 M         | 40 M            | MR  |
|    | ➤ Power supply                           | Required     | Provided        | MR  |
|    | ➤ Auto Starting of pump                  | Required     | Provided        | MR  |
| 14 | Captive Water Storage for Fire Fighting. |              |                 |     |
|    | • Underground tank capacity              | 50,000 Ltrs. | 1,00,000 Ltrs.  | MR  |
|    | ➤ Draw-off connection                    | Required     | Provided        | MR  |
|    | ➤ Fire service inlet                     | Required     | Provided        | MR  |
|    | ➤ Access to tank                         | Required     | Provided        | MR  |
|    | • Overhead Tank capacity                 | 5000 Ltrs.   | 20,000 Ltrs.    | MR  |
| 15 | Exit Signage.                            | N/A          | N/A             | N/A |
| 16 | Provision of Lifts.                      |              |                 |     |
|    | • Pressurization of Lift Shaft           | N/A          | N/A             | N/A |
|    | • Pressurization of Lift lobby           | N/A          | N/A             | N/A |
|    | • Communication in lift car              | N/A          | N/A             | N/A |
|    | • Firemen's grounding switch             | N/A          | N/A             | N/A |
|    | • Lift Signage                           | N/A          | N/A             | N/A |
| 17 | Standby power supply                     | N/A          | N/A             | N/A |
| 18 | Refuge Area.                             | N/A          | N/A             | N/A |
|    | • Total area                             | N/A          | N/A             | N/A |
|    | • Location                               | N/A          | N/A             | N/A |
| 19 | Fire Control Room                        | N/A          | N/A             | N/A |
|    | • Detector system panel                  | N/A          | N/A             | N/A |
|    | • Flow switch panel                      | N/A          | N/A             | N/A |
|    | • PA system panel                        | N/A          | N/A             | N/A |
|    | • Battery backup                         | N/A          | N/A             | N/A |
|    | • Building Floor Plans                   | N/A          | N/A             | N/A |

N/7

|    |  |     |     |     |
|----|--|-----|-----|-----|
| 20 | Special Fire Protection systems for protection of special Risks, if any: | N/A | N/A | N/A |
|----|--|-----|-----|-----|

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The NOC issued vide letter no. F.6/DFS/MS/2008/1359 Dated 16.05.2008 renewal under the circular no. 262-362 dated 17.01.2005 is recommended.

  
22/11/19

Signature of the Inspecting Officer

Name:-Virendra Singh

Designation:-DO(ED)

Dy.CFO(NDZ)