

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. FG/DFS/MS/2014/Motel/w2/530

Dated: 30/09/2014

FIRE SAFETY CERTIFICATE

Certified that **Carnival Motel, G T Karnal Road, Village Alipur, New Delhi.** comprised of **Basement + Ground + first floor Building** owned / occupied by **S. K. Motel and Resorts** has already been issued fire safety certificate vide Letter **NO F-6/DFS/MS/Motel/2011/640 dated 11/04/2011.** The premise have deem complied with the fire prevention and fire safety Requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of fire service on **12/04/2014** in the presence of **Sh Parveen Kumar** and that the building / premises is fit for occupancy **Class Residential Buildings** with effect from _____ / _____ / **2014** for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

1. All employees shall be acquainted with the use and maintenance of all the fire fighting installation/equipments.
2. The fire suppression / protection arrangements provided are to minimize losses, if maintained in good working condition. These systems cannot give a guarantee that there will be no fire or losses in the event of one.
3. Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the licensee.
4. This report may not in any way be treated as regularization of unauthorized construction, if any. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. The trained fire fighting staff should be available round the clock.
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on / /2014 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in

Copy to:

1. Sh Shiv Kumar, Carnival Motel, Village Alipur, G T Karnal Road, New Delhi
2. The Joint Commissioner of Police (Lic), 1st floor, Police station, Defense Colony, New Delhi.

INSPECTION REPORT

1. Name & address of the building : Carnival Motel G T Karnal Road, Village Alipur, New Delhi (B + G + 1)
2. Type of Occupancy : Motel
3. Type of Case : Renewal
4. Details of previous NOC : F-6/DFS/MS/Motel/2011/640 dated 11/04/2011
5. Fire Safety directives letter no. : F6/DFS/MS/BP/GH/2005/369. Date 23/02/2005
6. Date of inspection : 12/04/2014
7. Name of the Inspecting Officers : DO (NW)
8. Name and designation of officers :
from the building side : Sh. Parveen Kumar
9. Year of Construction : 2005
10. Applicant's letter No. : No.15253/Joint. CP/Lic. (H) dated 28/03/2014

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	Accessible	M/R.
	• Gate width	06 mtr	P	M/R.
	• Width of internal road	--	--	--
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	3	3	M/R
	• Basement	3	3	M/R
	b. Width of staircases			
	• Upper Floors	Old case	Old case	M/R
	• Basement	02 mtr	02 mtr	M/R
	c. Protection of exits			
	• Fire check door	R	P	M.R
	• pressurization	--	--	--
	d. No. of continuous staircases to terrace	--	--	--
	e. Width of Corridor	--	--	--
	f. Door size	01 mtr	01 mtr	M/R

3.	Compartmentation.			
	• Fire check door	R	P	M/R
	• Sealing of electrical shafts	R	P	M/R
	• Fire Rating of shaft door	—	—	—
	• Water Curtain	—	—	—
	• Fire Dampers	—	—	—
4.	Smoke Management System.			
	• Basements	30 a/c per hour	Exhaust fans	M/R
	• Upper floors	12 a/c per hour	P	M/R
5.	Fire Extinguishers			
	• Total numbers	16	08 ABC	M/R
	• Types	ISI Marked	08 WCO2	M/R
	• IS marking		Yes	M/R
6.	First-Aid Hose Rees.			
	• Total numbers on each floor	02	02	M/R.
	• Length of hose reel hose	30 m	P	M/R
	• Nozzle diameter	5 mm	P	M/R
7.	Automatic fire detection and alarming system.			
	• Type of detectors	R	P	M/R
	• Location of Main Panel	G/F	P	M/R
	• Location of Repeater Panel	Each floor	P	M/R
	• Alternate source of power	R	62 KVA	M/R
	• Hooter's Location	Each floor	P	M/R
8.	MOEFA			
		R	P	M/R
9.	Public Address System.			
		R	P	M/R
10.	Automatic Sprinkler system			
	• Basement	R	P in entire building	M/R
	• Upper Floor	R	P	M/R
	• Sprinkler above false ceiling	—	—	—
11.	Internal Hydrants			
	Size of riser/down-comer	4"	P	M/R
	• Number of hydrants per floor	02	P	M/R
	• Hose Box	02	P	M/R
12.	Yard Hydrants.			
	• Total number of hydrants	02	P	M/R
	• Hose Box	02	P	M/R

13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	—	—	—
	➤ Head of Main pump	—	—	—
	➤ Number of main pumps	—	—	—
	➤ Jockey Pump out put	180LPM	P	M/R
	➤ Jockey pump head	40 M	P	M/R
	➤ Standby pump out put	—	—	—
	➤ Standby pump Head	—	—	—
	➤ Auto Starting/Manual stopping	R	P	M/R
	➤ Pump Hose Access	—	—	—
	Terrace level			
	➤ Discharge of pump	1620 LPM	P	M.R
	➤ Head of the pump	40 m	P	M.R
	➤ Power supply	—	—	—
	➤ Auto Starting of pump	R	P	M.R
14.	Captive Water Storage for fire fighting.			
	➤ Underground tank capacity	1, 00,000 ltr.	P	M/R
	➤ Draw -off connection	R	P	M/R
	➤ Fire service inlet	R	P	M/R
	➤ Access to tank	R	P	M/R
	➤ Overhead Tank Capacity	10,000 ltr.	P	M/R
15	Exit Signage.	R	P	M/R
16.	Provision of Lifts			
	• Pressurization of Lift Shaft	—	—	—
	• Pressurization of Lift lobby	—	—	—
	• Communication In lift Car	R	P	M/R
	• Fireman's Grounding Switch	R	P	M/R
	• Lift Signage	R	P	M/R
17.	Standby power supply	R	62.5 KVA	M.R.
18.	Refuge Area			
	➤ Total Area	N.A.	N.A	N.A
	➤ Location	N.A.	N.A	N.A

19.	Fire Control Room			
	➤ Detector System Panel	R	P	M.R
	➤ Flow Switch Panel	R	P	M.R
	➤ PA system Panel	R	P	M.R
	➤ Batter backup	R	P	M.R
	➤ Building Floor plans	N/R	N/R	N/R
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.A.	N.A	N.A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F-6/DFS/MS/Motel/2011/640 dated 11/04/2011 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspection Officer

Signature of the Inspection Officer

Name

Name

Designation

Designation

[Handwritten Signature]
16/4/14
(w)