

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

Fax: 23412593, 011-23414333

NO.F6/DFS/MS/EH/2014/527563

Dated: 2/5/14

FIRE SAFETY CERTIFICATE

Certified that M/s Chungwa Super Caterers (Restaurant), located at M-34, Greater Kailash-II, Market, New Delhi-110048, is running at Ground & First floor with seating capacity of 80 persons in a building comprised of Basement, Ground + 03 Upper floors was granted FSC by this department vide letter No.F6/DFS/MS/EH/2011/367 dated 23/02/11. The premises was re- inspected by the officer concerned of this department in the presence of Mr. Gaurav (owner) on 12/04/14 and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Group - D, Assembly Building (Restaurant) with effect from ~~2-5-14~~ for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued ~~2/5/14~~ at New Delhi by.


(Dr. G.C. Misra)
Chief Fire Officer

Copy to:-

- (1) Dy. Health Officer,
MCD, South Zone, Green Park, New Delhi.
- (2) Mr. Surinder Pal Singh (Partner),
M/s Chungwa Super Caterers,
M-34, Greater Kailash Market,
New Delhi-110048

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of NBC
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building:- M/s Chungwa Super Caterers, M-34, Greater Kailash-II Market, New Delhi-110048
2. Type of occupancy:- Group – D (Assembly), Restaurant
3. Type of case:- Renewal
4. Details of previous NOC:- F6/DFS/MS/EH/2011/367 dated-23/02/2011
5. Fire safety directives No.- Nil
6. Date of inspection:-12/04/2014
7. Name of the inspecting officer:- D.B.Mukherjee, A.D.O.(BCP)
8. Name & designation of officer From the building side:- Mr. Gaurav (Owner)
9. Year of construction:- 1995
10. Applicant's letter no:- Nil Dated: 08/03/2014

Building is comprised of Basement, Ground + Three upper floors.

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement BBL/NBC	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	09 m	15m Provided	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	Old Case	02 nos.	MR(Old Case)
	2. Basements	Old Case	02 nos.	MR(Old Case)
	B. Width of staircase			
	1. Upper floors	Old Case	89cm & 1 m	MR(Old Case)
	2. Basements	Old Case	81cm & 1.02 m	MR(Old Case)
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	Required	01 Nos	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	Required 2 m	2m, 1.52m & 0.84m	MR
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	Provided	MR
	2) Upper floors	12 a/c per hour	Provided	MR
5.	Fire Extinguishers			
	1) Total numbers	ISI Marked	09Nos.	MR
	2) Types		ABC, Co2	MR
	3) ISI marking		Yes	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	Required	Provided	MR
	2) Length of hose reel hose	30 m	Provided	MR
	3) Nozzle diameter	5 mm	Provided	MR

7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided DG Set 64KVA	MR
	5) Hooter's Location	Every Floor	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	Required	Provided	MR
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 mm	Provided	MR
	2) Number of hydrants per floor	01	Provided	MR
	3) Hose box	01	Provided	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	Provided 02 nos. of pump 1080 & 600 LPM	MR
	b) Head of pump	Required	38 m & 30 m	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	5000 ltrs.	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR

18.	Refuge Area			
	Total area	N/A	N/A	N/A
	location	N/A	N/A	N/A
19.	Fire Control Room			
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the building were checked and found functional at the time of inspection.

In view of the compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F6/DFS/MS/EH/2011/367 dated 23/02/2011, renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended. Accordingly DFA is put up for signature please.

Accordingly DFA is put up please.

Signature of the inspecting officer

Name :- D.B. Mukherjee.
Designation :- Assistant Divisional Officer.