

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**

No.F6/DFS/MS/2014/52/554

Dated : 02/05/14

FIRE SAFETY CERTIFICATE

Certified that the **Dr. SR KVS Auditorium** located at **Kendriya Vidyalaya No.2, Near APS Colony, Gurgaon Road, Delhi Cantt.** comprised of **Ground + 2 Upper Floor** owned / Occupied by **Dr. SR KVS Auditorium**. The premises was inspected by the officer concerned of this department on **23/04/14** in the presence of NK Verma and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Assembly Building Group-D** with effect from 02/05/14 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 subject to conditions printed below.

Issued 02/05/14 at New Delhi by.


(Dr. GC Misra)
Chief Fire Officer
Ph. 011-23414333

Copy to:- (1) The Joint Commissioner of Police, (Lic.),
First Floor, PS Defence Colony, New Delhi.

(2) Dr. SR KVS Auditorium,
Kendriya Vidyalaya No.2, Near APS Colony, Gurgaon Road, Delhi Cantt.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

N/10

INSPECTION REPORT

1. Name & address of the building:- Dr. SR KVS Auditorium, Kendriya Vidyalaya No.2, Near APS Colony, Gurgaon Road, Delhi Cantt.
2. Type of occupancy:- Assembly Building Group-D.
3. Type of case:- New
4. Details of previous NOC:- No
5. Fire safety directives No.- F6/DFS/MS/BP/2012/3496 dated 24/09/12.
6. Date of inspection:- 23/04/14.
7. Name of the inspecting officer:- D.O. D.P. Bharadwaj & A.D.O. S.S. Kaushik
8. Name & designation of officer
From the building side:- Mr. N.K. Verma.
9. Year of construction:- 2006
10. Applicant's letter No:-15672-74/Joint.C.P./Lic.dated 02/04/14 Ground + 2 Upper Floor

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC /BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	14 mtr.	Provided	MR
	2) Gate width	5 mtr.	Provided	MR
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	3 Nos.	3 Nos.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.50 mtr.	1.50 mtr. X 2, 1.25 mtr. & 2 ramp 1.46 mtr. & 1.40 mtr.	N/A
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	Yes	Provided	MR
	2. Pressurization	Yes	Provided	MR
	D. No. of continuous staircase to terrace	2 Nos.	2 Nos.	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	10 Nos. 185 cms. each	Provided	MR
3.	Compartmentation			
	1) Fire check door	Yes	Provided	MR
	2) Sealing of electrical shafts	Yes	Provided	MR
	3) Fire rating of shaft door	Yes	Provided	MR
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	Yes	Provided	MR
4.	Smoke Management System			
	1) Basements	30 a/c per hour	N/A	N/A
	2) Upper floors	12 a/c per hour	Exhaust fan	MR

Handwritten signature

A/11-

5.	Fire Extinguishers			
	1) Total numbers	ISI Marked	35 Nos.	MR
	2) Types		ABC & W.Co2	MR
	3) ISI marking		Yes	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	Required	4 Nos. at ground floor & 1 Nos. at 1 st floor & 2 nd floor each.	MR
	2) Length of hose reel hose	30 m	Yes	MR
	3) Nozzle diameter	5 mm	Yes	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Smoke & beam	Provided	MR
	2) Location of main panel	Ground floor	Yes	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Yes	Provided	MR
	5) Hooter's Location	at all floors	Provided	MR
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	150 mm.	150 mm.	MR
	2) Number of hydrants per floor	4 Nos. at ground floor & 1 Nos. at 1 st floor & 2 nd floor each.	4 Nos. at ground floor & 1 Nos. at 1 st floor & 2 nd floor each.	MR
	3) Hose box	-----do-----	-----do-----	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	1620 LPM	1620 LPM	MR
	b) Head of main pump	60 mtr.	60 mtr.	MR
	c) Number of main pump	1 Nos.	1 Nos.	MR
	d) Jockey pump out put	180 LPM	180 LPM	MR
	e) Jockey pump head	60 mtr.	60 mtr.	MR
	f) Stand by pump output	1620 LPM	1620 LPM	MR
	g) Stand by pump head	60 mtr.	60 mtr.	MR
	h) Auto starting/Manual stopping	Yes	Yes	MR
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM	MR
	b) Head of pump	40 mtr.	40 mtr.	MR
	c) Power supply	Yes	Yes	MR

Handwritten signature

	d) Auto starting of pump	Yes	Yes	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	50,000 Ltrs.	50,000 ltrs.	MR
	a) Draw-off connection	Yes	Provided	MR
	b) Fire service inlet	Yes	Provided	MR
	c) Access to tank	Yes	Provided	MR
	d) Over head tank capacity	10,000 ltrs.	10,000 Ltr.	MR
15.	Exit Signage.	Yes	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A

	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Yes	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	Yes	Provided	MR
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	Yes	Provided	MR
	e) Building floor plan	Yes	Provided	MR
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the building were checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010-----

Accordingly DFA is put up please

Signature of the inspecting officer

Signature of the inspecting officer

Name:- D.P. Bharadwaj

Name:- S.S. Kaushik.

Designation:- Divisional Officer

Designation:- Assistant Divisional Officer