

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/Hospital/2014/W2/508 Dated: 24/04/2014

**FIRE SAFETY CERTIFICATE**

Certified that the **Jaipur Golden Hospital, Sector – 03, Rohini, Delhi-110085** is comprised of **Basement + Ground + Five upper floors** owned and occupied by **Jaipur Golden Hospital** was issued NOC for block IV and residential nurses hostel vide this office letter No **F6/DFS/MS/Hospital/99/554 dated 19/07/1999** was inspected by the officers concerned of this department on **20/03/2014** in the presence of **Mr. Malik (Fire Officer)** and found that the **Hospital building** have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and premises is fit for occupancy with effect from **24/04/2014** for a period of **three years** subject to conditions printed below.

1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able by guests in an event of emergency.
2. All employees shall be acquainted with the use and maintenance of all the fire fighting installation/equipments.
3. The fire suppression / protection arrangements provided in the guest house are to minimize losses, if maintained in good working condition. These systems cannot give any guarantee that there will be no fire or losses in the event of one.
4. Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the licensee.
5. This report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on...24/04/14.....at New Delhi.

  
(SANTOKH SINGH)  
Chief Fire Officer  
Delhi Fire Service  
Ph: 011-23414250  
[cfowz.dlfire@nic.in](mailto:cfowz.dlfire@nic.in)

**Copy to:**

1. The, Dr. Khushali Ratra, Medical Superintendent, Jaipur Golden Hospital, Sector – 03, Rohini, Delhi-110085

**INSPECTION REPORT**

**Block-A-(B+G+1,) Block-B&C-(B+G+3,) Block-D-(B+G+5)**

1. Name & address of the building: Jaipur Golden Hospital, Sector – 03, Rohini,
2. Type of Occupancy : **Hospital**
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/91(Hospital)117 dt 23/01/91( Low rise bldg)  
F6/DFS/MS/Hospital/99/554 dt 19/07/99 (IV blocks, H.R)
5. Fire Safety directives letter No :
6. Date of inspection : 20/03/2014
7. Name of the Inspecting Officers : DCFO(WZ) & DO (NW)
8. Name and designation of officers  
from the building side : Mr. Malik (Fire Officer)
9. Year of Construction : 1990 &1999
10. Applicant's letter No. : JGH/ADMIN/FIRE/2014/210 dated 10/03/2014.

	<b>Minimum Standards on fire prevention and fire safety U/R 33</b>	<b>NBC Requirement</b>	<b>Provided at site</b>	<b>Remarks MR/NMR</b>
1	<b>Access to building</b>			
	• Road width	09 mtr	09 mtr ✓	M/R ✓
	• Gate width	05 mtr	P ✓	M/R ✓
	• Width of internal road	06 mtr , 09 mtr T.C	P ✓	M/R ✓
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	Old case	Old case ✓	Old case ✓
	• Basements	Old case	Old case ✓	Old case ✓
	b. Width of staircases			
	• Upper Floors	Old case	Old case ✓	Old case ✓
	• Basements	Old case	Old case ✓	Old case ✓
	c. Protection of exits			
	• Fire check door	R	p ✓	M/R ✓
	• Pressurization	N.A	P ✓	N.A ✓
	e. No. of continuous staircases to terrace	Old case	Old case ✓	Old case ✓
	g. Width of Corridor	Old case	Old case ✓	Old case ✓
	h. Door Size	Old case	Old case ✓	Old case ✓

3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> </ul>	R	P	M/R ✓
	<ul style="list-style-type: none"> <li>• Sealing of electrical shafts</li> </ul>	R	P	M/R ✓
	<ul style="list-style-type: none"> <li>• Fire Rating of shaft door</li> </ul>	R	P	M/R ✓
	<ul style="list-style-type: none"> <li>• Water Curtain</li> </ul>	N/A	N/A	N/A ✓
	<ul style="list-style-type: none"> <li>• Fire Dampers</li> </ul>	N/A	N/A	N/A ✓
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	30 a/c per hour	P	M/R ✓
	<ul style="list-style-type: none"> <li>• Upper floors</li> </ul>	12 a/c per hour	P	M/R ✓
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> </ul>	Water Co2 09	188	M/R ✓
	<ul style="list-style-type: none"> <li>• Types</li> </ul>	ltr Co2 type 4.5	Yes	M/R ✓
	<ul style="list-style-type: none"> <li>• IS marking</li> </ul>	kg DCP type ISI marked	Yes	M/R ✓
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> </ul>	5 no's	P	M/R ✓
	<ul style="list-style-type: none"> <li>• Length of hose reel hose</li> </ul>	30 m	P	M/R ✓
	<ul style="list-style-type: none"> <li>• Nozzle diameter</li> </ul>	5 mm	P	M/R ✓
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> </ul>	R	P	M/R ✓
	<ul style="list-style-type: none"> <li>• Location of Main Panel</li> </ul>	R	P	M/R ✓
	<ul style="list-style-type: none"> <li>• Location of Repeater Panel</li> </ul>	R	P	M/R ✓
	<ul style="list-style-type: none"> <li>• Alternate source of power</li> </ul>	R	P	M/R ✓
	<ul style="list-style-type: none"> <li>• Hooters' Location</li> </ul>	Comman area	P	M/R ✓
8	<b>MOEFA</b>	R	P	M/R ✓
9	<b>Public Address System.</b>	R	P	M/R ✓
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> </ul>	R	P	M/R ✓
	<ul style="list-style-type: none"> <li>• Upper Floor</li> </ul>	R	P	M/R ✓
	<ul style="list-style-type: none"> <li>• Sprinkler above false ceiling</li> </ul>	—	—	—
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> </ul>	100 mm	P	M/R ✓
	<ul style="list-style-type: none"> <li>• Number of hydrants per floor</li> </ul>	05 no.	P	M/R ✓
	<ul style="list-style-type: none"> <li>• Hose Box</li> </ul>	05 no.	P	M/R ✓

12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	R	P	M/R
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	R	P	M/R
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>			
		2400 LPM	P	M/R
		70 M	P	M/R
		2 electric 1 stand by 0 jockey	P	M/R
		180 LPM	P	M/R
		70 M	P	M/R
		2400 LPM	P	M/R
		70 M	P	M/R
		R	P	M/R
		R	P	M/R
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> </ul>	3,00,000 ltrs	P	M/R
	<ul style="list-style-type: none"> <li>Draw-off connection</li> </ul>	R	P	M/R
	<ul style="list-style-type: none"> <li>Fire service inlet</li> </ul>	R	P	M/R
	<ul style="list-style-type: none"> <li>Access to tank</li> </ul>	R	P	M/R
	<ul style="list-style-type: none"> <li>Overhead Tank capacity</li> </ul>	20,000 ltr	P	M/R
15	<b>Exit Signage.</b>			
		R	P	M/R
16	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> </ul>	R	P	M/R
	<ul style="list-style-type: none"> <li>Pressurization of Lift lobby</li> </ul>	N/A	P	M/R
	<ul style="list-style-type: none"> <li>Communication In lift Car</li> </ul>	R	P	M/R
	<ul style="list-style-type: none"> <li>Fireman's Grounding Switch</li> </ul>	R	P	M/R
	<ul style="list-style-type: none"> <li>Lift Signage</li> </ul>	R	P	M/R
17	<b>Standby power supply</b>			
		R	P	M/R

18	<b>Refuge Area.</b>			
	➤ Total Area	R	P	M/R
	➤ Location	4 th floor	P	M/R
19	<b>Fire Control Room</b>			
	• Detector System Panel	R	P	M/R
	• Flow Switch Panel	R	P	M/R
	• PA System Panel	R	P	M/R
	• Batter backup	R	P	M/R
	• Building Floor Plans	R	P	M/R
20	Special Fire Protection Systems for Protection of special Risks, if any:		No special risk at present	

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/DFS/MS/Hospital/99/554 dt 19/07/99 Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name

Designation

Signature of the Inspecting Officer

Name

Designation

*[Handwritten Signature]*  
7/4/14  
DO (NW)