

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No: F6/DFS/MS/FW/2014/W2/547

Dated: 01/05/14

FIRE SAFETY CERTIFICATE

Certified that M/s Jindal Fire Works located at Ground Floor, Shop No. 7-8, DDA Market, Camp No.-1, Nangloi, Main Rohtak Road, Delhi-110041 of premises comprised of Ground + one upper floor owned/ occupied by M/s Jindal Fire Works, Proprietor (Sh. Harish Kumar) have complied with the guidelines issued by Delhi Police under Delhi Police Act and verified by the officer concerned of fire service on 28-03-2014 in the presence of Sh. Harish Kumar and that the building/ premises is fit for occupancy Class Mercantile (Group-F) Building Sub Division F – 1 w.e.f. date of issue of this certificate for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of Delhi Fire Service Rules, 2010.

Issued on ..01/05/14..... at New Delhi.


(SANTOKH SINGH)
CHIEF FIRE OFFICER.
Phone No.23414250.

Following fire safety directives must be adhered to:

1. All the means of escape/ entry/ exit shall be kept free from any obstruction.
2. All the fire protection measures shall be maintained in perfect working conditions all the times as seen during inspection.
3. All the staff members must know the correct method operation of fire fighting system.
4. Any lapse rendering fire fighting system/ equipment non functional shall be risk and responsibility of the management.
5. This inspection report may not in any way be treated as regularization of unauthorized construction, if any.
6. The NOC is for fireworks only.

Copy to:


1. The Joint. Commissioner of Police (Lic.),
1st Floor, P.S. Defence Colony, New Delhi.
(Ref. No. (PFW/06)/2014/12312-15/Jt.CP/Lic.(Expl.), dated 11-03-2014
2. Sh. Harish Kumar, R/o House No. F-1/445/447, Sultan Puri, Delhi – 110086.

INSPECTION PERFORMA (PART – B)
(TO BE FILLED IN TRIPLICATE BY THE INSPECTING OFFICER)

DATE:

TIME:

S.NO.	POINT OF INSPECTION	NORM AS PER GUIDELINES/ VR COMMITTEE REPORT	REMARKS OF THE INSPECTING OFFICER
1.	Type of construction and floor area and floor level	<ol style="list-style-type: none"> 1. Minimum floor area 9 m² 2. Pucca construction 3. Premises not under staircase/ means of exit 4. Business permissible only at ground floor 5. Business from pavement of road prohibited 	Provided Provided Provided Ground Floor Only Prohibited
2.	Entrance & exit to the licensed premises	The licensed premises shall have independent entrance and exit	Provided
3.	Type and distance of surrounding risk	The premises shall be situated at a distance of 15m from any such premises used for similar exclusive/ inflammable or hazardous materials	Provided
4.	Nature of business run in the licensed premises	The premises in which fire works are kept shall be used only for possession and sale of fire works and no other purpose	No other business allowed
5.	Type of Electrical wiring and electrical fittings	<ol style="list-style-type: none"> 1. Preferably concealed or through conduit 2. The electrical fittings should be flame/ spark proof 	Provided Provided
6.	Extension of shop for business	prohibited	Prohibited
7.	Approach road	The road width on the sides of which premises is located should be 12m	Provided
8.	Fire Protection arrangements <ol style="list-style-type: none"> 1. Extinguishers (type & no.) 2. Sand/ Water buckets 3. Water Drum 	<ol style="list-style-type: none"> 1. All the extinguishers shall have ISI mark 2. No. of fire extinguishers & type shall be in accordance with the risk & area of the premises 3. Minimum 2 buckets each of sand & water shall be provided 	Provided 4 nos. (2 ABC 5kg, 1 Foam 9 ltr, 1 CO2 4.5 Kg) Provided
9.	Any other point that is contrary to the safety of people		Fireworks allowed only at Ground Floor, No other trade is allowed.


 2/4/2014
 Signature of Inspecting Officer
 Designation
 ADO/(DWP)

GRANT OF NOC FOR SALE/ STORAGE OF FIRE WORKS
(In areas other than walled city and congested areas)
INSPECTION REPORT (PART - A)
(To be filled by the Inspecting Officer)

1. Name and Address of the licensee: M/s Jindal Fire Works, Proprietor Sh. Harish Kumar
2. Address of the licensed premises: Shop No. 7-8, DDA Market, Camp No.-1, Nangloi, Main Rohtak Road, Delhi-110041.
3. License No. and validity period: New
4. Authority by which license was issued last: New
5. Name and Designation of the Inspecting Officer: Ashok Kumar Jaiswal, ADO (Jwalapuri).
Date and time of inspection: 28-03-2014 at 1300 Hours
6. Period for which license is to be renewed and the authorized quantity: 1500 kg (300 kg fireworks + 1200 kg Chinese/ Sparkles)
7. Recommendations of the inspecting officer for issue/ rejection of NOC with reasons: Recommended

Remarks of DO

Ak Jaiswal
28/3/14
(Signature of Inspecting Officer)
Designation
ADO (JOP)