

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001


No. P61DPS/MS/2014/W2/568

Dated: 27/5/14

FIRE SAFETY CERTIFICATE

Certified that the Metro Club located at Hiran Kudna Road, Ghevra, New Delhi-110041, comprises of Hall (at Lower Ground Floor) + Ground Floor (Office) + 1<sup>st</sup> Floor (Bridal Rooms) only, owned/occupied by M/S Metro Club, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules,2010 and verified by the officer concerned of Delhi Fire Service on dated 21.02.14 in the presence of Sh. Om Prakash Jindal (Owner) and that the building is fit for occupancy class "Assembly" Group D except lower ground with effect from ...2.1.5.../..2014 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules,2010.

Issued on.....2/05/2014.....at New Delhi by

  
Santokh Singh  
Chief Fire Officer  
Delhi Fire Service

E-mail : cfowz.dlfire@nic.in

Phone : 011-23414250



Copy to:-

1. M/s Metro Club, Hiran Kudna Road, Ghevra, New Delhi-41.
2. Assistant Commissioner, NDMC, Narela Zone, Narela Delhi-110040.

Conditions for the validity of fire safety certificate are overleaf:-

### CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

M/1

3 step below GF

**INSPECTION REPORT**

Hall (Lower GF) + GF + 1F  
 Hall office Bridal Rooms

1. Name & address of the building: Metro club, Hiran Kudna Road  
Ghevra, Delhi - 110041
2. Type of Occupancy: Assembly
3. Type of Case: NLEW
4. Details of previous NOC: Letter No Nul
5. Fire Safety directives Letter No.: NBC Part (IV)
6. Date of inspection: 21/2/2014
7. Name of the Inspecting Officer: A.K. Jaiswal
8. Name and designation of Officer  
 from the building side: Om Prakash Jaiswal
9. Year of Construction: ---
10. Applicant's letter No.: Nul dated 21/2/14

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL / NBC (IV) Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 Mtr	Provided	MR
	• Gate width	4.5 Mtr	Provided	MR
	• Width of internal road	6 Mtr	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.25 Mtr	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NR	NR	NR
	• Pressurization	NR	NR	NR
	d. No of continuous staircase to terrace	1	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2.00 Mtr.	Provided	MR

3.	Compartmentation			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>			
4.	Smoke managements System			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	30 a/c per hour	NA	NA
	<ul style="list-style-type: none"> <li>• Upper floors</li> </ul>	12 a/c per hour	Exhaust Fan	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>• Total numbers</li> </ul>	9	10	MR
	<ul style="list-style-type: none"> <li>• Types</li> </ul>	ABC/CO2 ISI marked	Provided	MR
	<ul style="list-style-type: none"> <li>• IS marking</li> </ul>		Provided	MR
6.	First - Aid Hose Reels			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> </ul>	1	Provided	MR
	<ul style="list-style-type: none"> <li>• Length of hose reel hose</li> </ul>	30 Mtr	Provided	MR
	<ul style="list-style-type: none"> <li>• Nozzle diameter</li> </ul>	30 Mtr	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>• Type of detector</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>			
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NR	NP	NR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	NR	NP	NR
	<ul style="list-style-type: none"> <li>• Upper Floor</li> </ul>	NR	NR	NR
	<ul style="list-style-type: none"> <li>• Sprinkler above false ceiling</li> </ul>	NR	NR	NR

11.	Internal Hydrants	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>	150 mm	Provided	MR
			1	Provided	MR
			1	Provided	MR
12.	Yard Hydrants	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>	NR	NR	NR
			NR	NR	NR
13.	Pumping Arrangements	<ul style="list-style-type: none"> <li>• Ground Level</li> <li>• Discharge of main pump</li> <li>➤ Head of main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/Manual stopping</li> <li>➤ Pump House Access</li> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power supply</li> <li>➤ Auto starting of pump</li> </ul>			
			900 lpm	Provided	MR
			40 MTH	Provided	MR
			Required	Provided	MR
			Required	Provided	MR
14.	Captive water Storage for fire fighting	<ul style="list-style-type: none"> <li>• Under ground tank capacity</li> <li>➤ Draw of connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>			
			15,000 lts	Provided	MR

		Required	Provided	MR
15.	Exit Signage			MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft			NR
	➤ Pressurization of lift lobby			
	➤ Communication in lift Car			
	➤ Fireman's Grounding Switch			
	➤ Lift Signage			
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area			NR
	➤ Location			
19.	Fire control room			
	➤ Detector system panel			NA
	➤ Flow Switch Panel			
	➤ PA System Panel			
	➤ Batter backup			
	➤ Building Floor Plans			
20.	Special Fire Protection Systems for Protection of special Risks, if any;		NA	

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/~~issue shortcomings as noted at serial numbers~~

- Note I. Lower Ground Floor is a part of the building and not being used for any other purpose as affidavit attached by owner. This is 3 steps beneath the ground floor.
- II. There are a Hall (at Lower Ground Floor), office (at GF) & Bridal Rooms (at 1st Floor) in this building.
- III. There are 3 exits (doors) of more than 2.00Mtr width in Hall at Lower Ground Floor