

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

No. F6/DFS/MS/FW/2014/M02/591

Dated 30/04/14

FIRE SAFETY CERTIFICATE

Certified that the M/s Parasnath Fireworks Shop (Prop. Sh. Sunil Jain & Chitrang Jain) at ground floor level of the building comprised of ground plus two upper floors of 30/43, Main 60 ft. Road, Gali No.7, Vishwas Nagar, Shahdara, Delhi, owned/occupied by M/s Parasnath Fireworks have complied with the fire prevention and fire safety requirements in accordance with the Delhi Police Act and verified by the officer concerned of this department on dated 15.03.2014 in the presence of Sh. Sunil Jain, and that the shop is fit for occupancy class Fireworks storage (Manufactured Fireworks 300Kg + Chinese/Sparklers 1200 Kg.) with effect from...30.04.14.....for a period of three years, subject to conditions printed overleaf.

Issued on...30/04/14.....at New Delhi by



(Dr.G.C.Misra)  
Chief Fire Officer  
Ph.011-23414333

To,  
The Addl. Commissioner of police (Licensing),  
1<sup>st</sup> Floor, P.S. Defence colony,  
New Delhi.

Copy to:-  
Sh. Sunil Jain  
R/o H.No.1/11829/E-17, Panchsheel Garden,  
Naveen Shahdara, Delhi-32.

o/c  
fr

### CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. All comments/directions of the Licensing Department shall always be permitted and followed
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

N/1

1. Name & address of the building : M/s Parasnath Fireworks at Shop no. 30/43, Main 60 ft Road, Gali no.7, Vishwas Nagar, Shahdara, Delhi,
2. Type of Occupancy : Storage Fireworks
3. Type of Case : New Case
4. Details of Previous NOC : Nil
5. Fire Safety direction letter No : -----
6. Date of Inspection : 15.04.2014
7. Name of the Inspecting Officers : DO Virendra Singh
8. Name of the Person from the Building side : Sh.Sunil Jain (Prop.)
9. Year of Construction : 2005
10. Reference/Licensing deptt. letter no. (PFW/08)/2014/14200-03/Addl.Cp/Lic.(Expl.)

Dated 26.03.2014.

S.NO.	Point of Inspection	Requirement	Provided at Site	MR/NMR
1	Type of construction and floor area & floor level			
	a. Minimum floor area	9m <sup>2</sup> (Min.)	20 m <sup>2</sup>	MR
	b. Construction	Pucca	Provided	MR
	C. Premises Location	Not under the staircase/Means of escape	Provided	MR
		Required	Provided	MR
	d. Business permissible only at ground floor level	prohibited	Yes,	MR
	e. Business from pavement of road prohibited			
2	Entrance & Exits to the licensed premises			
	The licensed premises shall have independent entrance and exit	Required	Provided (Yes)	MR
3	Type and distance of the surrounding risk			
	The premises shall be situated at a distance of 15 m from any such premises used for similar explosives/inflammable or hazardous materials.	Required	Provided (15 mtrs. away)	MR

L

N/2

4	Nature of business run in the licensed premises			
	The premises in which fireworks are kept shall be used only for possession and sale for fireworks and no other purposes.	Required	Provided (yes)	MR
5.	Type of electrical wiring and electrical fittings			
	Preferably concealed or through conduit	Required	Provided	MR
	All electrical fitting should be flame/spark proof	Required	Provided with laid through conduit.	MR
6	Extension of Shop for Business.	Prohibited	Yes	MR
7	Approach Road			
	The road width on the side of which premises is located should be 12m.	12 M	18 M	MR
8	Fire Protection Arrangement.			
	Extinguishers (Type & No's.)	2 nos. water type & 1 no. of ABC or Co2 type	Provided	MR
	Sand and Water Buckets	2 nos. each	Provided	MR
	Water Drum(s)	1 nos.	Provided	MR
9	Any other point that is contrary to the safety of people.		Nil	

The fire protection systems provided in shop were test checked and found functional at the time of inspection. The two upper floors are vacant which has been provided separate staircase.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

  
 21/4/14  
 Signature of the Inspecting Officer