

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110 001.**

E-mail:- [cfohq.dlfire@nic.in](mailto:cfohq.dlfire@nic.in)

Fax:- 011-23412593


No. F.6/DFS/MS/School/2014/52/557

Dated: 02/05/14

**FIRE SAFETY CERTIFICATE**

Certified that the **Ramjas Public School (Day Boarding)** located at Anand Parbat, New Delhi-110005 having three wings namely Primary Wing, Senior Wing and Nursery Wing. Primary & Senior Wing is comprised of ground floor plus two upper floors and Nursery Wing is comprised of ground floor only was issued NOC by this department vide letter No.F.6/DFS/MS/2011/328 dated 18.02.2011. The School building was re-inspected by the officer concerned of this department on 19.04.2014 in the presence of Smt. Sarika Arora (Principal), Sh. Rajinder (Maintenance) and found that the management of Ramjas Foundation have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class educational w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....02/05/14..... at New Delhi.

  
(DR. G.C. MISRA)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE  
Ph:- 011-23414333

Copy to:-

1. The Principal,  
Ramjas Public School (Day Boarding),  
Anand Parbat, New Delhi-110005.
2. Director of Education,  
Govt. of NCT of Delhi, Old Secretariat,  
New Delhi – 110 054.

  
02/05/14

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/ occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

Ground Floor plus two upper floors.

N/3

**INSPECTION REPORT**

- 1. Name & address of the building : Ramjas Public School (Day Boarding), Anand Parbat, N.D-05.
- 2. Type of Occupancy : Educational (School)
- 3. Type of Case : New Case/Renewal
- 4. Details of Previous NOC : Letter No. F.6/DFS/MS/2011/328 Date 18.02.2011
- 5. Fire Safety Directives letter No : \_\_\_\_\_
- 6. Date of inspection : 19.04.2014
- 7. Name of Inspecting Officer : A.D.O P.S. Dahiya
- 8. Name and designation of officers  
From the building side : Smt. Sarika Asora (Principal), Sh. Rajinder Singh
- 9. Year of Construction : 1991, 1996, 2000
- 10. Applicant's letter No. : RDM/ADM/01-2013-14/404 dated 12.02.2014

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks
1.	Access to building			MR/NMR
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	<ul style="list-style-type: none"> <li>Accessible</li> <li>—</li> <li>—</li> </ul>	<ul style="list-style-type: none"> <li>06 mtr</li> <li>380 cms</li> <li>—</li> </ul>	<ul style="list-style-type: none"> <li>MR</li> <li>MR</li> <li>—</li> </ul>
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	<ul style="list-style-type: none"> <li>Four</li> <li>—</li> </ul>	<ul style="list-style-type: none"> <li>Four</li> <li>—</li> </ul>	<ul style="list-style-type: none"> <li>MR</li> <li>No Basement</li> </ul>
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basements</li> </ul>	<ul style="list-style-type: none"> <li>150cms</li> <li>—</li> </ul>	<ul style="list-style-type: none"> <li>150, 132, 150, 132 cms</li> <li>—</li> </ul>	<ul style="list-style-type: none"> <li>MR</li> <li>No Basement</li> </ul>
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• pressurization</li> </ul>	<ul style="list-style-type: none"> <li>—</li> <li>—</li> </ul>	<ul style="list-style-type: none"> <li>—</li> <li>—</li> </ul>	<ul style="list-style-type: none"> <li>—</li> <li>—</li> </ul>
	d. No. of continuous staircases to terrace			
	—		One	—
	e. Width of Corridor			
	—		235 cms, 280 cms	—
	f. Door Size			
	—		109 cms x 204 cms	—
	—		120 cms x 205 cms	—
3.	Compartmentation			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	<ul style="list-style-type: none"> <li>—</li> <li>—</li> <li>—</li> <li>—</li> <li>—</li> </ul>	<ul style="list-style-type: none"> <li>—</li> <li>Sealed</li> <li>—</li> <li>—</li> <li>—</li> </ul>	<ul style="list-style-type: none"> <li>—</li> <li>—</li> <li>—</li> <li>—</li> <li>—</li> </ul>
4.	Smoke Management System			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	<ul style="list-style-type: none"> <li>30 a/c per hour</li> <li>—</li> </ul>	<ul style="list-style-type: none"> <li>—</li> <li>Natural Ventilation</li> </ul>	<ul style="list-style-type: none"> <li>No Basement</li> <li>MR</li> </ul>

N/G

		12 a/c per hour	-	-
5.	Fire Extinguishers			
	• Total numbers	25 Nos	Provided	MR
	• Types	CO <sub>2</sub> , WCO <sub>2</sub> , ABC	- do -	MR
	• IS marking	ISI marked	ISI Marked	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	Four	Provided	MR
	• Length of hose reel hose	30 m	- do -	MR
	• Nozzle diameter	5 mm	- do -	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	-	-	-
	• Location of Main Panel	-	-	-
	• Location of Repeater Panel	-	-	-
	• Alternate source of power	-	D.G. Set of 125 kVA	-
	• Hooters' Location	-	-	-
8.	MOEFA			
		-	-	-
9.	Public Address System			
		-	Provided	MR
10.	Automatic Sprinkler System			
	• Basement	-	-	No Basement
	• Upper Floor	-	-	-
	• Sprinkler above false ceiling	-	-	-
11.	Internal Hydrants			
	• Size of riser/down-comer	-	100 M.M	MR
	• Number of hydrants per floor	-	-	-
	• Hose Box	-	-	-
12.	Yard Hydrants			
	• Total number of hydrants	-	One	-
	• Hose Box	-	- do -	-
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	-	-	-
	➤ Head of Main pump	-	-	-
	➤ Number of main pumps	-	-	-
	➤ Jockey Pump out put	-	-	-
	➤ Jockey pump head	-	-	-
	➤ Standby Pump out put	-	-	-
	➤ Standby Pump Head	-	-	-
	➤ Auto Starting/Manual stopping	-	-	-

N/5 Anand Parbat, New Delhi - 110005.

	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul>	-	-	-
		450 LPM	450 LPM, 180 LPM 450 LPM, 180 LPM	MR (04 Pumps)
		30M Required	30M Each Provided	-do- MR
		-	-	-
<b>14.</b>	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	-	-	-
		-	-	-
		-	-	-
		-	-	-
		10000 Ltr	10000 + 10000 Ltr	MR
<b>15.</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16.</b>	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	-	-	No Lift
		-	-	-do-
		-	-	-do-
		-	-	-do-
		-	-	-do-
<b>17.</b>	<b>Standby power supply</b>	Required	Provided	MR
<b>18.</b>	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	-	-	-
		-	-	-
<b>19.</b>	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>	-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
<b>20.</b>	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	-	-	-

N/B-

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no.

F.6/DFS/MS/2011/328 dated 18.02.2011 renewal under rule 35 of the

Delhi Fire Service rules 2010 is recommended.

Note:- The school building having three wings i.e Primary Wing comprised of G.F + 02 upper floors, Senior Wing Comprised of G.F + 02 upper floors and Nursery Wing at Ground Floor only. The primary wing & senior wing are served by two staircases each having width 150cms & 132cms respectively.



*P. S. Dahiya* 20/4/14

Signature of Inspecting Officer

Name P.S. Dahiya

Designation Asstt. Divisional Officer.

Signature of Inspecting Officer

Name

Designation