

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/Motel/2014/w2/550

Dated: 01/05/2014

FIRE SAFETY CERTIFICATE

Certified that **Sagu Dreamland (Pvt) Ltd Splash water park, Main G T K Road, Ali Pur, Delhi** comprised of **Ground floor only** owned / occupied by **Sh. Sanjeev Verma Manager Sagu Dreamland (P) Ltd** has already been issued fire safety certificate vide Letter **NO F6/DFS/MS/Motel/2011/616 Dated 07/04/2011.** There is no change in the building construction and found complied with the fire prevention and fire safety Requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of fire service on **11/04/2014** in the presence of **Sh. Sanjeev Verma** and that the building / premises is fit for occupancy **under the provisions of Rule 113 of regulation for licensing and controlling places of public Amusement (other than cinema) and performance of public Amusement 1980** with effect from the date of issue of this letter for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

1. All employees shall be acquainted with the use and maintenance of all the fire fighting installation/equipments.
2. The fire suppression / protection arrangements provided are to minimize losses, if maintained in good working condition. These systems cannot give a guarantee that there will be no fire or losses in the event of one.
3. Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the licensee.
4. This report may not in any way be treated as regularization of unauthorized construction, if any. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The trained fire fighting staff should be available round the clock.
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on 01/05 / 05 / 2014 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in

Copy to:

1. Sh Shiv Kumar, Sagu Dreamland (Pvt) Ltd Splash water park, Main G T K Road, Ali Pur, Delhi-110036
2. The Joint Commissioner of Police (Lic), 1st floor, Police station, Defense Colony, New Delhi.

INSPECTION REPORT

Ground Floor Only

1. Name & address of the building : Sagu Dreamland (P) Ltd Splash water park, Ali Pur, Delhi
2. Type of Occupancy : Amusement Park
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/Motel/2011/616 Dated 07/04/2011
5. Fire Safety directives letter No :
6. Date of inspection : 11/04/2014
7. Name of the Inspecting Officers : DO (NW) S. S Tuli
8. Name and designation of officers
from the building side : Sh. Sanjeev Verma
9. Year of Construction : 2003
10. Applicant's letter No. : 1224/3/Joint CP/Lic.(Amst.) dated 12/03/2014

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible	Accessible	M.R
		Accessible	Accessible	M.R
		--	--	--
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	NA	NA	NA
	b. Width of staircases	NA	NA	NA
	<ul style="list-style-type: none"> • Upper Floors • Basements 	NA	NA	NA
	c. Protection of exits	NA	NA	NA
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	NA	NA	NA
	e. No. of continuous staircases to terrace	NA	NA	NA
	g. Width of Corridor	--	--	--
	h. Door Size	--	--	--

3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	NA	NA
5	Fire Extinguishers			
	• Total numbers	One @ 300 m ²	08	M.R
	• Types		ABC	M.R
	• IS marking	ISI marked	yes	M.R
6	First-Aid Hose Reels.			
	• Total numbers on each floor	04	P	M.R
	• Length of hose reel hose	30 m	P	M.R
	• Nozzle diameter	5 mm	P	M.R
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	R	P	M.R
9	Public Address System.	--	--	--
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA

12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	--	--	--
	➤ Head of Main pump	--	--	--
	➤ Number of main pumps	--	--	--
	➤ Jockey Pump out put	--	--	--
	➤ Jockey pump head	--	--	--
	➤ Standby Pump out put	--	--	--
	➤ Standby Pump Head	--	--	--
	➤ Auto Starting/ Manual stopping	--	--	--
	➤ Pump House Access	--	--	--
	• Terrace level			
	➤ Discharge of pump	450 LPM	P	M.R
	➤ Head of the pump	40 m	P	M.R
	➤ Power Supply	--	--	--
	➤ Auto Starting of pump	--	--	--
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	50000 ltr	P	M.R
	➤ Draw-off connection	--	--	--
	➤ Fire service inlet	--	--	--
	➤ Access to tank	--	--	--
	• Overhead Tank capacity	--	--	--
15	Exit Signage.	R	P	M.R
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	R	125 KVA	M.R

18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/DFS/MS/Motel/2011/616 Dated 07/04/2011 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name

Designation

Signature of the Inspecting Officer

Name

Designation

Singh
17/4/14
DO (NW)

