

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**


No.F6/DFS/MS/2014/ 82/555

Dated : 02/05/14

FIRE SAFETY CERTIFICATE

Certified that the **Sirifort Auditorium Complex (Auditorium I,II,III & IV)** located at **August Kranti Marg, New Delhi** comprised of **Basement, Ground & 1st Floor only** was granted NOC by this department vide letter No./F6/DFS/MS/2011/Auditorium/295 dated 15/02/11. The premises was re-inspected by the officer concerned of this department on 15/03/14 in the presence of **Mr. J.S.Pangal (A.E. El.)** and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Assembly Building Group - D** with effect from 02/05/14 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 subject to conditions printed below.

Issued 02/05/14 at New Delhi by.


(Dr. GC Misra)
Chief Fire Officer
Ph. 011-23414333

Copy to:- (1) The Joint Commissioner of Police, (Lic.),
First Floor, PS Defence Colony, New Delhi.

(2) Sirifort Auditorium Complex (Auditorium I,II,III & IV),
August Kranti Marg, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

N/110

INSPECTION REPORT

1. Name & address of the building:- Sirifort Auditorium Complex (Auditorium I,II,III & IV),August Kranti Marg,New Delhi.
2. Type of occupancy:- Assembly Building Group-D.
3. Type of case:- Renewal
4. Details of previous NOC:-No./F6/DFS/MS/2011/Auditorium/295 dated 15/02/11
5. Fire safety directives No.- N/A
6. Date of inspection:- 15/03/14.
7. Name of the inspecting officer:- D.O. D.P. Bharadwaj & A.D.O. S.S. Kaushik
8. Name & designation of officer
From the building side:- Mr. J.S. Pangal (A.E. El.)
9. Year of construction:- 1982
10. Applicant's letter No:-7979-84/Joint.C.P./Lic.dated 14/02/14 Basement ,Ground & 1st floor only

| S.No. | Minimum Standards on fire Prevention and fire safety U/R 33 | NBC /BBL Requirement | Provided at site | Remarks MR/NMR |
|-----------|-------------------------------------------------------------|----------------------|------------------|----------------|
| 1. | Access to Building | | | |
| | 1) Road width | 15 mtr. | Provided | MR |
| | 2) Gate width | 5 mtr. | Provided | MR |
| | 3)Width of internal road | N/A | N/A | N/A |
| 2. | Number, Width Type & Arrangement of Exits | | | |
| | A. Number of staircases | | | |
| | 1. Upper floors | 8 Nos. | 8 Nos. | MR |
| | 2. Basements | 6 Nos. | 6 Nos. | MR |
| | B. Width of staircase | | | |
| | 1. Upper floors | N/A | N/A | N/A |
| | 2. Basements | 1.50 mtr. | 1.50 mtr. each. | MR |
| | C. Protection of exits | | | |
| | 1. Fire check door | Yes | Provided | MR |
| | 2. Pressurization | Yes | Provided | MR |
| | D. No. of continuous staircase to terrace | 2 Nos. | 2 Nos. | MR |
| | E. Width of corridor | N/A | N/A | N/A |
| | F. Door size | 8 Nos. | Provided | MR |
| 3. | Compartmentation | | | |
| | 1) Fire check door | Yes | Provided | MR |
| | 2) Sealing of electrical shafts | Yes | Provided | MR |
| | 3) Fire rating of shaft door | Yes | Provided | MR |
| | 4) Water curtain | N/A | N/A | N/A |
| | 5) Fire Dampers | Yes | Provided | MR |
| 4. | Smoke Management System | | | |
| | 1) Basements | 30 a/c per hour | Exhaust fan | MR |
| | 2) Upper floors | 12 a/c per hour | Exhaust fan | MR |
| 5. | Fire Extinguishers | | | |
| | 1) Total numbers | ISI Marked | 200 Nos. | MR |
| | 2) Types | | ABC & W.Co2 | MR |

S. Kaushik

| | | | | |
|------------|-------------------------------------------------------|-------------------------------------------------------------------------------|-------------------------------------------------------------------------------|-----|
| | 3) ISI marking | | Yes | MR |
| 6. | First-Aid Hose Reel | | | |
| | 1) Total number of each floor | Required | 2 Nos. at basement, 9 Nos. at ground floor & 4 Nos. at 1 st floor. | MR |
| | 2) Length of hose reel hose | 30 m | Yes | MR |
| | 3) Nozzle diameter | 5 mm | Yes | MR |
| 7. | Automatic Fire Detection & Alarming System | | | |
| | 1) Type of detectors | Smoke | Provided | MR |
| | 2) Location of main panel | Ground floor | Yes | MR |
| | 3) Location of repeater panel | N/A | N/A | N/A |
| | 4) Alternate source of power | Yes | Provided | MR |
| | 5) Hooter's Location | at all floors | Provided | MR |
| 8. | MOEFA | Yes | Provided | MR |
| 9. | Public Address System | Required | Provided | MR |
| 10. | Automatic Sprinkler System | | | |
| | 1) Basement | Yes | Provided | MR |
| | 2) Upper floors | Yes | Provided | MR |
| | 3) Sprinkler above false ceiling | Yes | Provided | MR |
| 11. | Internal Hydrants | | | |
| | 1) Size of riser/down-comer | 150 mm. | 150 mm. | MR |
| | 2) Number of hydrants per floor | 2 Nos. at basement, 9 Nos. at ground floor & 4 Nos. at 1 st floor. | 2 Nos. at basement, 9 Nos. at ground floor & 4 Nos. at 1 st floor. | MR |
| | 3) Hose box | -----do----- | -----do----- | MR |
| 12. | Yard Hydrants | | | |
| | 1) Total number of hydrants | 10 Nos. | 10 Nos. | MR |
| | 2) Hose box | 10 Nos. | 10 Nos. | MR |
| 13. | Pumping Arrangement | | | |
| | 1) Ground level | | | |
| | a) Discharge of main pump | 2280 LPM | 2280 LPM | MR |
| | b) Head of main pump | 35 mtr. | 35 mtr. | MR |
| | c) Number of main pump | 2 Nos. | 2 Nos. | MR |
| | d) Jockey pump output | 225 LPM | 225 LPM | MR |
| | e) Jockey pump head | 35 mtr. | 35 mtr. | MR |
| | f) Stand by pump output | 2280 LPM | 2280 LPM | MR |
| | g) Stand by pump head | 35 mtr. | 35 mtr. | MR |
| | h) Auto starting/Manual stopping | Yes | Yes | MR |
| | 2) Terrace level | | | |
| | a) Discharge of pump | N/A | N/A | N/A |
| | b) Head of pump | N/A | N/A | N/A |
| | c) Power supply | N/A | N/A | N/A |
| | d) Auto starting of pump | N/A | N/A | N/A |
| 14. | Captive Water Storage for Fire Fighting | | | |
| | 1) Under ground tank capacity | 75,000 Ltrs. | 1,00,000 ltrs. | MR |

Handwritten signature

N/12

| | | | | |
|-----|---------------------------------|--------------|-------------|-----|
| | a) Draw-off connection | Yes | Provided | MR |
| | b) Fire service inlet | Yes | Provided | MR |
| | c) Access to tank | Yes | Provided | MR |
| | d) Over head tank capacity | 20,000 ltrs. | 20,000 Ltr. | MR |
| 15. | Exit Signage. | Yes | Provided | MR |
| 16. | Provision of Lifts. | | | |
| | a) Pressurization of lift shaft | N/A | N/A | N/A |
| | b) Pressurization of lift lobby | N/A | N/A | N/A |
| | c) Communication in lift car | N/A | N/A | N/A |
| | d) Fireman's switch | N/A | N/A | N/A |

| | | | | |
|-----|-------------------------------------------------------------------------------|-----|----------|-----|
| | e) Lift signage | N/A | N/A | N/A |
| 17. | Stand by Power Supply | Yes | Provided | MR |
| 18. | Refuge Area | N/A | N/A | N/A |
| | Total area location | N/A | N/A | N/A |
| 19. | Fire Control Room | N/A | N/A | N/A |
| | a) Detector system panel | Yes | Provided | MR |
| | b) Flow switch panel | N/A | N/A | N/A |
| | c) PA system panel | Yes | Provided | MR |
| | d) Battery backup | Yes | Provided | MR |
| | e) Building floor plan | Yes | Provided | MR |
| 20. | Special Fire Protection System for Protection of special Risk, if any: | | | N/A |

The fire protection system provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No.F6/DFS/MS/2011/Auditorium/295 dated 15/02/11. renewal under rule35 of the Delhi Fire Service rules 2010 is recommended.

Accordingly DFA is put up please

Signature of the inspecting officer


Signature of the inspecting officer

Name:-D.P. Bharadwaj

Name:- S.S. Kaushik. 23/4

Designation:- Divisional Officer

Designation:- Assistant Divisional Officer



24/4/14

