

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

Fax: 23412593, Tel:- 011-23414333

NO.F6/DFS/MS/EH/2014/ 82/561

Dated: 2/5/14

**FIRE SAFETY CERTIFICATE**

Certified that Suribachi (Additional) Restaurant, (a unit of Royal Eastern Hospitalities Pvt. Ltd) located at T-540, Malviya Nagar, New Delhi-110017, comprised of ground floor was granted FSC by this department vide letter No.F6/DFS/MS/2011/EH/1988 dated 12/08/11 The premises was re- inspected by the officer concerned of this department on 16/04/14 in the presence of Mr. Manoj and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Group – D Assembly Building (Restaurant) with effect from ~~2/5/14~~ for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued ~~2/5/14~~ at New Delhi by.

  
(Dr. G.C. Misra)  
Chief Fire Officer

Copy to:

Mr. Vyom Ghai,  
Suribachi (Additional) Restaurant,  
T-540, Malviya Nagar,  
New Delhi-110017

o/c  
  
11/5/14  
220 (B.L.P.)

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of NBC
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)



**INSPECTION REPORT**

1. Name & address of the building:- Suribachi (Additional), T-540, Malviya Nagar, New Delhi-110017
2. Type of occupancy:- Assembly, Group – D, Restaurant
3. Type of case:- Renewal
4. Details of previous NOC:- F6/DFS/MS/2011/EH/1988 dated-12/08/2011
5. Fire safety directives No.- Nil
6. Date of inspection:-16/04/2014
7. Name of the inspecting officer:- D.B.Mukherjee, A.D.O.(BCP)
8. Name & designation of officer From the building side:- Mr. Manoj (Manager)
9. Year of construction:- 1994
10. Applicant's letter no:- Nil Dated: 08/03/2014

Building is comprised of Ground Floor Only. The restaurant is running in two sections under one roof.

| S.No. | Minimum Standards on fire Prevention and fire safety U/R 33 | Requirement NBC | Provided at site                                     | Remarks MR/NMR |
|-------|---|-----------------|--|----------------|
| 1.    | <b>Access to Building</b>                                   |                 |  |                |
|       | 1) Road width   | 09 m            | 15m Provided   | MR             |
|       | 2) Gate width   | N/A             | N/A  | N/A            |
|       | 3) Width of internal road                                   | N/A             | N/A  | N/A            |
| 2.    | <b>Number, Width Type &amp; Arrangement of Exits</b>        |                 |  |                |
|       | A. Number of staircases                                     |                 |  |                |
|       | 1. Upper floors   | N/A             | N/A  | N/A            |
|       | 2. Basements  | N/A             | N/A  | N/A            |
|       | B. Width of staircase                                       |                 |  |                |
|       | 1. Upper floors   | N/A             | N/A  | N/A            |
|       | 2. Basements  | N/A             | N/A  | N/A            |
|       | C. Protection of exits                                      |                 |  |                |
|       | 1. Fire check door  | N/A             | N/A  | N/A            |
|       | 2. Pressurization   | N/A             | N/A  | N/A            |
|       | D. No. of continuous staircase to terrace                   | N/A             | N/A  | N/A            |
|       | E. Width of corridor  | N/A             | N/A  | N/A            |
|       | F. Door size  | Old Case        | 1.06m, 1.40m, 0.74m, 0.81m, 1.08m, 0.81m, 1m & 0.74m | MR (Old Case)  |
| 3.    | <b>Compartmentation</b>                                     |                 |  |                |
|       | 1) Fire check door  | N/A             | N/A  | N/A            |
|       | 2) Sealing of electrical shafts                             | N/A             | N/A  | N/A            |
|       | 3) Fire rating of shaft door                                | N/A             | N/A  | N/A            |
|       | 4) Water curtain  | N/A             | N/A  | N/A            |
|       | 5) Fire Dampers   | N/A             | N/A  | N/A            |
| 4.    | <b>Smoke Management System</b>                              |                 |  |                |
|       | 1) Basements  | 30 a/c per hour | N/A  | N/A            |
|       | 2) Upper floors   | 12 a/c per hour | N/A  | N/A            |
| 5.    | <b>Fire Extinguishers</b>                                   |                 |  |                |
|       | 1) Total numbers  | ISI Marked      | 30Nos.   | MR             |
|       | 2) Types  |                 | ABC, Co2   | MR             |
|       | 3) ISI marking  |                 | Yes  | MR             |
| 6.    | <b>First-Aid Hose Reel</b>                                  |                 |  |                |
|       | 1) Total number of each floor                               | Required        | Provided   | MR             |
|       | 2) Length of hose reel hose                                 | 30 m            | Provided   | MR             |
|       | 3) Nozzle diameter  | 5 mm            | Provided   | MR             |



|            |   |          |                 |     |
|------------|---|----------|-----------------|-----|
| <b>7.</b>  | <b>Automatic Fire Detection &amp; Alarming System</b> |          |                 |     |
|            | 1) Type of detectors                                  | N/A      | N/A             | N/A |
|            | 2) Location of main panel                             | N/A      | N/A             | N/A |
|            | 3) Location of repeater panel                         | N/A      | N/A             | N/A |
|            | 4) Alternate source of power                          | Required | 320,160,160 KVA | MR  |
|            | 5) Hooter's Location                                  | N/A      | N/A             | N/A |
| <b>8.</b>  | <b>MOEFA</b>  | Required | Provided        | MR  |
| <b>9.</b>  | <b>Public Address System</b>                          | N/A      | N/A             | N/A |
| <b>10.</b> | <b>Automatic Sprinkler System</b>                     |          |                 |     |
|            | 1) Basement   | N/A      | N/A             | N/A |
|            | 2) Upper floors                                       | N/A      | N/A             | N/A |
|            | 3) Sprinkler above false ceiling                      | N/A      | N/A             | N/A |
| <b>11.</b> | <b>Internal Hydrants</b>                              |          |                 |     |
|            | 1) Size of riser/down-comer                           | 100 mm   | Provided        | MR  |
|            | 2) Number of hydrants per floor                       | 01       | Provided        | MR  |
|            | 3) Hose box   | 01       | Provided        | MR  |
| <b>12.</b> | <b>Yard Hydrants</b>                                  |          |                 |     |
|            | 1) Total number of hydrants                           | N/A      | N/A             | N/A |
|            | 2) Hose box   | N/A      | N/A             | N/A |
| <b>13.</b> | <b>Pumping Arrangement</b>                            |          |                 |     |
|            | 1) Ground level                                       | N/A      | N/A             | N/A |
|            | a) Discharge of main pump                             | N/A      | N/A             | N/A |
|            | b) Head of main pump                                  | N/A      | N/A             | N/A |
|            | c) Number of main pump                                | N/A      | N/A             | N/A |
|            | d) Jockey pump out put                                | N/A      | N/A             | N/A |
|            | e) Jockey pump head                                   | N/A      | N/A             | N/A |
|            | f) Stand by pump output                               | N/A      | N/A             | N/A |
|            | g) Stand by pump head                                 | N/A      | N/A             | N/A |
|            | h) Auto starting/Manual stopping                      | N/A      | N/A             | N/A |
|            | 2) Terrace level                                      |          |                 |     |
|            | a) Discharge of pump                                  | Required | 600 & 840 LPM   | MR  |
|            | b) Head of pump                                       | Required | 26m & 23.5 m    | MR  |
|            | c) Power supply                                       | Required | Provided        | MR  |
|            | d) Auto starting of pump                              | Required | Provided        | MR  |
| <b>14.</b> | <b>Captive Water Storage for Fire Fighting</b>        |          |                 |     |
|            | 1) Under ground tank capacity                         | N/A      | N/A             | N/A |
|            | a) Draw-off connection                                | N/A      | N/A             | N/A |
|            | b) Fire service inlet                                 | N/A      | N/A             | N/A |
|            | c) Access to tank                                     | N/A      | N/A             | N/A |
|            | d) Over head tank capacity                            | Required | 5,000 Ltrs      | MR  |
| <b>15.</b> | <b>Exit Signage.</b>                                  | Required | Provided        | MR  |
| <b>16.</b> | <b>Provision of Lifts.</b>                            |          |                 |     |
|            | a) Pressurization of lift shaft                       | N/A      | N/A             | N/A |
|            | b) Pressurization of lift lobby                       | N/A      | N/A             | N/A |
|            | c) Communication in lift car                          | N/A      | N/A             | N/A |
|            | d) Fireman's switch                                   | N/A      | N/A             | N/A |
|            | e) Lift signage                                       | N/A      | N/A             | N/A |
| <b>17.</b> | <b>Stand by Power Supply</b>                          | Required | Provided        | MR  |
| <b>18.</b> | <b>Refuge Area</b>                                    |          |                 |     |
|            | Total area  | N/A      | N/A             | N/A |
|            | location  | N/A      | N/A             | N/A |





219


|     |   |     |     |     |
|-----|---|-----|-----|-----|
| 19. | <b>Fire Control Room</b>  |     |     |     |
|     | a) Detector system panel  | N/A | N/A | N/A |
|     | b) Flow switch panel  | N/A | N/A | N/A |
|     | c) PA system panel  | N/A | N/A | N/A |
|     | d) Battery backup   | N/A | N/A | N/A |
|     | e) Building floor plan  | N/A | N/A | N/A |
| 20. | <b>Special Fire Protection System for Protection of special Risk, if any:</b> |     |     | N/A |

The fire protection system provided in the building were checked and found functional at the time of inspection.

In view of the compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F6/DFS/MS/2011/EH/1988 dated 12/08/2011, renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended. Accordingly DFA is put up for signature please.

Accordingly DFA is put up please.

Signature of the inspecting officer



Name :- D.B. Mukherjee.  
Designation :- Assistant Divisional Officer.