

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/school/2014/W2/546

Dated: 01/05/2014

FIRE SAFETY CERTIFICATE

Certified that the Joseph & Mary Public School, Nathu pura, Road, Burari, Delhi-110084 comprised of Basement + Ground + Two upper Floor owned / occupied by Joseph & Mary Public School has already been issued fire safety certificate vide letter no. F-6/DFS/MS/2007/2632 dated 20/09/2007 have complied with the fire prevention and fire safety requirements in accordance with Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 07/04/2014 in the presence of Sh. Jagat Thakur (Chairman) and that the building / premises is fit for occupancy of Educational building with effect from 01/05/2014 for a period of three years, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 01/05/14 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in

Copy to:

1. The Principal, Joseph & Mary Public School, Nathu pura, Road, Burari, Delhi-110084.
2. The Director of Education, Old Secretariat, Delhi.

NC-11

Previous - B + G₂ + one floor
 Present - B + G₂ + Two floors

INSPECTION REPORT

1. Name & address of the building: Joseph & Mary Public School, Nathu Pura, Meerut
2. Type of Occupancy: Educational Burari - Delhi - 84
3. Type of Case: New Case / Renewal
4. Details of previous NOC: F-6/PI-S/MS/2007/2639 dt 20.9.07
(for B + G₂ + one floor)
5. Fire Safety directives letter No: Dur: g edu
6. Date of inspection: 7-4-14
7. Name of the Inspecting Officers: ADD (BWS)
8. Name and designation of officers from the building side: Sh Jagat Thakur, Chairman
9. Year of Construction: 1997 & 2013
10. Applicant's letter No: Ref No - J.M.P.S./L.R./2014/601 dt 14.3.14

Plot area: 12140 m² Covered area: 9330 m² No.'s of students: 2800 No.'s of classrooms: 71
7 for other purpose

	Minimum Standards on fire prevention and fire safety U/R 33	Circular Dir. of Edu Requirement/ NBC	Provided at site	Remark MR/NM
1	Access to building			
	• Road width	Accessable	Accessable	MR ✓
	• Gate width	-do-	-do-	MR ✓
	• Width of internal road	-do-	-do-	MR ✓
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	4	4	MR ✓
	• Basements	2	2	MR ✓
	b. Width of staircases			
	• Upper Floors	1.5 mtr each	1.5 mtr each	MR ✓
	• Basements	1.5 mtr	1.50 mtr	MR ✓
	c. Protection of exits			
	• Fire check door	-	-	-
	• Pressurization	-	-	-
	e. No. of continuous staircases to terrace	R	P	MR ✓
	g. Width of Corridor	-	-	-
	h. Door Size	1 mtr	1 mtr	MR ✓

N-12

M

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NR	Basement s/c open to sky	MR
		—	—	—
		—	—	—
		—	—	—
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	Exhaust fan provided	MR ✓
			—	—
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	one @ 300 m ² ISI marked	40 ABC yes	MR ✓ MR ✓ MR ✓
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	3 30 m 5 mm	3 P P	MR ✓ MR ✓ MR ✓
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 			
			N/A	
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	R — —	P — —	MR ✓ — —
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 			
			N/A	

12	Yard Hydrants.	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A		
13	Pumping Arrangements.	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	<p>N/A</p> <p>900 LPM</p> <p>40 M</p> <p>—</p> <p>R</p>	<p>N/A</p> <p>900 LPM</p> <p>40 M</p> <p>—</p> <p>P</p>	<p>MR ✓</p> <p>MR ✓</p> <p>—</p> <p>MR ✓</p>
14	Captive Water Storage for fire fighting.	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	<p>N/A</p> <p>15,000 lts</p> <p>R</p>	<p>N/A</p> <p>P</p> <p>P</p>	<p>MR ✓</p> <p>MR ✓</p>
15	Exit Signage.				MR ✓
16	Provision of Lifts.	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	<p>N/A</p>	<p>N/A</p>	<p>MR ✓</p>
17	Standby power supply				

4-14

18	Refuge Area.			
	➤ Total Area			
	➤ Location			
19	Fire Control Room			
	• Detector System Panel			
	• Flow Switch Panel			
	• PA System Panel			
	• Batter backup			
	• Building Floor Plans			
20	Special Fire Protection Systems for Protection of special Risks, if any:			

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F-6/DFS/43/2007/2639 Dated. 20/09/07... Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name

Designation

[Handwritten Signature]

Signature of the Inspecting Officer

Name

Designation

[Handwritten Signature]
20/4/14
400(BW)