

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001
Fax : 011-23412593 E-mail : cfohq.dlfire@nic.in Ph. 011-23414333.


No.F6/DFS/MS/2014/ 52/575

Dated : 08/05/14

FIRE SAFETY CERTIFICATE

Certified that the **Chinmaya Mission Auditorium** located at **89, Lodhi Estate, New Delhi** comprised of **Basement, Ground + 2 upper Floors** but the auditorium is **running on 1st floor** was granted NOC by this department vide letter No./F6/DFS/MS/2011/1391 dated **01/07/11**. The premises was re-inspected by the officer concerned of this department on **24/04/14** in the presence of **Mr. S.C. Vohra Col. (Retd.)** and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Assembly Building Group - D** with effect from 08/05/14 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 subject to conditions printed below.

Issued 08/05/14 at New Delhi by.


(Dr. G.C. Misra)
Chief Fire Officer
Delhi Fire Service

Copy to:- (1) The Joint Commissioner of Police, (Lic.),
First Floor, PS Defence Colony, New Delhi.

(2) Chinmaya Mission Auditorium,
89, Lodhi Estate, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire-fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

- N/28 -

INSPECTION REPORT

1. Name & address of the building:- Chinmaya Mission Auditorium, 89, Lodhi Estate, New Delhi.
2. Type of occupancy:- Assembly Building Group-D.
3. Type of case:- Renewal
4. Details of previous NOC:- No./F6/DFS/MS/2011/1391 dated 01/07/11
5. Fire safety directives No.- N/A
6. Date of inspection:- 24/04/14.
7. Name of the inspecting officer:- A.D.O. S.S. Kaushik
8. Name & designation of officer
From the building side:- Mr. S.C. Vohra (Col. Retd.).
9. Year of construction:- 1996.
10. Applicant's letter No:- 2970/Joint.C.P./Lic. dated 21/02/14 Basement, Ground + 2 upper floor but auditorium is running on 1st floor

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC /BBL Requirement	Provided at site	Remarks MR/NMR
	Old case			
1.	Access to Building			
	1) Road width	15 mtr.	Provided	MR
	2) Gate width	5 mtr.	Provided	MR
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	3 Nos.	3 Nos.	MR
	2. Basements	2 Nos.	2 Nos.	MR
	B. Width of staircase			
	1. Upper floors	1.50 mtr.	2.40 mtr. , 1.80 mtr. & 1.50 mtr.	MR
	2. Basements	1.50 mtr.	2.40 mtr. & 1.80 mtr.	MR
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	1 Nos.	1 Nos.	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	3 Nos.	Provided	MR
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	Exhaust fan	MR
	2) Upper floors	12 a/c per hour	Exhaust fan	MR



5.	Fire Extinguishers			
	1) Total numbers	ISI Marked	12 Nos.	MR
	2) Types		ABC & W.Co2	MR
	3) ISI marking		Yes	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	Required	1 Nos. at each floor..	MR
	2) Length of hose reel hose	30 m	Yes	MR
	3) Nozzle diameter	5 mm	Yes	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Yes	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Yes	Provided	MR
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	150 mm.	150 mm.	MR
	2) Number of hydrants per floor	1 Nos.	1 Nos.	MR
	3) Hose box	1 Nos.	1 Nos.	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	900 LPM & 180 LPM	MR	MR
	b) Head of pump	40 mtr.	40 mtr.	MR
	c) Power supply	Yes	Provided	MR
	d) Auto starting of pump	Yes	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	Yes	Provided	MR

M. Anshu

	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	10,000 ltrs.	10,000 Ltr.	MR
15.	Exit Signage.	Yes	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A

	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Yes	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NCC issued vide letter No.F6/DFS/MS/2011/ 1391 dated 01/07/11. renewal under rule35 of the Delhi Fire Service rules 2010 is recommended.

Accordingly DFA is put up please

Signature of the inspecting officer

Signature of the inspecting officer

Name:-

Name:- S.S. Kaushik.

Designation:-

Designation:- Assistant Divisional Officer

DD Senath

S.S. Kaushik

S.S. Kaushik
24/4/14