

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. f6/DFS/ms/2014/W2/566

Dated: 07/05/2014

FIRE SAFETY CERTIFICATE

Certified that the M/S A. H Sons, D-38, Sector -3, Bawana Ind. Area, Delhi 110039, located on G.F of premises comprised of Basement + Ground + One floor owned/occupied by M/S A. H Sons have complied with the fire prevention and fire safety requirement in accordance with rule 33 of the Delhi Fire Service Rules, 2010, and verified by the officer concerned of Fire Service on 17/04/2014 in the presence of Sh. Kishore Bhambhani and that the building /premises is fit for occupancy Industrial G-2 (ii) building with effect from 07/05/2014 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able by guests in an event of emergency.
2. All employees shall be acquainted with the use and maintenance of all the fire fighting installation/equipments.
3. The fire suppression / protection arrangements provided in the guest house are to minimize losses, if maintained in good working condition. These systems cannot give any guarantee that there will be no fire or losses in the event of one.
4. Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the licensee.
5. This report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on.....07/05/14.....at New Delhi.


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dfire@nic.in

Copy to:-

1. M/S A. H Sons, D-38, Sector -3, Bawana Ind. Area, Delhi 110039.
2. The Assistant Drugs Controller & Licensing Authority, Govt. of NCT of Delhi, F-17, Karkardooma, New Delhi-110032



N-1

B + Gk + one

INSPECTION REPORT

1. Name & address of the building: M/S A.H. SONA, D-38, Sec-3, D.S.I.D.C. BAWANA DELHI-39.
2. Type of Occupancy: Industrial G-2(ii)
3. Type of Case: New Case / Renewal (FSC required for G.s. floor only)
4. Details of previous NOC: NIL
5. Fire Safety directives letter No: N.B.C Part (iv)
6. Date of inspection: 17.4.13
7. Name of the Inspecting Officers: ADD (BWS)
8. Name and designation of officers from the building side: Sh. Kishor Bhamhani, manager
9. Year of Construction: 2012
10. Applicant's letter No.: lt. No. Nil dt. 7.4.13

Plot Area - 150 m²

Covered Area 905 m²

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	<u>Accessible</u>	<u>Accessible</u>	<u>MR</u>
	• Gate width	<u>—</u>	<u>—</u>	<u>—</u>
	• Width of internal road	<u>—</u>	<u>—</u>	<u>—</u>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	<u>FSC for G.s. floor only</u>		<u>—</u>
	• Upper Floors	<u>NR</u>	<u>1</u>	<u>—</u>
	• Basements	<u>NR</u>	<u>2</u>	<u>—</u>
	b. Width of staircases			
	• Upper Floors	<u>—</u>	<u>1.22 m²</u>	<u>—</u>
	• Basements	<u>—</u>	<u>1.00 & 1.22 m²</u>	<u>—</u>
	c. Protection of exits			
	• Fire check door	<u>—</u>	<u>—</u>	<u>—</u>
	• Pressurization	<u>—</u>	<u>—</u>	<u>—</u>
	e. No. of continuous staircases to terrace	<u>—</u>	<u>—</u>	<u>—</u>
	g. Width of Corridor	<u>—</u>	<u>—</u>	<u>—</u>
	h. Door Size	<u>Two 1 m² each.</u>	<u>(i) 1.2 m² (ii) 3-6 m² shutters</u>	<u>MR</u>
3	Compartmentation.			
	• Fire check door	<u>—</u>	<u>—</u>	<u>—</u>

	<ul style="list-style-type: none"> Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 				
4	Smoke Management System.				
	<ul style="list-style-type: none"> Basements Upper floors 	30 a/c per hour 12 a/c per hour			
5	Fire Extinguishers				
	<ul style="list-style-type: none"> Total numbers Types IS marking 	G ABC ISI marked	6 ABC yes	MR MR MR	/
6	First-Aid Hose Reels.				
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	one 30 m 5 mm	P P P	MR MR MR	/
7	Automatic fire detection and alarming system.				
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 				
8	MOEFA				
9	Public Address System.				
10	Automatic Sprinkler System.				
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	R R —	P P —	MR MR —	/
11	Internal Hydrants				
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 				
12	Yard Hydrants.				
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 				

13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pum 	<p style="text-align: center; color: blue;">N/A</p>		<p style="text-align: center; color: blue;">N/A</p>
		900 LPM	P	MR ✓
		40 M	P	MR ✓
		—	—	—
		—	—	—
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	<p style="text-align: center; color: blue;">—</p>	<p style="text-align: center; color: blue;">—</p>	<p style="text-align: center; color: blue;">—</p>
		10,000 lts	P	MR ✓
15	Exit Signage.			
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	<p style="text-align: center; color: blue;">N/A</p>		<p style="text-align: center; color: blue;">N/A</p>
17	Standby power supply			
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 			
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel 			

14-10

	<ul style="list-style-type: none"> • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 			
20	Special Fire Protection Systems for Protection of special Risks, if any:			

N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....N.I.L.....

Signature of the Inspecting Officer

Name

Designation

DO (NW)

Signature of the Inspecting Officer

Name

Designation

Signature
21/4/19
ASO (BWS)

