

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F6/DFS/MS/School/2014/02/588

Dated: 09/05/2014

FIRE SAFETY CERTIFICATE

Certified that **Bhagat International School, Kh. no-26/8, Mohd. Pur Majri, (Rama Vihar) Delhi-110081** comprised of **Ground floor** owned/occupied by **Bhagat International School** has already been issued fire safety certificate vide letter no. **F.6/DFS/MS/2010/723 dated 11/06/2010**. The premises was re-inspected by the officer from this department on dated **15/04/2014** in the presence of **Sh. Manoj (Manager)** and observed that the school now comprised of ground + one upper floor. All the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with the requirements of **Circular issued by Director of Education letter dated 17/01/2005** and the building / premise is fit for occupancy of **Group Class B (Educational)** with effect from 09/05/2014 for a period of **three years**, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on 09/05/14 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in

Copy to:

1. The Principal, Bhagat International School, Kh. no-26/8, Mohd. Pur Majri, (Rama Vihar) Delhi-110081
2. The Director of Education, Old Secretariat, Delhi



N-3

Earlier - Gr. + floor only
Present - Gr. + one floorINSPECTION REPORT

1. Name & address of the building: Bhagat International School Majri (Rama Vihar)
 2. Type of Occupancy : Educational Dechi-81
 3. Type of Case : New Case/ Renewal
 4. Details of previous NOC : Dt No. F-6/DFS/MS/2010/723 dt. 11-6-2010
 5. Fire Safety directives letter No : Dir. of Education
 6. Date of inspection : 15-4-14
 7. Name of the Inspecting Officers : APD (BWS)
 8. Name and designation of officers
 from the building side : Sh. Manoj - Manager
 9. Year of Construction : 2006 + 2011
 10. Applicant's letter No. : Dt No. Nil dt. 13.5.14

Plot area:-

Covered area:-

No.'s of students:-

No's of classrooms:-

	Minimum Standards on fire prevention and fire safety U/R 33	Circular Dir. of Edu Requirement/ NBC	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	<u>Accessable</u>	<u>Accessable</u>	<u>MIR</u>
	• Gate width	<u>Accessable</u>	<u>Accessable</u>	<u>MIR</u>
	• Width of internal road	<u>—</u>	<u>—</u>	<u>—</u>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	<u>—</u>	<u>—</u>	<u>—</u>
	• Upper Floors	<u>2</u>	<u>2</u>	<u>MIR</u>
	• Basements	<u>—</u>	<u>—</u>	<u>—</u>
	b. Width of staircases	<u>—</u>	<u>—</u>	<u>—</u>
	• Upper Floors	<u>1.50 mtr</u>	<u>1.70 + 1.50 mtr</u>	<u>MIR</u>
	• Basements	<u>—</u>	<u>—</u>	<u>—</u>
	c. Protection of exits	<u>—</u>	<u>—</u>	<u>—</u>
	• Fire check door	<u>—</u>	<u>—</u>	<u>—</u>
	• Pressurization	<u>—</u>	<u>—</u>	<u>—</u>
	e. No. of continuous staircases to terrace	<u>—</u>	<u>—</u>	<u>—</u>
	g. Width of Corridor	<u>—</u>	<u>—</u>	<u>—</u>
	h. Door Size	<u>1 mtr</u>	<u>1 mtr</u>	<u>MIR</u>

H-4

	<ul style="list-style-type: none"> Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 								
4	Smoke Management System.								
	<ul style="list-style-type: none"> Basements Upper floors 	30 a/c per hour							
		12 a/c per hour							
5	Fire Extinguishers								
	<ul style="list-style-type: none"> Total numbers Types ISI marking 	9 ABC ISI marked	9 ABC 900	MR ✓ MR ✓ MR ✓					
6	First-Aid Hose Reels.								
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	30 m 5 mm							
7	Automatic fire detection and alarming system.								
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 								
8	MOEFA								
9	Public Address System.								
10	Automatic Sprinkler System.								
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 								
11	Internal Hydrants								
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 								
12	Yard Hydrants.								
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 								

12	Yard Hydrants.			
	<ul style="list-style-type: none">• Total number of hydrants• Hose Box			
13	Pumping Arrangements.			
	<ul style="list-style-type: none">• Ground Level<ul style="list-style-type: none">➤ Discharge of main Pump➤ Head of Main pump➤ Number of main pumps➤ Jockey Pump out put➤ Jockey pump head➤ Standby Pump out put➤ Standby Pump Head➤ Auto Starting/ Manual stopping➤ Pump House Access• Terrace level<ul style="list-style-type: none">➤ Discharge of pump➤ Head of the pump➤ Power Supply➤ Auto Starting of pum			
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none">• Underground tank capacity<ul style="list-style-type: none">➤ Draw-off connection➤ Fire service inlet➤ Access to tank• Overhead Tank capacity			
15	Exit Signage.			
16	Provision of Lifts.			
	<ul style="list-style-type: none">• Pressurization of Lift Shaft• Pressurization of Lift lobby• Communication In lift Car• Fireman's Grounding Switch• Lift Signage			
17	Standby power supply			

18-6

18	Refuge Area.			
	➤ Total Area			
	➤ Location			
19	Fire Control Room			
	• Detector System Panel			
	• Flow Switch Panel			
	• PA System Panel			
	• Batter backup			
	• Building Floor Plans			
20	Special Fire Protection Systems for Protection of special Risks, if any:			

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F-6/APS/MS/2010/723 Dated...11/06/2010 Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.



Signature of the Inspecting Officer

Name

Designation

[Handwritten signature]

Signature of the Inspecting Officer

Name

Designation

[Handwritten signature]
23/4/14
ADD (B/W)