

NO.F6/DFS/MS/EH/2014/SZ/ 593

DATED: 08/05/14

FIRE SAFETY CERTIFICATE

Certified that the M/s Swagat Restaurant at Plot No. C-8, Malviya Nagar, New Delhi 110017 is running at the ground floor of a building comprised of basement, ground plus three upper floors was granted NOC by this department vide letter No. F6/DFS/MS/EH/2011/22 dated 06.01.2011. The premises was re-inspected by the officer concerned of Delhi Fire Service on 23.4.2014 in the presence of Sh. Annappa (Manager) of the restaurant and observed that fire safety norms as required under Rule 33 of Delhi Fire Service Rules, 2010 have deemed complied and that the building / premises is fit for occupancy class-D "Assembly building Restaurant" with effect from 08/05/14 for a period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010..

Issued on ...08/05/14..... at New Delhi by


(Dr. G.C. Misra)
Chief Fire Officer
Delhi Fire Service
(011-23414333)

Copy To:-

1. The DHO (South Zone), Office of Deputy Health Officer, M.C.D. Public Health Department, Green Park, New Delhi
2. The Manager, M/s Swagat Restaurant at Plot No. C-8, Malviya Nagar, New Delhi 110017

Conditions for the validity of fire safety certificate

1. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye laws.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules-2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

M/s Swagat Restaurant at Plot No. C-8, Malivya Nagar, New Delhi 110017

1	Name & address of the building	M/s Swagat Restaurant at Plot No. C-8, Malivya Nagar, New Delhi 110017		
2	Type of Occupancy	Assembly Building "D" Restauant		
3	Type of case	Renewal		
4	Details of previous NOC	F6/DFS/MS/EH/2011/22 Dated 06.01.2011		
5	Fire safety directives letter No	Nil		
6	Date of inspection	23.04.2014		
7	Name of the inspecting Officers :	D.O. (South) D.P. Bhardwaj , ADO D.B. Mukherjee		
8	Name and designation of officers from the building side	Sh. Annapa (Manager),		
9	Year of construction	Nil	01.02.2014	(Resturant running at ground floor)
10	Applicant's letter No.	Nil	01.02.2014	(Resturant running at ground floor)
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR

1	Access to building	Required	10 Mtr Provided	MR
	1) Road width	N/A	N/A	N/A
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A

2	Number, width Type & arrangement of exits			
	a. Number of staircases	N/A	N/A	N/A
	1. Upper floors	N/A	N/A	N/A
	2. basements			
	b. Width of staircase	N/A	N/A	N/A
	1. Upper floors	N/A	N/A	N/A
	2. basements			
	c. Protection of exits	N/A	N/A	N/A
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrac	N/A	N/A	N/A
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	N/A	N/A	N/A
		Tow Exit	1.04, 0.68 Mtrs Provided	MR

3	Compartmentation.	N/A	N/A	N/A
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A

4	Smoke Management system.	30 a/c per hour	N/A	N/A
	basement	12 a/c per hour	Provided	MR
	upper floors			

5	Fire Extinguishers		6 Nos	MR
	total numbers		ABC, Water Co2	MR
	Types		Yes	MR
	ISI marking	ISI		

6	First-Aid Hose Reels.	One	Provided	MR
	total numbers on each floor	30 Mtrs	Provided	MR
	Length of Hose reel hose	5MM	Provided	MR
	Nozzle Diameter			


7	Automatic fire detection and alarming system:-			
	Type of detectors	N/A	N/A	MR
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	Required	Provided (Ground)	MR
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	100 MM	Provided	MR
	Number of Hydrants per floor	One	Provided	MR
	hose Box	One	Provided	MR
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	450 & 180 LPM	Provided	MR
	b. head of the pump	35 Mtr	Provided	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	5000 Ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

		Required	Provided	MR
18	Standby power supply			
	Refuge Area.			
	total area	N/A	N/A	N/A
	location	N/A	N/A	N/A
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: N/A			

The fire protection systems provided in the building were checked and found functional at the time of inspection.


In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules of NOC issued vide letter no. **F6/DFS/MS/EH/2011/22 Dated 06.01.2011** renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Accordingly DFA is put up for your approval and signature please.



11/5/14

Signature of the Inspecting Officer
 Name D.P. BHARDWAJ
 Designation:- D.O. (South)



28/4/14

Signature of the Inspecting Officer
 Name D.B. Mukherjee
 Designation:- A.D.O. (BCP)