

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. FG/DFS/MS/EH/2014/W2/578

Dated: 08/05/2014


FIRE SAFETY CERTIFICATE

Certified that the **M/s Survaie (a unit of Holy Shrine Hotels Pvt. Ltd.)** at 2/85, first floor, Punjabi Bagh Club Road, Delhi-110026, comprised of ground + two upper floors owned/occupied by **M/s Survaie (a unit of Holy Shrine Hotels Pvt. Ltd.)** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on **25.04.2014** in the presence of **Mr. Navneet Gupta** and that the building/premises is fit for occupancy **Assembly** with effect from 08/05/14..... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Following fire safety directives must be adhered to:-

- 1) All the means of escape shall be kept free of all type of obstruction all the time.
- 2) All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
- 3) All the fire fighting equipment shall be maintained in perfect working condition all the time and lapse rendering non-functional of fire safety measures, management shall be responsible.
- 4) Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
- 5) Basement shall be used as per NBC.
- 6) This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

Issued on 08/05/14.....at New Delhi by

  
Santokh Singh  
Chief Fire Officer  
Delhi Fire Service

E-mail :

Phone : 011-23414250

Copy to:

1. M/s Survaie (a unit of Holy Shrine Hotels Pvt. Ltd.) at 2/85, first floor, Punjabi Bagh Club Road, Delhi-110026
2. Dy. Health Officer West Zone, Vishal Enclave, New Delhi

N-I

Name & address of the building : **M/s Survaie (a unit of Holy Shrine Hotels Pvt. Ltd.)** at 2/85, first floor, Punjabi Bagh Club Road, Delhi-110026

Type of Occupancy : Assembly

Type of Case : New

Details of previous NOC : N.A

Fire Safety directives letter No. : N.A.

Date of inspection : 25.04.2014

Name of the Inspecting Officers : Divisional Officer Sunil Chawdhary

Name and designation of officers from the building side : Mr. Navneet Gupta

Year of Construction :

Applicant's letter No. : 535/DHO/WZ/2014

**INSPECTION REPORT**

wise fire safety arrangements/equipments are mentioned as under:-

Minimum Standards on fire Prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
<b>Access to building</b>			
• Road width	12 mtr	Provided	M.R.
• Gate width	N.R.	N.R.	N.R.
• Width of internal road	N.R.	N.R.	N.R.
<b>Number, Width, Type &amp; Arrangement of Exits</b>			
<b>a. Number of staircases</b>			
• Upper Floors	2	2 staircase Provided up to 1 <sup>st</sup> floor for restaurant	M.R.
• Basement	2	2	M.R.
<b>b. Width of staircases</b>			
• Upper Floors	1.5 & 1.25 mtr	Provided	M.R.
• Basement	1.5 mtr	Provided	M.R.
<b>c. Protection of exits</b>			
• Fire check door	N.R.	N.R.	N.R.

• Pressurization	N.R.	N.R.	N.R.
d. No. of continuous staircases to terrace	One	Provided	M.R.
e. Width of corridor	N.A	N.A (Hall only)	N.A.
f. Door size	2 mtr	Provided	M.R.

**Compartmentation.**

• Fire check door	N.R.	N.R.	N.R.
• Sealing of electrical shafts	N.A.	N.A.	N.A.
• Fire Rating of shaft door	N.R.	N.R.	N.R.
• Water Curtain	N.R.	N.R.	N.R.
• Fire Dampers	N.R.	N.R.	N.R.

**Smoke Management System.**

• Basements	Required	Provided	M.R.
• Upper floors	Required	Provided	M.R.

**Fire Extinguishers**

• Total numbers	04	06	M.R.
• Types	ABC & CO <sub>2</sub> Required	Provided	M.R.
• IS marking	ISI marks required	provided	M.R.

**First-Aid Hose Rees.**

• Total numbers on each floor	01	Provided	M.R.
• Length of hose reel hose	30 m required	Provided	M.R.
• Nozzle diameter	5 mm required	Provided	M.R.

**Automatic fire detection and alarming system.**

• Type of detectors	N.R.	N.R.	N.R.
---------------------	------	------	------

<ul style="list-style-type: none"> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooter's Location</li> </ul>	N.R.	N.R.	N.R.
	N.R.	N.R.	N.R.
	N.R.	N.R.	N.R.
	N.R.	N.R.	N.R.
<b>MOEFA</b>	Required	Provided	M.R.
<b>Public Address System.</b>	N.R.	N.R.	N.R.
<b>Automatic Sprinkler system</b>			
<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>	N.R.	N.R.	N.R.
	N.R.	Provided	M.R.
	N.R.	Provided	M.R.
<b>Internal Hydrants</b>			
<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>	Required	Provided 150 m.m.	M.R.
	1	Provided	M.R.
	1	Provided	M.R.
<b>Yard Hydrants.</b>			
<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>	N.R.	N.R.	N.R.
	N.R.	N.R.	N.R.
<b>Pumping Arrangements.</b>			
<b>Ground Level</b>			
➤ Discharge of main pump	N.R.	N.R.	N.R.
➤ Head of Main pump	N.R.	N.R.	N.R.

➤ Number of main pumps	N.R.	N.R.	N.R.
➤ Jockey Pump out put	N.R.	N.R.	N.R.
➤ Jockey pump head	N.R.	N.R.	N.R.
➤ Standby pump out put	N.R.	N.R.	N.R.
➤ Standby pump Head	N.R.	N.R.	N.R.
➤ Auto Starting Manual stopping	N.R.	N.R.	N.R.
➤ Pump Hose Access	N.R.	N.R.	N.R.
<b>terrace level</b>			
➤ Discharge of pump	450 LPM	Provided	M.R.
➤ Head of the pump	33 mtr	Provided	M.R.
➤ Power supply	Required	Provided	M.R.
➤ Auto Starting of pump	required	Provided	M.R.
<b>Captive Water Storage for fire fighting.</b>			
<b>Underground tank capacity</b>			
➤ Draw -off connection	N.R.	N.R.	N.R.
➤ Fire service inlet	N.R.	N.R.	N.R.
➤ Access to tank	N.R.	N.R.	N.R.
➤ Overhead Tank Capacity	10,000 ltrs	20,000 ltrs	M.R.
<b>Exit Signage.</b>	Required	Provided	M.R.
<b>Provision of Lifts</b>			
• Pressurization of Lift Shaft	N.R.	N.R.	N.R.
• Pressurization of Lift lobby	N.R.	N.R.	N.R.
• Communication In lift Car	N.R.	N.R.	N.R.

AL-11

<ul style="list-style-type: none"> <li>* Fireman's Grounding Switch</li> <li>* Lift Signage</li> </ul>	N.R.	N.R.	N.R.
	N.R.	N.R.	N.R.
<b>Standby power supply</b>	Required	Provided	M.R.
<b>Refuge Area</b>			
➤ Total Area	N.R.	N.R.	N.R.
➤ Location	N.R.	N.R.	N.R.
<b>Fire Control Room</b>			
➤ Detector System Panel	N.R.	N.R.	N.R.
➤ Flow Switch Panel	N.R.	N.R.	N.R.
➤ PA system Panel	N.R.	N.R.	N.R.
➤ Batter backup	N.R.	N.R.	N.R.
➤ Building Floor plans	N.R.	N.R.	N.R.
Special Fire Protection Systems for Protection of special Risks, if any:	N.R.	N.R.	N.R.

The protection systems provided in the building were test checked and found functional at the time of inspection. In view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/



Signature of the Inspection Officer

Anil Chowdhary

Signature of the Inspection Officer

Name

Designation

Station D.A.R. (M.N.)