

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFs/MS/2014/W2/567

Dated: 07/05/2014

**FIRE SAFETY CERTIFICATE**

Certified that M/s Sidhi Cosmetics, D-259, Sector-3, DSIDC Bawana, Delhi-110039 comprised of G.F of premises Basement + Ground + One upper floor owned/occupied by M/s Sidhi Cosmetics have complied with the fire prevention and fire safety requirement in accordance with rule 33 of the Delhi Fire Service Rules, 2010, and verified by the officer concerned of Fire Service on 24/04/2014 in the presence of Sh. Kashish Madaan and that the building /premises is fit for occupancy Industrial G-2 (ii) building with effect from 07/05/2014 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able by guests in an event of emergency.
2. All employees shall be acquainted with the use and maintenance of all the fire fighting installation/equipments.
3. The fire suppression / protection arrangements provided in the guest house are to minimize losses, if maintained in good working condition. These systems cannot give any guarantee that there will be no fire or losses in the event of one.
4. Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the licensee.
5. This report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on.....07/05/14.....at New Delhi.

  
(SANTOKH SINGH)  
Chief Fire Officer  
Delhi Fire Service  
Ph: 011-23414250  
cfowz.dlfire@nic.in

Copy to:-

1. M/s Sidhi Cosmetics, D-259, Sector-3, DSIDC Bawana, Delhi-110039.
2. The Assistant Drugs Controller & Licensing Authority, Govt. of NCT of Delhi, F-17, Karkardooma, New Delhi-110032

N-7

B + Gr. + one + two rooms.

**INSPECTION REPORT**

1. Name & address of the building: Sidhi Cosmetics, D-259, Sec-2 DSI/DL Barang Delhi-59
2. Type of Occupancy: Industrial G-2 (ii)
3. Type of Case: New Case / Renewal (FSC for Gr. floor only)
4. Details of previous NOC: Nil
5. Fire Safety directives letter No: NBC Part B
6. Date of inspection: 24.4.14
7. Name of the Inspecting Officers: AOO (BW)
8. Name and designation of officers from the building side: Sh. Keshish Madam - prop.
9. Year of Construction: 2013
10. Applicant's letter No: Lt No Nil dt. 9.4.14

Plot Area - 150m<sup>2</sup> CA - 425 m<sup>2</sup>

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	Accessible	Accessible	MR ✓
	• Gate width	—	—	—
	• Width of internal road	—	—	—
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	(FSC Regd. for Gr. floor only) ✓		
	• Upper Floors	—	—	—
	• Basements	—	—	—
	b. Width of staircases			
	• Upper Floors	—	1.12 mtr	— ✓
	• Basements	—	1.12 mtr	— ✓
	c. Protection of exits			
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	—	—	—
	g. Width of Corridor	—	—	—
	h. Door Size	2 exit 1 mtr each	1.12 mtr f 2.90 mtr shelter	MR ✓
3	<b>Compartmentation.</b>			
	• Fire check door	—	—	—

H-8

M

	<ul style="list-style-type: none"> <li>Sealing of electrical shafts</li> <li>Fire Rating of shaft door</li> <li>Water Curtain</li> <li>Fire Dampers</li> </ul>				
4	<b>Smoke Management System.</b>				
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	30 a/c per hour 12 a/c per hour			
5	<b>Fire Extinguishers</b>				
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>ISI marking</li> </ul>	7 ABC ISI marked	12 ABC yes	MR MR MR	
6	<b>First-Aid Hose Reels.</b>				
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	one 30 m 5 mm	P P P	MR MR MR	
7	<b>Automatic fire detection and alarming system.</b>				
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>				
8	<b>MOEFA</b>				
9	<b>Public Address System.</b>				
10	<b>Automatic Sprinkler System.</b>				
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	R R -	P P -	MR MR -	
11	<b>Internal Hydrants</b>				
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>				
12	<b>Yard Hydrants.</b>				
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>				




H-10

	<ul style="list-style-type: none"> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>			
20	Special Fire Protection Systems for Protection of special Risks, if any:			

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers..... NIL .....



Signature of the Inspecting Officer

Name

Designation

20/6/10

Signature of the Inspecting Officer

Name

Designation

24/4/19  
ASO (SW)