

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001**

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593

No.F.6/DFS/MS/School/2014/ 82/592

Dated: 09/05/14

FIRE SAFETY CERTIFICATE

Certified that the building of **Shokeen International School** located at Chawala, New Delhi-110071 is comprised of ground floor plus one upper floor was issued NOC by this department vide letter No.F.6/DFS/MS/2009/1220 dated 05.05.2009. The School building was re- inspected by the officer concerned of this department on 28.04.2014 in the presence of Sh. Naresh Kumar (Chairman) and found that the school management have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/ premises is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed overleaf.

Issued on.....09/05/14.....at New Delhi.


(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph:- 011-23414333

Copy to:-

1. The Chairman,
Shokeen International School,
Chawala, New Delhi-110071.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi – 110054.

OK
09

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/ occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

Ground floor and one upper floor

N/2

(Renewal)

INSPECTION REPORT

1. Name & address of the building: Shokeen International School, Village Chauwala, ND-71
2. Type of Occupancy : Educational
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. F6/DFS/MS/09/1220 Dated 05/05/09
5. Fire Safety directives letter No : _____
6. Date of inspection : 28/04/2014
7. Name of Inspecting Officer : ADO Sandeep Duggal
8. Name and designation of officers
From the building side : Mr Naresh Kumar (Chairman)
9. Year of Construction : 2004
10. Applicant's letter No. : 02/SIS/14/14 dt 15/04/14.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Circular dt. 01.03.2011	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<p>Accessible</p> <p>—</p> <p>—</p>	<p>5 mtr</p> <p>480 cms</p> <p>—</p>	<p>MR</p> <p>—</p> <p>—</p>
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	<p>02 Nos</p> <p>—</p>	<p>02 Nos</p> <p>—</p>	<p>MR</p> <p>No Basement</p>
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	<p>1.5 mtr</p> <p>—</p>	<p>2 mtr & 123 cms</p> <p>—</p>	<p>MR (Being old case)</p> <p>No Basement</p>
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • pressurization 	<p>—</p> <p>—</p>	<p>—</p> <p>—</p>	<p>—</p> <p>—</p>
	d. No. of continuous staircases to terrace			
		—	01	—
	e. Width of Corridor			
		—	340 & 190 cm	MR
	f. Door Size			
		1 mtr	120 cms (2 Nos) in each class	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p>	<p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p>	<p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p>
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	<p>30 a/c per hour</p> <p>—</p> <p>—</p>	<p>—</p> <p>—</p> <p>Natural ventilation</p>	<p>No Basement</p> <p>MR</p>

Sand

P/B

		12 a/c per hour		
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	<p>04 Nos ABC</p> <p>ISI marked</p>	<p>06 Nos Provided</p> <p>— do —</p>	<p>MR</p> <p>MR</p> <p>MR</p>
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	<p>—</p> <p>30 m</p> <p>5 mm</p>	<p>Provided⁵⁰⁰</p> <p>— do —</p> <p>— do —</p>	<p>—</p> <p>—</p> <p>—</p>
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	<p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p>	<p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p>	<p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p>
8.	MOEFA			
9.	Public Address System			
			Provided ⁵⁰⁰	
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	<p>—</p> <p>—</p> <p>—</p>	<p>—</p> <p>—</p> <p>—</p>	<p>—</p> <p>—</p> <p>—</p>
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	<p>—</p> <p>—</p> <p>—</p>	<p>—</p> <p>—</p> <p>—</p>	<p>—</p> <p>—</p> <p>—</p>
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	<p>—</p> <p>—</p>	<p>—</p> <p>—</p>	<p>—</p> <p>—</p>
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/Manual stopping 	<p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p>	<p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p>	<p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p>

SPM

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	—	—	—
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	—	—	—
		—	250 litres.	—
15.	Exit Signage.	—	—	—
16.	Provision of Lifts.			No lift
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	—	—	—
17.	Standby power supply	—	—	—
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	—	—	—
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	—	—	—
20.	Special Fire Protection System for Protection of special Risks, if any:	—	—	—

MS

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. FG/DFS/MS/09/1220 dated 05/05/09 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

1
Sandeep
05/05/14.

Signature of Inspecting Officer

Name Sandeep Duggal

Designation Asst. Divisional Officer

Signature of Inspecting Officer

Name

Designation