

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001


No. *FG/DFS/MS/2014/Petl/ND2/584*

Dated *08/05/2014*

FIRE SAFETY CERTIFICATE


Certified that the Petroleum Storage Class A & B (Delhi Police Fleet only) at Police Station, Kalyan Puri, Delhi, owned by Delhi Police have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 03.05.2014 in the presence of Sh. Raj Kumar Saha (Inspector) and found that the Retail Outlet (Petrol Pump) is fit for occupancy Petroleum storage (class A & B 20 KL Each) with effect from*8/5/14*... for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on.....*8/5/14*.....at New Delhi by


(Dr. G. C. Misra)
Chief Fire Officer
Ph.011-23414333

To,
The Addl. Commissioner of police (Licensing),
1st Floor, P.S. Defence colony,
New Delhi.

Copy to:-
The Dy. Commissioner of police
East District, Delhi.

Received

H. C. VINOD KUMAR
No. 2746/E
DA - 9/5/14

OIC
fr

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. All comments/directions of the Licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

1. Name & address of the building : Retail Outlet(Petrol Pump) at Police Station, Kalyan Puri, Delhi.
2. Building is comprised of : N/A
- 3.Type of Occupancy : Petroleum Storage
- 4.Type of Case : New
- 5.Details of Previous NOC letter :Nil
6. Fire Safety direction letter No : F.5/(3A)/DFS/2010/240 Dated 06/08/2010.
- 7.Date of Inspection : 03.05.2014
- 8.Name of the Inspecting officers : DO Virendra Singh
- 9.Name and designation of Officer
from the building side :Sh.Raj Kumar Saha (Inspector)
- 10.Year of Construction :2014
11. Applicant's letter No : F.7(1113)/2010/17763/Addl.C.P/Lic.(Pet/Expl) dtd.25.04.14

S.NO.	Minimum Standards on fire prevention and fire safety U/R33	NBC/BBL Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	12 Mtrs.	15 Mtr,	MR
		4.5 Mtrs.	4.5 Mtrs.	MR
		N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	N/A	N/A	N/A
		N/A	N/A	N/A
	B. Width of Staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	N/A	N/A	N/A
		N/A	N/A	N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A	N/A	N/A
		N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	N/A	N/A	N/A
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basement • Upper floor 	N/A	N/A	N/A
		N/A	N/A	N/A
5.	Fire Extinguisher			
	<ul style="list-style-type: none"> • Total numbers • types • IS marking 	04 nos.	04 Nos.	MR
		Foam & DCP type	Foam & DCP type	MR
		ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers of each floor • Length of hose reel hose 	N/A	N/A	N/A
		N/A	N/A	N/A


7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.	N/A	N/A	N/A
	• basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level	N/A	N/A	N/A
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the Pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15	Exit Signage.	N/A	N/A	N/A
16	Provision of Lifts.	N/A	N/A	N/A
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	N/A	N/A	N/A
	• Total area	N/A	N/A	N/A


N14

19	Fire Control Room			
	<ul style="list-style-type: none">• Detector system panel	N/A	N/A	N/A
	<ul style="list-style-type: none">• Flow switch panel	N/A	N/A	N/A
	<ul style="list-style-type: none">• PA system panel	N/A	N/A	N/A
	<ul style="list-style-type: none">• Battery backup	N/A	N/A	N/A
	<ul style="list-style-type: none">• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems i.e. fire extinguishers provided at the Petrol Pump were checked and found functional at the time of inspection. No smoking " sign board both in Hindi and English displayed and fire buckets filled with dry & loose sand were found provided.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.




5/5/14
Signature of the Inspecting Officer
Name: Virendra Singh
Designation: DO(ED)