

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F.6/DFS/MS/2014 / *School/w2/585*

Dated: *08/05/2014*

**FIRE SAFETY CERTIFICATE**

Certified that **M C Primary Boys School, Palla Delhi-110036** comprised of **Ground Floor** owned/occupied by **M C Primary boys School** has already been issued fire safety certificate **vide letter no. F-6/DFS/MS/2011/1092 dated 03/06/2011.** The premises was re-inspected by the officer from this department on dated **28/04/2014** in the presence of **Sh. Gaje Singh (T. in-charge)** and observed that the school is now comprised of Ground + One upper floor. All the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with the requirements of **circular issued by Director of Education letter dated 17/01/2005** and the building / premise is fit for occupancy of **Group Class B (Educational)** with effect from **08/05/2014** for a period of **three years**, subject to compliance of the conditions mentioned below:

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on *08/05/14* at New Delhi by

  
(SANTOKH SINGH)  
Chief Fire Officer  
Delhi Fire Service  
Ph: 011-23414250  
[cfowz.dlfire@nic.in](mailto:cfowz.dlfire@nic.in)

**Copy to:**

1. The Principal, M C Primary Boys School, Palla Delhi-110036
2. The Addl. Director of Education, North MCD, Civic Centre New Delhi.

*dce*

N-5

earlier. Gr floor only.  
old bldg. demolish New Bldg. Gr. + one.**INSPECTION REPORT**

1. Name & address of the building: M.C. 1st. Boys School, Pall Delhi-36.
2. Type of Occupancy : Educational
3. Type of Case : New Case / Renewal
4. Details of previous NOC : F.6/DAS/MS/2011/1092 dt. 3-06-11
5. Fire Safety directives letter No : dir. of edu.
6. Date of inspection : 28-04-14.
7. Name of the Inspecting Officers : ADO (BW)
8. Name and designation of officers from the building side : Sh. Gaj Singh (Teacher Incharge)
9. Year of Construction : 2014
10. Applicant's letter No. : Nil dt. 15-04-14

Plot area:-

7896 Sqm

Covered area:-

1089-90 Sqm

No.'s of students:-

140

No.'s of classrooms:-

14+2

	Minimum Standards on fire prevention and fire safety U/R 33	Circular Dir. of Edu Requirement/ NBC	Provided at site	Remark MR/NM
1	<b>Access to building</b>			
	• Road width	Accessible	Accessible	MR ✓
	• Gate width	Accessible	Accessible	MR ✓
	• Width of internal road	Accessible	Accessible	MR ✓
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	-	-	-
	• Upper Floors	2	2	MR ✓
	• Basements	-	-	-
	b. Width of staircases	-	-	-
	• Upper Floors	150 Cm.	150 Cm. each	MR ✓
	• Basements	-	-	-
	c. Protection of exits	-	-	-
	• Fire check door	-	-	-
	• Pressurization	-	-	-
	e. No. of continuous staircases to terrace	-	-	-
	g. Width of Corridor	-	-	-
	h. Door Size	100 Cm.	110 Cm. Double Door	MR ✓



3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>			N.A.
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour 12 a/c per hour		N.A.
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	07 ABC ISI marked	07 ABC yes	MR ✓ MR ✓ MR ✓
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	30 m 5 mm		N.A.
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>			N.A.
8	<b>MOEFA</b>			
9	<b>Public Address System.</b>			
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>			N.A.
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>			N.A.

12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>		N.A.	
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>• Ground Level               <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> </ul> </li> <li>• Terrace level               <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pum</li> </ul> </li> </ul>		N.A.	
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity               <ul style="list-style-type: none"> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> </ul> </li> <li>• Overhead Tank capacity</li> </ul>		N.A.	
15	<b>Exit Signage.</b>			
16	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>		N.A.	
17	<b>Standby power supply</b>			



18	<b>Refuge Area.</b>			
	➤ Total Area			
	➤ Location		N.A.	
19	<b>Fire Control Room</b>			
	• Detector System Panel			
	• Flow Switch Panel			
	• PA System Panel			
	• Batter backup			
	• Building Floor Plans			
20	Special Fire Protection Systems for Protection of special Risks, if any:			

Note: Earlier the school was having GF only. After demotion to the bldg on 4+1 & meets the requirements.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.G./D.F.S./ms/2011/1092 Dated.../03/06/11..... Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name

Designation

DO (NW)

*Geetha*  
15/11/14

Signature of the Inspecting Officer

Name

Designation

*K. K. Saxena*

ADO (BW)

*K. K. Saxena*