

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/2014/School/ 42/571

Dated: 07 / 05 / 2014

FIRE SAFETY CERTIFICATE

Certified that Gyanodya Model Public School, Near Dayal Market, Alipur, Delhi-110036 comprised of Ground + two upper floors owned / occupied by Gyanodya Model Public School has already been issued fire safety certificate vide this office letter No F-6/DFS/MS/2011/722 dated 20/04/2011. The premise was re-inspected by the officer from this department on dated 04/04/2014 in the presence of Smt. Reeta Maan (Principal) and observed that the school is running on ground floor + one upper floor now and all the fire prevention & fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety requirements in accordance with circular issued by Director of Education letter dated 17/01/2005 and that the building / premises is fit for occupancy of Group Class B (Educational) with effect from 07 / 05 / 2014 for a period of three years, subject to compliance of the conditions mentioned below.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 07 / 05 / 14 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in

Copy to:

1. The Principal, Gyanodya Model Public School, Near Dayal Market, Alipur, Delhi-110036
2. The Director of Education, Old Secretariat, Delhi - 110054.



N-5

Bldg. G.R + Two floors
School running G.R + one floor

INSPECTION REPORT

1. Name & address of the building : Gyanodya model Public School Near Dayal Mkt. Alipur Delhi-36
2. Type of Occupancy : Educational (Circular 2005)
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. F6/DFS/MS/2011/722 Dated: 20.4.11
5. Fire Safety directives letter No : Dir. of Edu. (Circular 2005)
6. Date of inspection : 4.4.14
7. Name of the Inspecting Officers : ADO (BW)
8. Name and designation of officers from the building side : Smt. Reeta Mann, Principal
9. Year of Construction : 2002
10. Applicant's letter No. : Of No. 300/2014 Dt. 21.3.14

Plot area 225 sq. yards Covered area 625 sq. yards No.s of student 340 No.s of class room 7
4 for other purpose.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement <u>Dir. of Edu.</u>	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	<u>Accessible</u>	<u>Accessible</u>	<u>MR</u>
	• Gate width	<u>—</u>	<u>—</u>	<u>—</u>
	• Width of internal road	<u>—</u>	<u>—</u>	<u>—</u>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	<u>—</u>	<u>—</u>	<u>—</u>
	• Upper Floors	<u>1</u>	<u>2</u>	<u>MR</u>
	• Basements	<u>—</u>	<u>—</u>	<u>—</u>
	b. Width of staircases	<u>—</u>	<u>—</u>	<u>—</u>
	• Upper Floors	<u>1.5 mtr</u>	<u>1.27 + 1.10 mtr</u>	<u>MR</u>
	• Basements	<u>—</u>	<u>—</u>	<u>—</u>
	c. Protection of exits	<u>—</u>	<u>—</u>	<u>—</u>
	• Fire check door	<u>—</u>	<u>—</u>	<u>—</u>
	• Pressurization	<u>—</u>	<u>—</u>	<u>—</u>
	e. No. of continuous staircases to terrace	<u>—</u>	<u>—</u>	<u>—</u>
		<u>—</u>	<u>—</u>	<u>—</u>

1N-6

M

	g. Width of Corridor h. Door Size	1.45	old case	old case
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A		
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	N/A	
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	7 ABC ISI marked	9 ABC 7 cell	MR ✓ MR ✓ MR ✓
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	one 30 m 5 mm	P P P	MR ✓ MR ✓ MR ✓
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	N/A		
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	N/A		

N-8

	<ul style="list-style-type: none"> • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 			
17	Standby power supply			
18	Refuge Area.			
	➤ Total Area			
	➤ Location			
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 			
20	Special Fire Protection Systems for Protection of special Risks, if any:			

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F-6/D.F.S./.. MS/2011/722 dated 20.4.11...Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspection Officer

Name

Designation

DO (N/A)

Signature of the Inspection Officer

Name

Designation

ASD (BN)