

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F.6/DFS/MS/school/2014/W2/570  
**FIRE SAFETY CERTIFICATE**

Dated: 07/05/2014

Certified that the **Govt. Co-ed Sarvodaya Vidyalaya, Sawda (Ghevra) Colony, A-Block, Delhi-110081** comprised of **Ground + One Upper Floor** has already been issued fire safety certificate vide letter no. **F.6/DFS/MS/2012/School/4230 dated 12/11/2012.** The new block comprise of Ground + one upper floor owned / occupied by **Govt. Co-ed Sarvodaya Vidyalaya** was inspected and found to have complied with the fire prevention and fire safety requirements in accordance with the **Circular No F.16/Estate/CC/Fire Safety /2011/3298-3398 dated 01/03/2011 issued by Director of Education** and verified by the officer concerned of Fire Service on **11/02/2014** in the presence of **Sh K.K.Dabbas** and that the building / premise is fit for occupancy of **Educational** building with effect from **07/05/2014** for a period of **three years**, subject to compliance of the conditions mentioned below:

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on 07/05/14 at New Delhi by

  
(SANTOKH SINGH)  
Chief Fire Officer  
Delhi Fire Service  
Ph: 011-23414250  
[cfowz.dlfire@nic.in](mailto:cfowz.dlfire@nic.in)

**Copy to:**

1. The Principal, Govt. Co-ed Sarvodaya Vidyalaya, Sawda (Ghevra) Colony, A-Block, Delhi-110081
2. The Director of Education, Old Secretariat, Delhi



New-Block - G.F + F.F.

INSPECTION REPORT

1. Name & address of the building: Govt. Co-ed Sarvodaya Vidyalaya, (Sawda) Colony (A-Block) Delhi-81
2. Type of Occupancy: .....
3. Type of Case: ✓ : New Case / Renewal
4. Details of previous NOC: F-6/DPS/ms/2012/school/4230/-12-11-12 (old case)
5. Fire Safety directives letter No: Circular of the director of Ed'n dt 01-3-11
6. Date of inspection: 11-2-14
7. Name of the Inspecting Officers: M. P. Sharma
8. Name and designation of officers from the building side: Sh. K-K. Babbar
9. Year of Construction: old block - 2007, New Block - 2013
10. Applicant's letter No.: SM dt 15-10-13

Plot area:- 4495 m<sup>2</sup> Covered area:- 2448 m<sup>2</sup> No.'s of students:- 1063. No.'s of classrooms:- 33

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Edu BBL/NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	<u>Accessible</u>	<u>Accessible</u>	<u>MR</u>
	• Gate width	<u>-</u>	<u>-</u>	<u>-</u>
	• Width of internal road	<u>-</u>	<u>-</u>	<u>-</u>
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	<u>R</u>	<u>P</u>	<u>MR</u>
	• Upper Floors	<u>03</u>	<u>03</u>	<u>MR</u>
	• Basements	<u>-</u>	<u>-</u>	<u>-</u>
	b. Width of staircases	<u>R</u>	<u>P</u>	<u>MR</u>
	• Upper Floors	<u>1.5 mtr</u>	<u>1.5 mtr each</u>	<u>MR</u>
	• Basements	<u>-</u>	<u>-</u>	<u>-</u>
	c. Protection of exits	<u>-</u>	<u>-</u>	<u>-</u>
	• Fire check door	<u>-</u>	<u>-</u>	<u>-</u>
	• Pressurization	<u>-</u>	<u>-</u>	<u>-</u>
	e. No. of continuous staircases to terrace	<u>-</u>	<u>-</u>	<u>-</u>
	g. Width of Corridor	<u>-</u>	<u>-</u>	<u>-</u>
	h. Door Size	<u>1 mtr</u>	<u>1.2 mtr</u>	<u>MR</u>



N/20

3	<b>Compartmentation.</b>	NIA		
	• Fire check door	-	-	-
	• Sealing of electrical shafts	-	-	-
	• Fire Rating of shaft door	-	-	-
	• Water Curtain	-	-	-
	• Fire Dampers	-	-	-
4	<b>Smoke Management System.</b>	NIA		
	• Basements	30 a/c per hour	-	-
	• Upper floors	12 a/c per hour	-	-
5	<b>Fire Extinguishers</b>			
	• Total numbers	09	28	MR ✓
	• Types	ISI marked	ABC type	MR ✓
	• IS marking		yes	MR ✓
6	<b>First-Aid Hose Reels.</b>	NIA		
	• Total numbers on each floor		-	-
	• Length of hose reel hose	30 m	-	-
	• Nozzle diameter	5 mm	-	-
7	<b>Automatic fire detection and alarming system.</b>	NIA		
	• Type of detectors	-	-	-
	• Location of Main Panel	-	-	-
	• Location of Repeater Panel	-	-	-
	• Alternate source of power	-	-	-
	• Hooters' Location	-	-	-
8	<b>MOEFA</b>	-	-	-
9	<b>Public Address System.</b>	-	-	-
10	<b>Automatic Sprinkler System.</b>	NIA		
	• Basement	-	-	-
	• Upper Floor	-	-	-
	• Sprinkler above false ceiling	-	-	-
11	<b>Internal Hydrants</b>	NIA		
	• Size of riser/down-comer	-	-	-
	• Number of hydrants per floor	-	-	-
	• Hose Box	-	-	-

N/21

12	<b>Yard Hydrants.</b>	N/A		
	• Total number of hydrants	-	-	-
	• Hose Box	-	-	-
13	<b>Pumping Arrangements.</b>	N/A		
	• Ground Level	-	-	-
	➤ Discharge of main Pump	-	-	-
	➤ Head of Main pump	-	-	-
	➤ Number of main pumps	-	-	-
	➤ Jockey Pump out put	-	-	-
	➤ Jockey pump head	-	-	-
	➤ Standby Pump out put	-	-	-
	➤ Standby Pump Head	-	-	-
	➤ Auto Starting/ Manual stopping	-	-	-
	➤ Pump House Access	-	-	-
	• Terrace level	-	-	-
	➤ Discharge of pump	-	-	-
	➤ Head of the pump	-	-	-
	➤ Power Supply	-	-	-
	➤ Auto Starting of pum	-	-	-
14	<b>Captive Water Storage for fire fighting.</b>	N/A		
	• Underground tank capacity	-	-	-
	➤ Draw-off connection	-	-	-
	➤ Fire service inlet	-	-	-
	➤ Access to tank	-	-	-
	• Overhead Tank capacity	-	-	-
15	<b>Exit Signage.</b>	-	-	-
16	<b>Provision of Lifts.</b>	N/A		
	• Pressurization of Lift Shaft	-	-	-
	• Pressurization of Lift lobby	-	-	-
	• Communication In lift Car	-	-	-
	• Fireman's Grounding Switch	-	-	-
	• Lift Signage	-	-	-
17	<b>Standby power supply</b>	-	-	-

N/22

18	<b>Refuge Area.</b>	N/A		
	➤ Total Area	—	—	—
	➤ Location	—	—	—
19	<b>Fire Control Room</b>	N/A		
	• Detector System Panel	—	—	—
	• Flow Switch Panel	—	—	—
	• PA System Panel	—	—	—
	• Batter backup	—	—	—
	• Building Floor Plans	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	—	—

Note. FSC was issued for old block vide no R-6/DFS/MS/2012/school/4230 dt 12-11-12. Inspection was carried out for new block G.F + R.F.

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. ....Dated...../...../..... Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer *(Signature)* 19-3-14

Name N.P. Sharma

Designation ADO 'R'

Signature of the Inspecting Officer

Name

Designation

