GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001
Fax:- 011-23412593 E-mail ID:cfohq.dlfire@nic.in

No F 6 / DFS / MS / GH / 2014 / N02/603 Dated 15/05/14

## FIRE SAFETY CERTIFICATE

Certified that the **Ambrosia Bliss Restaurant (A unit of Felicia Entertainments p Ltd) at L-51 to 54, SF, Connaught Place, Outer Circle, New Delhi** comprises of Ground floor + 02 upper floors occupied by (A Unit of Felicia Entertainments p Ltd.) Restaurant running at 2nd floor have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of the fire service on 25/04/2014 in the presence of Mr. Surender (Manager) and found that the said building / premises is fit for occupancy **Class Group D Assembly Building** with effect from ~~15/05/14~~ --2014 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ..15/05/14..... at New Delhi by.

(Dr. G. C. Misra)
Chief Fire Officer
Delhi fire Service
Ph – 011-23414333

Copy to:-

1. Ambrosia Bliss Restaurant (A unit of Felicia Entertainments p Ltd) at L-51 to 54, SF, Connaught Place, Outer Circle, New Delhi.
2. Medical officer of Health, Health Department, Palika Kendra, New Delhi – 110001 No. MOH/D/184/CSI (Lic.)SI-1 dated 04/03/2014.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

N/2

## INSPECTION REPORT

1. Name & address of the building : M/s Ambrosia Bliss Restaurant (A unit of Felicia Entertainment (P) Ltd.) at L-51 to L-54, SF, Connaught Place, Outer Circle, New Delhi.
2. Type of Occupancy : Assembly (Restaurant) Gr.+ 2nd floor, Restaurant at 2nd floor
3. Type of Case : Fresh
4. Details of previous NOC : NA
5. Fire Safety directives Letter No. : NA
6. Date of inspection : 25/04/2014
7. Name of the Inspecting Officer : Sh. Gurmukh Singh (DO/CD) & Sh. M. K. Sharma (ADO/CC)
8. Name and designation of Officer from the building side : Mr. Surender (Manager)
9. Year of Construction : old Heritage Bldg.
10. Applicant's letter No. : MOH/D/184/CSI(Lic.)SI-1 dated 04/03/2014

| S No | Minimum standards on fire prevention and fire safety U/R 33 | Requirements | Provided at site | Remarks MR/NMR |
|---|---|---|---|---|
| 1. | Access of building | | | |
| | • Road width | 9 Mtr. | 12 Mtr. | MR |
| | • Gate width | NA | NA | NA |
| | • Width of internal road | NA | NA | NA |
| 2. | Number, width, Type & Arrangements of exits | | | |
| | a. Number of staircases | | | |
| | • Upper floors | 2 Nos. | 2 Nos. | MR |
| | • Basements | NA | NA | NA |
| | b. Width of staircases | | | |
| | • Upper floors | 1.50 Mtr. old Heritage Bldg. | 1.0 & 1.25 Mtr. | MR |
| | • Basements | NA | NA | NA |
| | c. Protection of exits | | | |
| | | NA | NA | NA |

mer

| | | | | |
|---|---|---|---|---|
| | • Fire check door | NA | NA | NA |
| | • Pressurization | NA | NA | NA |
| | d. No of continuous staircase to terrace | 01 | 02 | MR |
| | e. Width Of Corridor | NA | NA | NA |
| | f. Door Size | 2.0 Mtr. | 2.0 Mtr. | MR |
| 3. | Compartmentation | | | |
| | • Fire check door | NA | NA | NA |
| | • Sealing of electrical shafts | NA | NA | NA |
| | • Fire Rating of shaft door | NA | NA | NA |
| | • Water Curtain | NA | NA | NA |
| | • Fire Dampers | NA | NA | NA |
| 4 | Smoke managements System | | | |
| | • Basements | NA | NA | NA |
| | • Upper floors | 12 ACPH | NATURAL | MR |
| 5 | Fire Extinguishers | | | |
| | • Total numbers | 10 Nos. | 12 Nos. | MR |
| | • Types | ABC, $CO_2$, $Wco_2$ | ABC, $CO_2$, $Wco_2$ | MR |
| | • IS marking | Required | Provided | MR |
| 6 | First – Aid Hose Reels | | | |
| | • Total numbers on each floor | 02 | 02 | MR |
| | • Length of hose reel hose | 30 Mtr. | 30 Mtr. | MR |
| | • Nozzle diameter | 05 MM | 05 MM | MR |
| 7 | Automatic fire detection and alarming system | | | |
| | • Type of detectors | Required | Provided | MR |
| | • Location of Main Panel | NA | NA | NA |
| | • Location of Repeater Panel | NA | NA | NA |
| | • Alternate source of power | NA | NA | NA |
| | • Hooters' Location | NA | NA | NA |
| 8 | MOEFA | Required | Provided | MR |
| 9 | Public Address System | NA | NA | NA |
| 10 | Automatic Sprinkler | | | |
| | • Basements | NA | NA | NA |

N/A.

| | | | | |
|---|---|---|---|---|
| | Upper | Required | Provided | MR |
| | • Sprinkler above false ceiling | NA | NA | NA |
| 11 | Internal Hydrants | | | |
| | • Size of riser/down- comer | 100 MM | 100 MM | MR |
| | • Number of hydrants per floor | 02 | 02 | MR |
| | • Hose Box | 02 | 02 | MR |
| 12 | Yard Hydrants | | | |
| | • Total number of hydrants | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 13 | Pumping Arrangements | | | |
| | ○ Ground Level | | | |
| | • Discharge of main pump | NA | NA | NA |
| | • Head of main pump | NA | NA | NA |
| | • Number of main pumps | NA | NA | NA |
| | • Jockey pump out put | NA | NA | NA |
| | • Jockey pump head | NA | NA | NA |
| | • Standby Pump out put | NA | NA | NA |
| | • Standby Pump Head | NA | NA | NA |
| | • auto Staring/Manual stopping | NA | NA | NA |
| | • Pump House Access | NA | NA | NA |
| | ○ Terrace level | | | |
| | • Discharge of pump | 450 LPM | 450 LPM 2 Nos. | MR |
| | • Head of the pump | 30 Mtr. | 30 Mtr. | MR |
| | • Power supply | Required | Provided | MR |
| | • Auto starting of pump | Required | Provided | MR |
| | | | | |
| 14 | Captive water Storage for fire fighting | NA | NA | NA |
| | • Under ground tank capacity | NA | NA | NA |
| | • Draw of connection | NA | NA | NA |
| | • Fire service inlet | NA | NA | NA |
| | • Access to tank | Required | Provided | MR |
| | • Overhead Tank capacity | 10,000 Ltr. | 10,000 Ltr. | MR |

h

mett

14/5

| | | | | |
|---|---|---|---|---|
| 15 | Exit Signage | Required | Provided | MR |
| 16 | Provision of Lifts | NA | NA | NA |
| | • Pressurization of Lift Shaft | NA | NA | NA |
| | • Pressurization of lift lobby | NA | NA | NA |
| | • Communication in lift Car | NA | NA | NA |
| | • Fireman's Grounding Switch | NA | NA | NA |
| | • Lift Signage | NA | NA | NA |
| 17 | Standby power supply | Required | Provided | MR |
| 18 | Refuge Area | | | |
| | • Total area | NA | NA | NA |
| | • Location | NA | NA | NA |
| 19 | Fire control room | | | |
| | • Detector system panel | NA | NA | NA |
| | • Flow Switch Panel | NA | NA | NA |
| | • PA System Panel | NA | NA | NA |
| | • Batter backup | NA | NA | NA |
| | • Building Floor Plans | NA | NA | NA |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any; | Required | ABC, $Co_2$ | MR |

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.
Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rule to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010, FSC is recommended please.

Name :- Sh. Gurmukh Singh
Designation :-DO(CD)

24/4/14

Name:- Sh. M. K. Sharma
Designation :- A. D.O. (CC)