

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/2014/W2/627

Dated: 22/5/14

FIRE SAFETY CERTIFICATE

Certified that the **B – 08, GD ITL Tower** located at **Netaji Subhash Place, Pitampura, Delhi – 110034** comprised of Basement + Ground + 13 Upper Floors was issued FSC vide Letter No. F6/DFS/MS/2000/2196 dated 04-12-2000. The premises was re inspected by the officers concerned of this department on 22-04-2014 in the presence of Mr. Laxman Singh (Manager) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class “ Mercantile & Business Building” Group F & Group E with effect from 22/5/14 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...22/5/14...at New Delhi by.


(Santokh Singh)
Chief Fire Officer,
Delhi Fire Service

Copy to:

1. Sh. Laxman Singh (Manager),
B – 08, GD ITL Tower,
Netaji Subhash Place, Pitampura, Delhi – 110034.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: B – 08, GD ITL Tower, Netaji Subhash Place, Pitam Pura, Delhi – 110034.
2. Type of Occupancy : Mercantile + Business (Mixed), Basement + Ground + 13 Upper Floors
3. Type of Case : Renewal
4. Details of previous NOC : Letter No. F6/DFS/MS/2000/2196 dated 04-12-2000
5. Fire Safety directives Letter No. : Letter No. F6/DFS/MS/BP/96-21 dated 04-01-1996
6. Date of inspection : 22-04-2014
7. Name of the Inspecting Officer : DO (West) & ADO (MN)
8. Name and designation of Officer
from the building side : Sh. Laxman Singh (Manager)
9. Year of Construction : 2000
10. Applicant's letter No. : Form J dated 10-02-2014

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 m	Provided	MR
	• Gate width	6 m	Provided	MR
	• Width of internal road	6 m	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	2	Provided	MR
	b. Width of staircases			
	• Upper floors	Old Case	Old Case	MR
	• Basements	Old Case	Old Case	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NR	NR	NR
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width Of Corridor	Required	Provided	MR
	f. Door Size	Old Case	Old Case	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	NR	NR	NR
	• Fire Dampers	NR	NR	NR

4.	Smoke managements System			
	<ul style="list-style-type: none"> Basements Upper floors 	30 a/c per hour	Provided	MR
		12 a/c per hour	Provided	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	45 nos. CO ₂ & WCO ₂ ISI marked	Provided	MR
			Provided	MR
			Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	1 30 m 5 mm	Provided	MR
			Provided	MR
			Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Smoke & Heat Required Required Required Required	Provided	MR
			Provided	MR
			Provided	MR
			Provided	MR
			Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	Required Required Required	Provided	MR
			Provided	MR
			Provided	MR
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	150 mm 1 Required	Provided	MR
			Provided	MR
			Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	Required Required	Provided	MR
			Provided	MR
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump 	2400 lpm 110 m 2 250 lpm 110 m 2400 lpm 110 m Required Required NR NR	Provided	MR
			Provided	MR
			Provided	MR
			Provided	MR
			Provided	MR
			Provided	MR
			Provided	MR
			Provided & Functional	MR
			Provided	MR
			NR	NR
			NR	NR

	➤ Power supply	NR	NR	NR
	➤ Auto starting of pump	NR	NR	NR
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	2.00,000 litres	Provided	MR
		Required	Provided	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	20, 000 litres	Provided	MR
	• Overhead Tank capacity			
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	Required	Provided	MR
	➤ Pressurization of lift lobby	Required	Provided	MR
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	Old Case	Old Case	MR
	➤ Location	5 th , 6 th , 7 th , & 10 th Floor	Provided	MR
19.	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	Required	Provided	MR
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide Letter No. F6/DFS/MS/2000/2196 dated 04-12-2000 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

CFD/572
21/5/14

Signature of the Inspecting Officer

Name

MURKESH VERMA

Designation

ADD (MN)

Signature of the Inspecting Officer

Name

Designation

