

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

Fax:- 011-23412593

E-mail ID: cfohq.dlfire@nic.in


No F6/DFS/MS/2014/ND2/618

Dated 20/05/14

FIRE SAFETY CERTIFICATE

Certified that the **Ghalib Institute Auditorium** at, **Aiwan-E-Ghalib Marg, Mata Sundari Lane, New Delhi** comprises of Basement floor & Ground floor (Hall) was granted NOC by this department vide letter No. F6/DFS/MS/2011/1105 dated 06/06/2011. The premises was re-inspected by the officers concerned of this department on 11-04-2014 in the presence of Mr. Idrish Admn. Officer and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and the building is fit for occupancy class Group D "Assembly Building" Sub Division D-2 with effect from 20/05/14 for period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 20/05/14..... at New Delhi by.


(Dr. G. C. Misra)
Chief Fire Officer
Delhi Fire Service
Ph – 011-23414333

Copy to:-

1. Ghalib Institute Auditorium at, Aiwan-E-Ghalib Marg, Mata Sundari Lane, New Delhi.
2. The Joint. Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi – 110049 w.r.t. letter No 4011-16/Joint.C.P./Lic(Amst.) dated Delhi 27-01-2014.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

INSPECTION REPORT

1. Name & address of the building : Ghalib Institute Auditorium at, Aiwan-E-Ghalib Marg, Mata Sundari Lane, New Delhi.
2. Type of Occupancy : Assembly Building (Basement + Ground (Hall))
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2011/1105 dated 06/06/2011
5. Fire Safety directives Letter No. : F6/DFS/MS/1982/128 dated 19/01/82
6. Date of inspection : 11/04/2014
- 7 Name of the Inspecting Officer : Sh. Gurmukh Singh (DO/CD) & Sh. M. K. Sharma (ADO/CC)
- 8 Name and designation of Officer
from the building side : Mr. Idrish Admn. Officer
- 9 Year of Construction : 1982 old building
10. Applicant's letter No. : No. 4011-16/Joint C.P./Lic.(Amst.) dated Delhi the 27/01/14.

S No	Minimum standards on fire prevention and fire safety U/R 33	Existing Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9 Mtr.	12 Mtr.	MR
	• Gate width	4.5 Mtr.	4.5 Mtr.	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits & Spiral Staircase			
	a. Number of staircases			
	• Upper floors	4 Nos.	4 Nos.	MR
	• Basements	1 No	1 No	MR
	b. Width of staircases			
	• Upper floors (one ramp)	1.50 Mtr. old	2 nos. 1.50 Mtr. old 2 nos. 1.30 Mtr.	MR
	• Basements	1.0 Mtr. old	0.90 Mtr. existing	MR
	c. Protection of exits Fire check door	NA	NA	NA

h

Mash

	<ul style="list-style-type: none"> • Pressurization 	NA	NA	NA
	d. No of continuous staircase to terrace	1 No	1 No	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1.50 Mtr. old	2 nos. 1.30 Mtr, 2 nos. 1.50 Mtr. 2 nos. 1.75 Mtr. & 2.0 Mtr.	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door 	NA	NA	NA
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	NA	NA	NA
	<ul style="list-style-type: none"> • Water Curtain 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Dampers 	NA	NA	NA
4	Smoke managements System			
	<ul style="list-style-type: none"> • Basements 	30 ACPH	Machincal	MR
	<ul style="list-style-type: none"> • Upper floors 	12 ACPH	NATURAL	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	20 Nos.	22 Nos.	MR
	<ul style="list-style-type: none"> • Types 	ABC, CO ₂ , Wco ₂	ABC, CO ₂ , Wco ₂	MR
	<ul style="list-style-type: none"> • IS marking 	Required	Provided	MR
6	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor 	04	04	MR
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 Mtr.	30 Mtr.	MR
	<ul style="list-style-type: none"> • Nozzle diameter 	05 MM	05 MM	MR
7	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors 	Required	Provided	MR
	<ul style="list-style-type: none"> • Location of Main Panel 	At G. floor	At G. floor	MR
	<ul style="list-style-type: none"> • Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Alternate source of power 	Required	Provided	MR
	<ul style="list-style-type: none"> • Hooters' Location 	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler			

h

new

N/50

	<ul style="list-style-type: none"> Basements 	Required	Provided	MR
	<ul style="list-style-type: none"> Upper Floor 	Required	Provided	MR
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down- comer 	100 MM	100 MM	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	04	04	MR
	<ul style="list-style-type: none"> Hose Box 	04	04	MR
12	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	02	02	MR
	<ul style="list-style-type: none"> Hose Box 	02	02	MR
13	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> Discharge of main pump 	1620 LPM	1620 LPM	MR
	<ul style="list-style-type: none"> Head of main pump 	25 Mtr.	30 Mtr.	MR
	<ul style="list-style-type: none"> Number of main pumps 	01	01	MR
	<ul style="list-style-type: none"> Jockey pump out put 	280 LPM	450 LPM	MR
	<ul style="list-style-type: none"> Jockey pump head 	25 Mtr.	30 Mtr.	MR
	<ul style="list-style-type: none"> Standby Pump out put 	NA	NA	NA
	<ul style="list-style-type: none"> Standby Pump Head 	NA	NA	NA
	<ul style="list-style-type: none"> auto Staring/Manual stopping 	NA	NA	NA
	<ul style="list-style-type: none"> Pump House Access 	NA	NA	NA
	<ul style="list-style-type: none"> Terrace level 			
	<ul style="list-style-type: none"> Discharge of pump 	NA	NA	NA
	<ul style="list-style-type: none"> Head of the pump 	NA	NA	NA
	<ul style="list-style-type: none"> Power supply 	NA	NA	NA
	<ul style="list-style-type: none"> Auto starting of pump 	NA	NA	NA
14	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> Under ground tank capacity 	50,000 Ltr.	50,000 Ltr.	MR
	<ul style="list-style-type: none"> Draw of connection 	Required	Provided	MR
	<ul style="list-style-type: none"> Fire service inlet 	Required	Provided	MR

h mer

N/51

	<ul style="list-style-type: none"> • Access to tank • Overhead Tank capacity 	Required 20,000 Ltr.	Provided 20,000 Ltr.	MR MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of lift lobby	NA	NA	NA
	• Communication in lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area			
	• Total area	NA	NA	NA
	• Location	NA	NA	NA
19	Fire control room			
	• Detector system panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	Required	Co2 & DCP	MR

The fire protection systems provided in the building were tested, checked randomly and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/2011/1105 dated 06/06/2011 renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer

Name :- Sh. Gurmukh Singh
Designation :-DO(CD)

Signature of the Inspecting Officer

Name :- Sh. M. K. Sharma
Designation :- A. D.O. (CC)