

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001
Fax: 23412593, Tel:- 011-23414333

NO.F6/ DFS/ MS/School/2014/52/623

Dated: 21/5/14

FIRE SAFETY CERTIFICATE

Certified that, **Manava Bharati India International School**, Located at Panchsheel Park (South), New Delhi-110017, comprised of ground Plus one upper floor (31classroom, 02computer lab,01 library, 04 office, 01 staff room, 04 laboratory,01art room,01 music room, 01audio visual room), owned/occupied by school management was granted FSC by this department vide letter no.F6/DFS/MS/2010/3129 dated: 11/11/2010.The school was re-inspected by the officer concerned of this department on 06/05/2014 in the presence of Mr.Vishal (Admn. Officer) and found that the School have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class - **Educational (School)** with effect from the date of issue of this certificate for a period of three years, subject to compliance of the below mentioned conditions.

Issued on ~~21/5/14~~ at New Delhi by.


(Dr. G.E. Misra)
Chief Fire Officer

9/c
19/5/2014
A201218

Copy to: -

The Principal,
Manava Bharati India International School,
Panchsheel Park (South), New Delhi-110017

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Manav Bharati India International School
Panchsheel Park, New Delhi-110017
2. Type of Occupancy : Educational (School)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2010/3129 dated 11/11/2010
5. Fire Safety directives letter No : F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01-03-2011.
6. Date of inspection : 06-05-2014
7. Name of the Inspecting Officers : ADO D.B.Mukherjee
8. Name and designation of officers
from the building side : Mr Vishal Singh, (Admin)
9. Year of Construction : 1976
10. Applicant's letter No. : MBS/ND/13-14/383 dated: 24/03/2014,
School campus is comprised of three blocks 'A' block-School(Ground Plus one upper floor)
'B' block - Auditorium & 'C' Block-Hostel)

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL/NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Required	Provided	MR
	• Gate width	05 m	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
a. Number of staircases				
• Upper Floors	02	06 nos,		MR
• Basements	N/A	N/A		N/A
b. Width of staircases				
• Upper Floors	1.5 mtr	1.22,1.25,1.35,1.52,1.52,1.40 m		MR
• Basements	N/A	N/A		N/A
c. Protection of exits				
• Fire check door	N/A	N/A		N/A
• Pressurization	N/A	N/A		N/A
e. No. of continuous staircases to terrace	01	10		MR
g. Width of Corridor	N/A	N/A		N/A
h. Door Size	N/A	N/A		N/A

[Signature]

3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	N/A	N/A
5	Fire Extinguishers			
	• Total numbers	Required	25 Nos.	MR
	• Types	ABC,CO ₂	Provided	MR
	• IS marking	Required	Provided	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8	MOEFA			
		N/A	N/A	N/A
9	Public Address System.			
		N/A	N/A	N/A
10	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• Size of riser/down-comer	100 mm	N/A	N/A
	• Number of hydrants per floor	01	N/A	N/A
	• Hose Box	01	N/A	N/A


7/5

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the NOC issued vide letter no.F6/DFS/MS/2010/3129 dated: 11/11/2010, renewal under rules 35 of the Delhi Fire Service Rules 2010 is recommended. Accordingly DFA is put up for perusal and sign pl.

Signature of the Inspecting Officer


12/5/2014

Name (D.B.Mukherjee)
Designation :- Assistant Divisional Officer(BCP)

DO (Month)


13/5/14