

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/School/2014/MOZ/636

Dated: 26/05/14

FIRE SAFETY CERTIFICATE

Certified that the Anglo Arabic Model School, Ajmeri Gate, Delhi-06 , comprises of Ground plus one floor only , was granted NOC by this department vide letter No. F6/DFS/MS/2009/3695 dated 04-12-2009. The premises was re-inspected by the officer concerned of this department on 15-5-2014 in the presence of Mr. Abrar Ahmad Khan (Principal) and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education dated 17.01.2005 and that the premises is fit for occupancy class "B" educational building with effect from2014 for period of three years.

Issued 26/05/2014 at New Delhi by.


(Santokh Singh)

Chief Fire Officer

011-23414250



Copy to:-,

1. Principal,

Anglo Arabic Model School,
Ajmeri Gate, Delhi-06.

2. Director of Education

North Delhi Municipal Corporation
Dr. SPM Civic Centre, JLN Marg, N.D

Conditions for the validity of fire safety certificate are overleaf:-

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Anglo Arabic Model School, Ajmeri Gate, Delhi-06.
 2. Building is comprises of : G+1
 3. Type of Occupancy : Education
 4. Type of Case : Renewal
 5. Details of Previous NOC : No.F6/DFS/MS/2009/3695, dated 4.12.09.
 6. Fire Safety direction letter No : 262-362, dated- 17.01.2005.
 7. Date of Inspection : 15.05.14.
 8. Name of the Inspecting Officers: : Vedpal (ADO)
 9. Name and designation of Officer from the building side : Sh. Abrar Ahmad Khan (Principal)
 10. Year of Construction : 1996.
 11. Applicant's letter No : AAMS/79-RECOG/1317, dated 06.05.2014.

| S.No | Minimum Standards on fire prevention and fire safety as per circular no.262-362, dated17.01.05 | Requirement | Provided at Site | Remarks MR/NMR |
|------|--|-----------------|------------------|----------------|
| 1 | Access to building | | | |
| | Road width | 6 m | 6 m | MR |
| | Gate width | N.A. | N.A. | N.A. |
| | Width of internal road | N.A. | N.A. | N.A. |
| 2 | Number, Width, Type and Arrangement of Exits. | | | |
| | a. Number of Staircases | | | |
| | Upper Floor | 01 no. | 02 nos. | MR |
| | Basement | N.A. | N.A. | N.A. |
| | B. Width of Staircases | | | |
| | Upper Floor | 1.5 m | 100cm&110cm | MR |
| | Basement | N.A. | N.A. | N.A. |
| | c. Protection of exits | | | |
| | Fire check door | N.A. | N.A. | N.A. |
| | Pressurization | N.A. | N.A. | N.A. |
| | e. No. of continuous staircases to terrace | 01no. | 01no. | MR |
| | g. Width of Corridor | 1.5 m | 1.5 m | MR |
| | h. Door Size | 1 m | 1m | MR |
| 3 | Compartmentation | | | |
| | Fire check door | N.A. | N.A. | N.A. |
| | Sealing of electrical shafts | N.A. | N.A. | N.A. |
| | Fire rating of shaft door | N.A. | N.A. | N.A. |
| | Water curtain | N.A. | N.A. | N.A. |
| | Fire Dampers | N.A. | N.A. | N.A. |
| 4 | Smoke Management System. | | | |
| | Basement | 30a/c per hour | N.A. | N.A. |
| | Upper floor | 12 a/c per hour | N.A. | N.A. |

| | | | | |
|----|---|-----------------------|-----------------------|------|
| 5. | Fire Extinguisher | | | |
| | Total numbers | 04 nos. | 10 nos. | MR |
| | types | CO ₂ & ABC | CO ₂ & ABC | MR |
| | IS marking | ISI marked | ISI marked | MR |
| 6 | First-aid-Hose Reels. | | | |
| | Total numbers of each floor | 01no. | 01no. | MR |
| | Length of hose reel hose | 30m | 30m. | MR |
| | Nozzle diameter | 6.5mm | 6.5mm | MR |
| 7 | Automatic fire detection and alarming system. | | | |
| | Type of detectors | N.A. | N.A. | N.A. |
| | Location of main panel | N.A. | N.A. | N.A. |
| | Location of repeater panel | N.A. | N.A. | N.A. |
| | Alternate source of power | N.A. | N.A. | N.A. |
| | Hooters | N.A. | N.A. | N.A. |
| 8 | MOEFA | N.A. | N.A. | N.A. |
| 9 | Public address System. | N.A. | Provided. | MR |
| 10 | Automatic Sprinkler System. | | | |
| | Basement | N.A. | N.A. | N.A. |
| | upper floor | N.A. | N.A. | N.A. |
| | sprinkler above false ceiling | N.A. | N.A. | N.A. |
| 11 | Internal Hydrants | | | |
| | size of riser/down-comer | N.A. | N.A. | N.A. |
| | Number of hydrants per floor | N.A. | N.A. | N.A. |
| | Hose Box | N.A. | N.A. | N.A. |
| 12 | Yard Hydrants. | | | |
| | Total number of hydrants | N.A. | N.A. | N.A. |
| | Hose Box | N.A. | N.A. | N.A. |
| 13 | Pumping Arrangements. | | | |
| | ➤ Ground Level | N.A. | N.A. | N.A. |
| | ➤ Discharge of main Pump | N.A. | N.A. | N.A. |
| | ➤ Head of Main Pump | N.A. | N.A. | N.A. |
| | ➤ Number of main pumps | N.A. | N.A. | N.A. |
| | ➤ Jockey pump out put | N.A. | N.A. | N.A. |
| | ➤ Jockey pump head | N.A. | N.A. | N.A. |
| | ➤ Standby pump out put | N.A. | N.A. | N.A. |
| | ➤ Standby pump Head | N.A. | N.A. | N.A. |
| | ➤ Auto Starting /Manual stopping | N.A. | N.A. | N.A. |
| | ➤ Pump House Access | N.A. | N.A. | N.A. |
| | ➤ Terrace Level | N.A. | N.A. | N.A. |
| | ➤ Discharge of pump | 01no. | 01no. | MR |
| | ➤ Head of the Pump | 220LPM | 220LPM | MR |
| | ➤ Power supply | 40m | 40m. | MR |
| | ➤ Auto Starting of pump | Required | Provided | MR |
| | | N.A. | N.A. | N.A. |

| | | | | |
|----|--|-----------|-----------|------|
| 14 | Captive Water Storage for Fire Fighting. | | | |
| | Underground tank capacity | N.A. | N.A. | N.A. |
| | Draw-off connection | N.A. | N.A. | N.A. |
| | Fire service inlet | N.A. | N.A. | N.A. |
| | Access to tank | N.A. | N.A. | N.A. |
| | Overhead Tank capacity | 2500Ltrs. | 2500Ltrs. | MR |
| 15 | Exit Signage. | N.A. | N.A. | N.A. |
| 16 | Provision of Lifts. | | | |
| | Pressurization of Lift Shaft | N.A. | N.A. | N.A. |
| | Pressurization of Lift lobby | N.A. | N.A. | N.A. |
| | Communication in lift car | N.A. | N.A. | N.A. |
| | Firemen's grounding switch | N.A. | N.A. | N.A. |
| | Lift Signage | N.A. | N.A. | N.A. |
| 17 | Standby power supply | N.A. | N.A. | N.A. |
| 18 | Refuge Area. | | | |
| | Total area | N.A. | N.A. | N.A. |
| | Location | N.A. | N.A. | N.A. |
| 19 | Fire Control Room | | | |
| | Detector system panel | N.A. | N.A. | N.A. |
| | Flow switch panel | N.A. | N.A. | N.A. |
| | PA system panel | N.A. | N.A. | N.A. |
| | Batter backup | N.A. | N.A. | N.A. |
| | Building Floor Plans | N.A. | N.A. | N.A. |
| 20 | Special Fire Protection systems for protection of special Risks, if any: | N.A. | N.A. | N.A. |

The fire protection systems provided in the building were test checked and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the NOC issued vide letter No.F.6/DFS/MS/2009/3695 dated 04.12.09 renewal under rule 35 of the Delhi Fire Service Rule 2010 is recommended.

Signature of the Inspecting Officer

Name: Vedpal

Designation: ADO