

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE:
CONNAUGHT PLACE, NEW DELHI - 110001

Ph: 011-23414333; cfhq.dfire@nic.in


No. F6/DFS/MS/Club/2014/52/644

Date: 27/05/14

FIRE SAFETY CERTIFICATE

Certified that M/s Delhi Gymkhana Club at 2, Safdarjung Road, New Delhi, comprised of ground floor was granted NOC by this department vide letter No. F6/DFS/MS/2011/815 Dated 06.05.2011. The premises was re-inspected by the officer concerned of Delhi Fire Service on 09.05.2014 in the presence of Sh. Col. O.P. Malhotra (Retd), secretary of the club and observed that fire safety norms as required under Rule 33 of Delhi Fire Service Rules, 2010 are deemed complied and that the building / premises is fit for occupancy class-D "Assembly building (Club)" with effect from 27/05/14 for a period of THREE years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010.

Issued on ..27/05/14..... at New Delhi by


27/5
(Dr. G.C. Misra)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. Sh. Dr. P.K. Sharma, Medical Officer, Office of the Medical Officer of Health, NDMC, Palika Kendra, New Delhi.
2. Sh. Col. O.P. Malhotra (Retd), Secretary, M/s Delhi Gymkhana Club at 2, Safdarjung Road, New Delhi

Conditions for the validity of Fire Safety Certificate

1. All the Fire Safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning Authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The Basement shall be used strictly as per the provisions of Building Bye Laws.
5. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1	Name & address of the building	M/s Delhi Gymkhana Club at 2, Safdarjung Road, New Delhi		
2	Type of Occupancy	Assembly "D" Club		
3	Type of case	Renewal		
4	Details of previous NOC	F6/DFS/MS/2011/815 Dated 06.05.2011		
5	Fire safety directives letter No	No		
6	Date of inspection	09.05.2014		
7	Name of the inspecting Officers :	D.O. (South) D.P. Bhardwaj, ADO M.K. Chattopadhyay		
8	Name and designation of officers from the building side	Sh. Col. O.P. Malhotra (Retd), Secretary		
9	Year of construction		ground floor	
10	Applicant's letter No.	MOH/D/230/DSO/(Lic.)SI-7 Dated 7.5.2014		Old Case

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
--------	---	-----------------	------------------	---------------------

1	Access to building			
	1) Road width	Required	12 Mtr Provided	MR
	2) Gate width	Required	4.5 Mtr	MR
	3) Width of internal road	N/A	N/A	N/A

2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	N/A	N/A	N/A
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	N/A	N/A	N/A
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	N/A	N/A	N/A
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	N/A	N/A	N/A

3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A

4	Smoke Management system.			
	basement	30 a/c per hour 12 a/c per hour	N/A	N/A
	upper floors		Natural Ventilation	MR

5	Fire Extinguishers			
	total numbers		30 Nos	MR
	Types		ABC, Co2, water Co2	MR
	ISI marking	ISI	Yes	MR

6	First-Aid Hose Reels.			
	total numbers on each floor			

7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level/ Terrace level			
	a. Discharge of main Pump	450 & 180 LPM	Provided	MR (Old Case)
	b. Head of main pump	70 Mtr	Provided	MR (Old Case)
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	Required	Provided	MR
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	Old Case	15,000 ltr Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.	Not Required		
	total area			
	location			

Fire control room

a. detector system Panel	N/A	N/A	N/A
b. Flow switch Panel	N/A	N/A	N/A
c. PA system Panel	N/A	N/A	N/A
d. Batter backup	N/A	N/A	N/A
e. Building floor plans	N/A	N/A	N/A

20 **Special Fire Protection systems for protection of special risks, if any: N/A.**

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules of NOC issued vide letter no. **F6/DFS/MS/2011/815** Dated **06.05.2011** renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Accordingly DFA is put up for your approval and signature please.

Signature of the inspecting officer

Name D. P. Bhardwaj

Designation : Divisional Officer (South)

Signature of the inspecting officer

Name:- M.K. Chattopadhyay

Designation : ADO (MRD)