

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/Hospital/2014/ND2/629

Dated 22/5/14

FIRE SAFETY CERTIFICATE

Certified that the Panchsheel Hoapital Pvt.Ltd.,C-3/63 A,64 -A ,Yamuna Vihar,Delhi-53, comprised of Basement ground plus three upper floors owned/occupied by Panchsheel Hoapital Pvt.Ltd., have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of this department on dated 15.04.14 in the presence of Dr. V.K.Goyal (Director), and found that the building is fit for occupancy class C 'Institutional Building' with effect from ...22/5/14..... for a period of **three** years, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, subject to conditions printed overleaf.

Issued on...22/5/14.....at New Delhi by



(Dr.G.C.Misra)
Chief Fire Officer
Ph.011-23414333

O/c
for

To,

M/s Panchsheel Hoapital Pvt.Ltd.,
C-3/63 A,64 -A ,Yamuna Vihar,Delhi-53,

Copy to-

The Directorate of Health Services
M.O. I/C Nursing Home Cell,
Govt. of NCT of Delhi, F-17, Karkardooma, Delhi-32.

CONDITIONS:

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety Certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. Basement shall be used as per BBL.

1. Name & address of the building : Panchsheel Hospital Private Limited,
C-3/63-A, 64-A, Yamuna Vihar, Delhi -110053.
2. Building is comprised of : Basement & Ground plus three upper floor
3. Type of Occupancy : Institutional
4. Type of Case : **New**
5. Details of Previous NOC letter : Nil
6. Fire Safety direction letter No : **NBC. Part-IV**
7. Date of Inspection : **15/04/2014**
8. Name of the Inspecting officers : ADO Vijay Bahadur
9. Name and designation of Officer:
from the building side : Dr. V.K. Goyal (Director)
10. Year of Construction : **1992**
11. Applicant's letter No : Letter No.- Nil, Dated-20/01/2014

S.NO	Minimum Standards on fire prevention and fire safety U/R33	NBC Part-IV Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	06 mtr. N/A N/A	06 mtr. N/A N/A	MR N/A N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	01 No. 01 No.	03 Nos. 03 Nos.	MR MR
	B. Width of Staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	2.00 mtr. 2.00 mtr	2.05 M, 1.0 M, & 1.01 Mtr. 2.05 M, 1.0 M, & 1.01Mtr.	MR MR
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	Required N/A	Provided N/A	MR N/A
	d. No. of continuous staircases to terrace	01 Nos.	03 Nos.	MR
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	1.0 Mtr.	1.0 mtr.	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 	Required N/A N/A N/A N/A	Provided N/A N/A N/A N/A	MR N/A N/A N/A N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basement • Upper floor 	Required Required	Ventilated Ventilated	MR MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • types • IS marking 	12 nos. ABC /CO ₂ ISI marked	14 nos. ABC /CO ₂ ISI marked	MR MR MR

❖ Travel Distance Meet with one staircase of 2.0 mtrs.wide.

6	First-aid-Hose Reels.			
	Total numbers on each floor	01 No.	01 No.	MR
	• Length of hose reel hose	30 mtr.	30 mtr.	MR
	• Nozzle diameter	05 mm	05 mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	Smoke or Heat	Smoke	MR
	• Location of main panel	Required	Provided	MR
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	Required	Provided	MR
	• Hooter's location	Required at different locations	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	Required	provided	MR
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	01 no.	01 no.	MR
	• Hose Box	01 no.	01 no.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level	Required	Provided	MR
	➤ Discharge of pump	900 Lpm.	900 Lpm.	MR
	➤ Head of the Pump	40 M	40 M	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	25,000 Ltr.	25,000 Ltr.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	Required	Provided	MR
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	Required	Provided	MR
	• Firemen's grounding switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR

N/3


		Required	Provided	MR
17	Standby power supply			
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

DO (B/D)

Signature of the Inspecting Officer
Name
Designation


Vijay Behadur
A.D.O