

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

Fax : 23412593, E-mail: cfohq.dlfire@nic.in, Tel:- 011-23414333

NO.F6/DFS/MS/EH/2014/52/654

Dated: 29/05/14

FIRE SAFETY CERTIFICATE

Certified that M/s 1, Boulevard (A unit of Lazeez hospitality Pvt. Ltd.) located at G-11 to G-14, ground floor at Salcon Rasvilas, D-1, District Market, Saket, New Delhi comprised of three tier basements, ground and five upper floors was granted NOC by this department vide letter No. F6/MS/DFS/EH/2011/159 dated 27.01.2011. The restaurant was re-inspected by the officer concerned of this department on 21-05-2014 in presence of Mr. Rakesh Lakhera, General Manager and observed that the said restaurant have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and that the premises / building is fit for occupancy class- D (Assembly Building) with effect from 29/05/14 for a period of 3(three) years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi fire service Rules,2010.

Issued on 29/05/14 at New Delhi by.


(Dr. G.C. MISRA)
CHIEF FIRE OFFICER

Copy to: -

1. The Deputy Health Officer, MCD, South Zone, Green Park, New Delhi
2. The General Manager, M/s 1, Boulevard (A unit of Lazeez hospitality Pvt. Ltd.), G-11 to G-14, ground floor, Salcon Rasvilas, D-1, District Market, Saket, New Delhi

Conditions for the validity of fire safety certificate

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : M/s 1, Boulevard (A unit of Lazeez hospitality Pvt. Ltd.), G-11 to G-14, ground floor, Salcon Rasvilas, D-1, District Market, Saket, New Delhi
2. Type of Occupancy : Assembly
3. Type of Case : Renewal
4. Details of previous NOC : F6/MS/DFS/EH/2011/159 dated 27.01.2011.
5. Fire Safety directives letter No : Delhi Fire Service Act-2007 & Rules 2010.
6. Date of inspection : 21-05-2014
7. Name of the Inspecting Officers : M.K.Chattopadhyay, ADO(M.Rd)
8. Name and designation of officers
9. from the building side : Mr. Rakesh Lakhera, General Manager
10. Year of Construction : 2008-09
11. Applicant's letter No. : nil dated 22.04.2014.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mts	Provided	MR
	• Gate width	----	Directly accessible from the road	MR
	• Width of internal road	06 mts	Provided in mall	MR
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-	-	-
	• Upper Floors	Restt. Located at GF	05 stair provided for mall	----
	• Basements	N/A	05 stair provided for mall	----
	b. Width of staircases	-	-	-
	• Upper Floors	Restt. Located at GF	1.5 mts each for mall	----
	• Basements	N/A	1.5 mts each for mall	----
	c. Protection of exits	---	---	---
	• Fire check door	N/A	Provided in mall	----
	• Pressurization	N/A	Provided in mall	----
	d. No. of continuous staircases to terrace	N/A	(05) Provided in mall	----
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	1.5 mts	1.70 mts, 0.80, 0.90 & 0.65 mts	MR
3	Compartmentation.			



	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A	Provided in mall	----
		N/A	Provided in mall	----
		N/A	Provided in mall	----
		N/A	N/A	N/A
		N/A	Provided in mall	----
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	Provided in mall	----
		12 a/c per hour	Venting provided in kitchen	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	04 ABC, CO ₂ ISI marked	Provided	MR
			Provided	MR
			Provided	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	01 30 m 5 mm	Provided	MR
			Provided	MR
			Provided	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	N/A N/A N/A N/A N/A	Provided Provided N/A Provided Provided	---- ---- N/A ---- ----
8	MOEFA	Required	Provided	MR
9	Public Address System.	N/A	Provided in mall	----
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	N/A Required N/A	Provided in mall Provided in restaurant N/A	---- MR N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	N/A N/A N/A	Provided Provided Provided	---- ---- ----

12	Yard Hydrants.			
	• Total number of hydrants	N/A	Provided in mall	----
	• Hose Box	N/A	Provided in mall	----
13	Pumping Arrangements.			
	• Ground Level	-	-	-
	➤ Discharge of main Pump	N/A	Provided in mall.	----
	➤ Head of Main pump	N/A	Provided in mall.	----
	➤ Number of main pumps	N/A	Provided in mall.	----
	➤ Jockey Pump out put	N/A	Provided in mall.	----
	➤ Jockey pump head	N/A	Provided in mall.	----
	➤ Standby Pump out put	N/A	Provided in mall.	----
	➤ Standby Pump Head	N/A	Provided in mall.	----
	➤ Auto Starting/ Manual stopping	N/A	Provided in mall.	----
	➤ Pump House Access			
	• Terrace level	---	---	---
	➤ Discharge of pump	450 LPM	Connected to mall & restaurant.(900 LPM)	MR
	➤ Head of the pump	50 mts	Provided in mall.	MR
	➤ Power Supply	Required	Provided in mall	MR
	➤ Auto Starting of pump	Required	Provided in mall.	MR
14	Captive Water Storage for fire fighting. Maintained by mail			
	• Underground tank capacity	N/A	Provided in mall. 1,50,000 lts	----
	➤ Draw-off connection	N/A	Provided in mall.	----
	➤ Fire service inlet	N/A	Provided in mall.	----
	➤ Access to tank	N/A	Provided in mall.	----
	• Overhead Tank capacity	10,000 lts	Connected to mall & restaurant.(20,000 lts)	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	Provided in mall.	----
	• Pressurization of Lift lobby	N/A	Provided in mall.	----
	• Communication In lift Car	N/A	Provided in mall.	----
	• Fireman's Grounding Switch	N/A	Provided in mall.	----


	• Lift Signage	N/A	Provided in mall.	----
17	Standby power supply	Required	Provided in mall.	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	Provided in mall.	----
	• Flow Switch Panel	N/A	Provided in mall.	----
	• PA System Panel	N/A	Provided in mall.	----
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	01 CO ₂ type fire extinguishers found provided near elect. panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F6/MS/DFS/EH/2011/159 dated 27.01.2011, renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

DFA is put up for approval & signature please.

Do(Sx) - Admitted in Hospital


 21/5/14
 Signature of the Inspecting Officer
 Name M.K. CHATTOPADHYAY
 Designation: - Asstt. Div. Officer (M.Rd)