

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/2014/WZ/ 665

Dated: 30 / 05 / 2014

FIRE SAFETY CERTIFICATE

Certified that North Gate Orbit Plaza, Gujranwala town, Delhi-110009 comprised of 02 Basement + Ground + Three Upper Floors owned/occupied by M. N Securities Pvt. Ltd. was issued fire safety certificate by this department vide letter no. F.6/DFS/MS/2010/2488 Dated 27/08/2010 The premises was re-inspected by the officer concerned of this department on 01/05/2014 in the presence of Sh. Mukesh Arora and found that the building have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010, and premise is fit for class Group 'F' Mercantile Building (Shopping Mall) with effect from 30 / 05 / 2014 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rule, 2010.

1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able by guests in an event of emergency.
2. All employees shall be acquainted with the use and maintenance of all the fire fighting installation/equipments.
3. The fire suppression / protection arrangements provided in the guest house are to minimize losses, if maintained in good working condition. These systems cannot give any guarantee that there will be no fire or losses in the event of one.
4. Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the licensee.
5. This report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on... 30 / 05 / 14 at New Delhi.


Santokh Singh
Chief Fire Officer
Delhi Fire Service
E-mail : cfowz.dlfire@nic.in
Phone : 011-23414250

Copy to:-

1. Sh. Mukesh Arora, Authorized signatory, M. N. Securities Pvt. Ltd, Statesman House, 8th Floor, Barakhamba Road, New Delhi 110001

2/14

INSPECTION REPORT**02 Basement + G + Three upper floors**

1. Name & address of the building : North Gate Mall, Gujranwala Town - II, Delhi-
2. Type of Occupancy : Shopping Mall, Mercantile (Group- F)
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/2010/2488 Dated 27/08/2010
5. Fire Safety directives letter No : F.6/DFS/MS//BP/2006/3738 Dated 21/02/2006
6. Date of inspection : 01/05/2014
7. Name of the Inspecting Officers : DCFO (WZ) & DO (NW)
8. Name and designation of officers
from the building side : Mukesh Arora
9. Year of Construction :
10. Applicant's letter No. : L.No- Nil dated 21/04/2014

S. No	Minimum Standards on fire prevention and fire safety U/R 33	BBL & NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	24 m	P	M.R. ✓
	• Gate width	06 m	P	M.R. ✓
	• Width of internal road	06 m	P	M.R. ✓
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	06	P	M.R. ✓
	• Basements	06 + 02 ramp	P	M.R. ✓
	b. Width of staircases			
	• Upper Floors	Old case	Old case	Old case ✓
	• Basements	Old case	Old case	Old case ✓
	c. Protection of exits			
	• Fire check door	R	P	M.R. ✓
	• Pressurization	N.A	Stairs open to sky	N.A ✓
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	1.5 mtr	P	M.R. ✓
	f. Door Size	Old case	Old case	Old case ✓



3	Compartmentation.			
	➤ Fire check door	R	P	M.R. ✓
	➤ Sealing of electrical shafts	R	P	M.R. ✓
	➤ Fire Rating of shaft door	R	P	M.R. ✓
	➤ Water Curtain	R	P	M.R. ✓
	➤ Fire Dampers	R	P	M.R. ✓
4	Smoke Management System.			
	➤ Basements	30 a/c per hour	P	M.R. ✓
	➤ Upper floors	12 a/c per hour	P	M.R. ✓
5	Fire Extinguishers			
	➤ Total numbers	64 One @ 300 m ²	W co ₂ , DCP type	M.R. ✓
	➤ Types		P	M.R. ✓
	➤ IS marking	ISI marked	yes	M.R. ✓
6	First-Aid Hose Reels.			
	• Total numbers on each floor	06 at each floor	P	M.R. ✓
	• Length of hose reel hose	30mm	P	M.R. ✓
	• Nozzle diameter	5mm	P	M.R. ✓
7	Automatic fire detection and alarming system.			
	➤ Type of detectors	Smoke & heat	P	M.R. ✓
	➤ Location of Main Panel	GF	P	M.R. ✓
	➤ Location of Repeater Panel	Each floor	P	M.R. ✓
	➤ Alternate source of power	R	P	M.R. ✓
	➤ Hooters' Location	Comman areas	P	M.R. ✓
8	MOEFA	R	P	M.R. ✓
9	Public Address System.	R	P	M.R. ✓
10	Automatic Sprinkler System.			
	➤ Basement	R	P	M.R. ✓
	➤ Upper Floor	R	P	M.R. ✓
	➤ Sprinkler above false ceiling	R	P	M.R. ✓

11	Internal Hydrants			
	➤ Size of riser/down-comer	100 mm	P	M.R.
	➤ Number of hydrants per floor	06	P	M.R.
	➤ Hose Box	06	P	M.R.
12	Yard Hydrants.			
	➤ Total number of hydrants	10	P	M.R.
	➤ Hose Box	R	P	M.R.
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	2280 LPM	P	M.R.
	➤ Head of Main pump	60 M	P	M.R.
	➤ Number of main pumps	02	P	M.R.
	➤ Jockey Pump out put	180 LPM	P	M.R.
	➤ Jockey pump head	60 M	P	M.R.
	➤ Standby Pump out put	2280 LPM	P	M.R.
	➤ Standby Pump Head	60 M	P	M.R.
	➤ Auto Starting/ Manual stopping	R	P	M.R.
	➤ Pump House Access	R	P	M.R.
	• Terrace level			
	➤ Discharge of pump	—	—	—
	➤ Head of the pump	—	—	—
	➤ Power Supply	—	—	—
	➤ Auto Starting of pump	—	—	—
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	3,00,000 ltr	P	M.R.
	➤ Draw-off connection	R	P	M.R.
	➤ Fire service inlet	R	P	M.R.
	➤ Access to tank	R	P	M.R.
	• Overhead Tank capacity	30,000 Ltr	P	MR
15	Exit Signage.	R	P	MR
16	Provision of Lifts.			

	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	R	P & F	M.R
		—	—	—
		R	P	M.R
		R	P	M.R
		R	P	M.R
17	Standby power supply	R	P	M.R
18	Refuge Area.	R	P	M.R
	➤ Total Area	N.A	N.A	N.A
	➤ Location	N.A	N.A	N.A
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	R	P	M.R
		R	P	M.R
		R	P	M.R
		R	P	M.R
		R	P	M.R
20	Special Fire Protection Systems for Protection of special Risks, if any:		No special risk seen at time of inspection	

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/2010/2488 Dated 27/08/2010 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

27/5/14
16/5/14

Signature of the Inspecting Officer

Name

Designation

Signature of the Inspecting Officer

Name

Designation

