

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/ school/2014/w2/658

Dated: 30/05/2014

FIRE SAFETY CERTIFICATE

Certified that the **Margshree School** at **Najafgarh Road, Nangloi, Delhi-41**, comprised of **Ground + Two Upper Floors** owned / occupied by **Margshree School**, has already been issued Fire Safety Certificate **Vide letter No. F6/DFS/MS/2009/3654 dated 2.12.2009**. The premises was re-inspected by the officer concerned of Fire Service on **20.05.2014** in the presence of **Sh. Prakash** and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with **Directorate of Education, Circular No. 262-362 dated 17.01.2005** and that the building / premises is fit for occupancy class-B **Educational** with effect from 30/05/2014 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 30/05/14 **at New Delhi by.**


(SANTOKH SINGH)
CHIEF FIRE OFFICER.
Phone:-23414250

Copy to :-

1. The Principal, Margshree School, Najafgarh Road, Nangloi, Delhi-41
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-110054.

N/S Total Area = 8000 m²
 Covered Area = 5,000 m² G+2

INSPECTION REPORT

1. Name & address of the building: Mary Shree School, Najafgarh Rd. Nangloi, Delhi - 110041
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : Letter No F6/DFS/MS/09/3654/2.12.09
5. Fire Safety directives Letter No. : D.O.E circular 262-362/17.01.2005
6. Date of inspection : 20/05/2014
7. Name of the Inspecting Officer : Ashok Kumar Jaiswal
8. Name and designation of Officer
 from the building side : Prakash
9. Year of Construction : 2005
10. Applicant's letter No. : Nil 8/5/2014

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL/NBC/DOE Requirements ^{17.1.05}	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	<u>Accessible</u>	<u>Provided</u>	<u>MR</u>
	• Gate width	<u>Accessible</u>	<u>Provided</u>	<u>MR</u>
	• Width of internal road	<u>NA</u>	<u>NA</u>	<u>NA</u>
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	<u>2</u>	<u>Provided</u>	<u>MR</u>
	• Basements	<u>NA</u>	<u>NA</u>	<u>NA</u>
	b. Width of staircases			
	• Upper floors	<u>old case</u>	<u>old case</u>	<u>old case</u>
	• Basements	<u>NA</u>	<u>NA</u>	<u>NA</u>
	c. Protection of exits			
	• Fire check door	<u>NA</u>	<u>NA</u>	<u>NA</u>
	• Pressurization	<u>NA</u>	<u>NA</u>	<u>NA</u>
	d. No of continuous staircase to terrace	<u>1</u>	<u>1</u>	<u>MR</u>
	e. Width Of Corridor	<u>old case</u>	<u>old case</u>	<u>old case</u>
	f. Door Size	<u>old case</u>	<u>old case</u>	<u>old case</u>
3.	Compartmentation			
	• Fire check door	<u>NA</u>	<u>NA</u>	<u>NA</u>
	• Sealing of electrical shafts	<u>NA</u>	<u>NA</u>	<u>NA</u>
	• Fire Rating of shaft door	<u>NA</u>	<u>NA</u>	<u>NA</u>
	• Water Curtain	<u>NA</u>	<u>NA</u>	<u>NA</u>
	• Fire Dampers	<u>NA</u>	<u>NA</u>	<u>NA</u>

4.	Smoke managements System			
	<ul style="list-style-type: none"> Basements 	30 a/c per hour	NA	NA
	<ul style="list-style-type: none"> Upper floors 	12 a/c per hour	Natural ventilation	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	17	18	MR
	<ul style="list-style-type: none"> Types 	ABC / CO ₂	Provided	MR
	<ul style="list-style-type: none"> IS marking 	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor 	1	1	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30 Mtr.	30 Mtr.	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm.	5 mm.	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detector Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NR		
8.	MOEFA	NR	NR	NR
9.	Public Address System	NR	NR	NR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NR		
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down- comer 	100 mm.	100 mm	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	1	1	MR
	<ul style="list-style-type: none"> Hose Box 	1	1 at each floor	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NR		



18.	Refuge Area			
	➤ Total area	NR	NR	NR
	➤ Location	NR	NR	NR
19.	Fire control room			
	➤ Detector system panel	NR	NR	NR
	➤ Flow Switch Panel			
	➤ PA System Panel			
	➤ Batter backup			
	➤ Building Floor Plans			
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers

In view of the deemed compliance of the minimum standards of fire prevention & fire safety measures, as required under the rules, Noc issued vide letter No. F6/DFS MS/09/3654/2.12.2009, renewal under the rule 35 of the Delhi Fire Service Rules, 2010 is recommended.

Ak jaiswal
20/5/14
Signature of the Inspecting Officer

Signature of the Inspecting

~~Officer~~

Name :- (Ashok Kumar Jaiswal)

Name

Designation :- A.D.O. (Jwalapuri)

Designation

CFD/589
28/5/14
20/5/14
DELHI FIRE SERVICE